

MIDDLE GEORGIA, GA, USA

WMO: 722170

Lat: 32.685N

Lon: 83.653W

Elev: 105

StdP: 100.07

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03813

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.6	-2.7	-13.4	1.2	1.9	-10.8	1.5	2.5	9.4	10.7	8.7	10.0	2.1	300	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	35.9	24.0	34.7	23.9	33.6	23.8	26.0	32.1	25.5	31.4	25.1	30.7	3.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	19.7	28.2	24.0	19.1	27.6	23.5	18.6	27.2	80.9	32.3	78.7	31.6	76.7	30.7	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.2	6.1	DB	-8.1	37.5	1.8	1.8	-9.4	38.9	-10.5	39.9	-11.5	41.0	-12.8	42.3	(4)
(5)			WB	-9.1	27.2	1.9	0.9	-10.5	27.8	-11.6	28.3	-12.7	28.8	-14.1	29.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	8.3	10.4	14.0	17.9	22.4	26.1	27.5	27.1	24.2	18.6	12.9	9.6	(6)	
	DBStd	7.85	5.30	4.90	4.57	3.72	3.21	2.18	1.69	1.88	2.84	4.15	4.49	4.94	(7)	
	HDD10.0	257	99	51	17	1	0	0	0	0	0	1	20	69	(8)	
	HDD18.3	1235	313	224	146	53	7	0	0	0	2	48	171	272	(9)	
	CDD10.0	3283	44	62	140	237	384	482	544	531	426	267	108	58	(10)	
	CDD18.3	1220	1	2	11	39	133	232	286	272	177	56	8	2	(11)	
	CDH23.3	11929	3	14	123	440	1391	2266	2921	2647	1548	497	71	9	(12)	
	CDH26.7	5309	0	0	16	104	565	1091	1455	1270	668	133	8	0	(13)	
(14) Wind	WSAvg	2.5	2.9	2.9	3.0	2.8	2.5	2.3	2.1	2.0	2.3	2.3	2.4	2.6	(14)	
(15) Precipitation	PrecAvg	1154	111	114	117	87	80	102	117	100	84	58	76	110	(15)	
	PrecMax	1854	286	327	302	214	210	311	461	259	322	184	261	321	(16)	
	PrecMin	823	25	9	11	3	0	23	9	27	9	0	12	15	(17)	
	PrecStd	205	57	60	69	53	46	54	76	54	66	51	48	64	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.5	25.2	28.6	30.8	34.9	36.9	37.0	37.3	35.7	31.9	27.9	24.6	(19)	
		MCWB	17.6	17.8	17.9	20.1	22.0	23.6	24.2	24.7	23.0	22.1	19.7	18.5	(20)	
	2%	DB	21.4	23.1	26.4	29.3	32.9	35.2	35.7	35.6	33.8	29.7	25.3	22.4	(21)	
		MCWB	16.4	16.4	17.5	19.2	21.6	23.4	24.3	24.4	22.8	20.8	17.9	17.6	(22)	
	5%	DB	19.5	21.1	24.5	27.8	31.5	33.8	34.5	34.0	32.1	28.1	23.4	20.4	(23)	
		MCWB	15.5	15.5	16.5	18.8	21.2	23.4	24.3	24.4	22.7	20.0	17.2	16.7	(24)	
	10%	DB	17.4	19.1	22.6	26.1	30.0	32.3	33.3	32.6	30.7	26.3	21.3	18.3	(25)	
		MCWB	14.3	14.3	15.5	17.9	20.7	23.2	24.3	24.2	22.5	19.3	16.4	15.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.3	19.7	20.5	22.4	24.5	26.1	26.9	26.9	25.3	24.5	21.9	20.4	(27)	
		MCDB	21.5	22.5	24.8	27.6	30.3	32.1	33.1	33.3	30.2	27.9	24.4	22.2	(28)	
	2%	WB	17.9	18.3	19.2	21.3	23.5	25.4	26.1	26.0	24.7	23.2	20.4	18.9	(29)	
		MCDB	20.1	21.4	23.3	26.3	29.1	31.8	32.3	32.0	29.6	27.0	22.9	21.0	(30)	
	5%	WB	16.6	17.0	18.2	20.4	22.7	24.8	25.6	25.5	24.2	22.2	19.0	17.6	(31)	
		MCDB	18.9	19.9	22.4	25.0	28.4	30.9	31.6	31.2	29.0	25.5	21.9	19.8	(32)	
	10%	WB	14.8	15.5	17.0	19.4	22.0	24.2	25.1	25.1	23.7	21.1	17.5	15.8	(33)	
		MCDB	17.0	18.3	21.1	23.9	27.4	29.7	30.8	30.4	28.1	24.3	20.5	18.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	12.5	13.3	13.8	13.4	11.7	11.3	11.1	11.7	13.3	13.8	12.1	(35)	
		MCDBR	13.6	14.0	15.3	15.6	15.0	13.9	13.1	13.0	14.0	14.7	15.3	13.4	(36)	
	5% WB	MCWBR	9.2	8.4	7.7	6.8	5.3	4.3	3.8	3.9	4.9	6.7	8.4	8.9	(37)	
		MCWBR	11.1	11.3	12.2	12.0	12.0	11.4	11.2	10.9	11.0	10.5	11.3	10.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.325	0.327	0.355	0.388	0.438	0.479	0.522	0.521	0.426	0.379	0.349	0.325	(40)	
		taud	2.509	2.495	2.441	2.339	2.238	2.182	2.070	2.064	2.318	2.426	2.460	2.524	(41)	
	Ebn at Noon		896	930	924	902	855	816	779	773	841	859	857	874	(42)	
		Edh at Noon	86	96	109	126	141	148	165	164	122	102	90	81	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.86	3.45	4.53	5.66	6.25	6.20	6.05	5.48	4.81	4.13	3.17	2.46	(44)	
	RadStd		0.15	0.39	0.36	0.39	0.48	0.46	0.33	0.28	0.45	0.47	0.26	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+0.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+154	+101	(46)
(47) Regional (40 neighbors)		+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+179	+124	(47)

Nomenclature: See separate page