

ROBINS AFB, GA, USA

WMO: 722175

Lat: 32.633N

Lon: 83.600W

Elev: 294

StdP: 14.54

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13860

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.7	28.0	9.1	8.9	35.4	13.6	11.1	38.0	23.8	47.6	21.0	47.9	6.4	330	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	96.8	75.8	94.8	75.7	92.7	75.4	79.7	90.3	78.5	88.7	77.7	87.6	8.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.2	143.2	83.4	76.0	137.3	82.2	75.1	133.2	81.4	43.3	90.2	42.2	88.9	41.2	87.7	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.4	16.8	14.4	18.4	99.5	3.6	3.5	15.8	102.1	13.7	104.1	11.7	106.0	9.1	108.6		
			16.5	81.7	3.6	1.6	13.9	82.8	11.8	83.8	9.8	84.7	7.2	85.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.5	47.2	51.5	58.3	65.1	73.1	79.2	81.9	80.9	75.7	65.7	56.0	50.8
	DBStd	13.91	9.42	8.87	8.35	6.80	5.64	4.06	3.11	3.40	5.12	7.23	7.96	8.77
	HDD50	408	169	81	25	1	0	0	0	0	0	2	30	100
	HDD65	2084	554	382	237	83	10	0	0	0	3	80	289	446
	CDD50	6072	82	124	281	453	715	877	990	958	772	488	209	123
	CDD65	2273	2	5	28	84	260	427	525	493	325	102	17	5
	CDH74	22076	8	42	294	931	2632	4190	5475	4798	2705	841	130	30
	CDH80	9781	0	3	48	251	1085	2031	2724	2272	1138	216	13	0
Wind	WSAvg	6.0	6.9	7.0	7.3	6.9	6.1	5.6	5.4	5.0	5.0	5.3	5.5	6.1
Precipitation	PrecAvg	47.1	4.0	4.2	4.8	3.5	2.6	4.7	5.2	4.3	3.6	2.7	3.2	4.5
	PrecMax	73.5	10.4	12.8	11.4	7.6	5.8	12.2	12.0	10.2	12.7	8.7	8.3	12.7
	PrecMin	33.8	1.4	0.7	0.6	0.9	0.0	1.6	1.9	1.3	0.1	0.2	0.4	1.1
	PrecStd	9.3	1.9	2.3	2.8	2.0	1.4	2.3	2.2	2.2	3.0	2.1	2.0	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.1	78.6	84.4	89.0	95.3	99.2	99.2	99.1	95.9	89.4	81.9	77.4
		MCWB	64.1	64.9	66.3	69.8	73.1	75.6	76.1	76.4	73.4	73.1	68.7	66.6
	2%	DB	71.1	74.6	81.0	85.9	91.5	95.6	96.5	95.7	92.3	85.3	77.7	73.2
		MCWB	62.2	62.3	64.7	67.5	71.9	75.6	76.7	76.4	73.7	70.3	64.2	64.4
	5%	DB	67.2	70.9	77.2	83.0	89.1	93.1	94.3	93.1	89.8	82.0	74.1	69.5
		MCWB	60.2	60.4	62.0	66.1	70.9	75.3	76.3	76.3	73.8	68.5	62.7	62.9
	10%	DB	63.4	67.2	73.4	80.0	86.3	90.6	91.9	90.7	86.9	79.1	70.4	65.9
		MCWB	57.8	58.4	60.2	64.6	70.0	75.0	76.1	75.8	73.0	67.1	62.2	60.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.2	68.5	70.4	73.0	77.0	80.8	81.3	81.1	78.3	76.4	71.9	69.7
		MCDB	71.1	74.3	78.0	83.6	87.6	91.8	92.7	90.5	87.2	82.9	77.5	73.3
	2%	WB	64.7	65.8	68.1	70.9	75.0	78.8	79.5	79.7	77.2	74.3	69.3	67.1
		MCDB	68.5	71.6	75.5	80.4	85.1	89.7	90.4	89.8	85.9	80.5	73.2	70.3
	5%	WB	62.4	63.3	66.0	69.1	73.5	77.5	78.4	78.5	76.1	72.3	66.6	64.8
		MCDB	66.0	67.9	73.2	77.4	83.6	88.5	89.0	88.1	84.6	78.5	71.0	68.4
	10%	WB	59.0	60.7	63.6	67.4	72.4	76.4	77.5	77.5	75.0	70.2	63.9	62.0
		MCDB	62.6	65.6	69.9	75.4	82.1	86.6	87.8	86.6	82.8	75.5	68.3	65.5
Mean Daily Temperature Range	5% DB	MDBR	21.7	22.4	23.5	24.6	23.7	20.8	19.9	19.5	20.4	22.7	24.1	21.5
		MCDBR	24.6	25.4	27.3	27.7	26.5	24.7	22.8	22.6	23.8	25.0	26.9	24.1
		MCWBR	16.5	14.8	13.0	11.3	9.3	7.9	6.9	7.0	8.2	11.5	14.9	16.0
	5% WB	MCDBR	20.2	20.9	22.0	22.1	21.9	21.5	20.1	19.6	19.3	18.5	19.4	19.7
		MCWBR	15.9	15.1	12.7	11.6	8.9	8.2	7.2	7.1	7.5	9.7	13.4	15.4
Clear-Sky Solar Irradiance	taub	0.325	0.328	0.356	0.388	0.438	0.480	0.522	0.521	0.426	0.379	0.349	0.326	
	taud	2.508	2.493	2.440	2.339	2.238	2.182	2.070	2.065	2.318	2.425	2.460	2.522	
	Ebn at Noon	284	295	293	286	271	259	247	245	266	272	272	277	
	Edh at Noon	27	30	35	40	45	47	52	52	39	32	29	26	
All-Sky Solar Radiation	RadAvg	910	1097	1440	1797	1984	1966	1922	1739	1529	1312	1007	782	
	RadStd	46	121	115	115	125	151	145	104	89	143	148	83	78

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.86	N/A	N/A	N/A	N/A	+0.68	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+320	+221

Nomenclature: See separate page