

ROBINS AFB, GA, USA

WMO: 722175

Lat: 32.633N

Lon: 83.600W

Elev: 90

StdP: 100.25

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13860

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.2	-12.7	1.3	1.9	-10.2	1.6	3.3	10.6	8.6	9.4	8.9	2.9	330	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	36.0	24.3	34.9	24.3	33.7	24.1	26.5	32.4	25.8	31.5	25.4	30.9	3.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.5	28.6	24.4	19.6	27.9	23.9	19.0	27.5	82.8	32.3	80.2	31.6	77.9	30.9	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
8.7	7.5	6.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-7.6	37.5	2.0	1.9	-9.0	38.9	-10.2	40.0	-11.3	41.1	-12.7	42.5
			-8.6	27.6	2.0	0.9	-10.1	28.2	-11.2	28.8	-12.4	29.3	-13.8	29.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	8.4	10.9	14.6	18.4	22.8	26.2	27.7	27.2	24.3	18.7	13.3	10.4	(6)
(7)		DBStd	7.73	5.24	4.93	4.64	3.78	3.13	2.26	1.73	1.89	2.84	4.02	4.42	4.87	(7)
(8)		HDD10.0	227	94	45	14	1	0	0	0	0	1	17	56		(8)
(9)		HDD18.3	1158	308	212	132	46	6	0	0	2	44	161	248		(9)
(10)		CDD10.0	3373	46	69	156	252	397	487	550	532	429	271	116	68	(10)
(11)		CDD18.3	1263	1	3	16	47	144	237	292	274	181	57	9	3	(11)
(12)		CDH23.3	12264	4	23	163	517	1462	2328	3042	2666	1503	467	72	17	(12)
(13)		CDH26.7	5434	0	2	27	139	603	1128	1513	1262	632	120	7	0	(13)
(14)	Wind	WSAvg	2.7	3.1	3.1	3.3	3.1	2.7	2.5	2.4	2.2	2.4	2.4	2.7	(14)	
(15)	Precipitation	PrecAvg	1197	102	106	121	88	65	119	133	108	91	68	81	115	(15)
(16)		PrecMax	1867	265	324	290	194	148	309	305	260	322	222	210	323	(16)
(17)		PrecMin	858	35	19	14	24	1	41	47	33	3	5	11	27	(17)
(18)		PrecStd	235	47	59	71	52	36	59	55	55	75	54	50	69	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	25.9	29.1	31.7	35.2	37.3	37.3	35.5	31.9	27.7	25.2	(19)	
(20)		MCWB	17.8	18.3	19.1	21.0	22.8	24.2	24.5	24.7	23.0	22.8	20.4	19.2	(20)	
(21)		2%	DB	21.7	23.6	27.2	29.9	33.0	35.3	35.8	35.4	33.5	29.6	25.4	22.9	(21)
(22)		MCWB	16.8	16.8	18.2	19.7	22.2	24.2	24.8	24.7	23.1	21.3	17.9	18.0	(22)	
(23)		5%	DB	19.5	21.6	25.1	28.3	31.7	34.0	34.6	33.9	32.1	27.8	23.4	20.8	(23)
(24)		MCWB	15.7	15.8	16.7	19.0	21.6	24.1	24.6	24.6	23.2	20.3	17.0	17.2	(24)	
(25)		10%	DB	17.5	19.6	23.0	26.7	30.2	32.5	33.3	32.6	30.5	26.1	21.4	18.8	(25)
(26)		MCWB	14.3	14.7	15.7	18.1	21.1	23.9	24.5	24.3	22.8	19.5	16.8	16.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	20.3	21.3	22.8	25.0	27.1	27.4	27.3	25.7	24.7	22.2	20.9	(27)
(28)		MDCB	21.7	23.5	25.6	28.7	30.9	33.2	33.7	32.5	30.6	28.3	25.3	22.9	(28)	
(29)		2%	WB	18.2	18.8	20.1	21.6	23.9	26.0	26.4	26.5	25.1	23.5	20.7	19.5	(29)
(30)		MDCB	20.3	22.0	24.2	26.9	29.5	32.1	32.5	32.1	29.9	26.9	22.9	21.3	(30)	
(31)		5%	WB	16.9	17.4	18.9	20.6	23.1	25.3	25.8	24.5	22.4	19.2	18.2	(31)	
(32)		MDCB	18.9	19.9	22.9	25.2	28.7	31.4	31.7	31.2	29.2	25.8	21.7	20.2	(32)	
(33)		10%	WB	15.0	15.9	17.6	19.7	22.5	24.7	25.3	25.3	23.9	21.2	17.7	16.7	(33)
(34)		MDCB	17.0	18.7	21.0	24.1	27.9	30.3	31.0	30.3	28.2	24.1	20.2	18.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	12.1	12.5	13.1	13.7	13.2	11.6	11.1	10.9	11.3	12.6	13.4	11.9	(35)	
(36)		5% DB	MCDBR	13.7	14.1	15.2	15.4	14.7	13.7	12.7	12.6	13.2	13.9	14.9	13.4	(36)
(37)		MCWBR	9.1	8.2	7.2	6.3	5.2	4.4	3.8	3.9	4.6	6.4	8.3	8.9	(37)	
(38)		5% WB	MCDBR	11.2	11.6	12.2	12.3	12.1	11.9	11.2	10.9	10.7	10.3	10.8	10.9	(38)
(39)		MCWBR	8.8	8.4	7.1	6.4	4.9	4.5	4.0	3.9	4.2	5.4	7.4	8.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.325	0.328	0.356	0.388	0.438	0.480	0.522	0.521	0.426	0.379	0.349	0.326	(40)	
(41)		taud	2.508	2.493	2.440	2.339	2.238	2.182	2.070	2.065	2.318	2.425	2.460	2.522	(41)	
(42)		Ebn at Noon	895	929	923	902	855	815	779	773	840	859	857	873	(42)	
(43)		Edh at Noon	86	96	109	126	141	148	165	164	122	102	90	81	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.87	3.46	4.54	5.67	6.25	6.20	6.06	5.48	4.82	4.14	3.17	2.46	(44)	
(45)		RadStd	0.15	0.38	0.36	0.39	0.47	0.46	0.33	0.28	0.45	0.47	0.26	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) +0.48	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) +0.38	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (38 neighbors)	+0.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+178	+123	(47)

Nomenclature: See separate page