

NEWMAN COWETA COUNTY AP, GA, USA

WMO: 722176

Lat: 33.312N

Lon: 84.770W

Elev: 296

StdP: 97.82

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 53884

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.7	-5.9	-13.8	1.2	-1.2	-11.4	1.5	0.2	8.1	6.4	7.2	7.1	0.8	0	0.350

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	33.9	24.3	32.8	24.2	32.0	24.1	26.5	30.6	25.8	30.0	25.4	29.6	1.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.3	21.2	28.3	24.8	20.6	27.9	24.1	19.7	27.3	84.3	30.4	81.5	30.2	79.3	29.6	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.4	4.7	-12.2	35.3	6.0	1.6	-16.5	36.5	-20.0	37.4	-23.4	38.4	-27.7	39.6		
(5)			-11.5	27.3	2.1	0.7	-13.0	27.8	-14.2	28.1	-15.3	28.5	-16.8	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	5.5	8.2	11.8	16.2	20.2	24.1	25.4	25.3	22.7	16.7	11.3	7.8		
	DBStd	8.13	5.46	5.35	5.22	4.09	3.53	2.41	2.10	2.15	3.30	4.68	4.51	5.37		
	HDD10.0	451	159	92	41	4	0	0	0	0	0	7	37	110		
	HDD18.3	1632	396	286	207	88	23	1	0	0	5	84	214	329		
	CDD10.0	2754	22	42	98	189	317	423	477	475	382	214	75	41		
	CDD18.3	894	0	2	5	23	81	174	218	217	137	34	3	1		
	CDH23.3	7899	0	8	57	257	789	1541	1962	1881	1121	267	17	1		
	CDH26.7	3037	0	1	6	41	231	628	832	809	429	58	1	0		
(14) Wind	WSAvg	1.4	1.9	1.9	2.0	1.7	1.2	1.0	1.0	0.9	1.0	1.2	1.5	1.8		
(15) Precipitation	PrecAvg	1263	120	125	140	100	90	99	122	97	92	77	101	114		
	PrecMax	1754	223	228	277	193	249	226	351	188	246	225	291	340		
	PrecMin	864	68	42	28	40	23	28	54	28	10	7	25	30		
	PrecStd	241	36	43	55	41	48	48	75	36	51	55	61	62		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	24.4	27.4	29.1	32.6	34.0	34.5	35.6	35.2	31.0	25.5	22.8		
		MCWB	16.9	17.8	18.0	19.9	21.9	24.2	24.9	24.7	23.1	22.1	18.6	19.2		
	2%	DB	18.9	21.4	24.9	27.8	30.8	32.8	33.3	33.7	32.8	28.0	22.8	21.2		
		MCWB	15.5	16.1	16.9	18.9	21.9	23.8	25.0	24.6	22.9	20.9	17.4	18.3		
	5%	DB	17.2	19.4	22.8	26.4	29.1	32.0	32.4	32.5	31.1	26.2	21.4	18.9		
		MCWB	14.8	15.4	15.9	18.3	21.3	23.7	24.9	24.5	23.1	19.6	16.7	16.6		
	10%	DB	14.9	17.6	21.0	24.5	27.7	30.6	31.2	31.2	29.0	24.2	19.8	17.0		
		MCWB	12.1	13.7	15.1	17.5	20.9	23.7	24.7	24.5	22.9	19.6	15.8	14.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.4	19.2	20.0	22.4	24.2	26.6	27.2	27.3	25.7	24.3	21.7	21.1		
		MCDB	20.3	21.8	24.3	26.3	28.8	30.6	30.9	31.2	29.3	27.9	22.7	21.8		
	2%	WB	17.1	17.8	19.0	21.1	23.5	25.6	26.5	26.5	25.0	23.1	19.9	19.0		
		MCDB	18.0	20.1	22.6	24.9	28.1	30.1	30.7	30.7	29.0	25.5	21.3	20.2		
	5%	WB	15.3	16.7	17.7	20.1	22.8	25.0	25.8	25.8	24.3	21.9	18.2	17.3		
		MCDB	16.9	18.6	20.4	23.8	27.2	29.6	30.0	30.0	28.3	25.0	20.0	18.2		
	10%	WB	12.9	15.1	16.4	19.1	22.0	24.4	25.4	25.4	23.6	20.8	16.9	15.1		
		MCDB	14.2	17.3	19.6	22.6	26.1	28.6	29.5	29.4	27.4	23.1	18.7	16.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	12.6	13.5	13.7	13.0	11.7	11.1	11.0	11.4	12.9	13.3	11.8		
		MCDBR	13.7	13.4	15.1	15.4	13.8	13.4	12.1	12.8	13.1	14.0	14.5	12.1		
	5% WB	MCWBR	10.3	8.7	8.1	7.4	6.1	5.4	4.8	5.0	5.0	7.4	9.2	9.0		
		MCWBR	11.6	10.3	12.4	11.9	11.7	11.4	10.7	10.8	10.6	10.0	11.3	10.4		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.318	0.351	0.384	0.440	0.472	0.514	0.516	0.417	0.365	0.338	0.316		
	taud		2.525	2.510	2.441	2.329	2.217	2.180	2.071	2.054	2.321	2.456	2.472	2.537		
	Ebn at Noon		904	937	926	904	853	821	784	776	846	871	866	881		
	Edh at Noon		83	94	108	127	143	148	165	165	121	98	87	79		
(44) All-Sky Solar Radiation	RadAvg		2.73	3.29	4.39	5.54	6.11	6.14	5.94	5.44	4.74	4.04	3.04	2.32		
	RadStd		0.16	0.41	0.38	0.37	0.51	0.50	0.41	0.32	0.46	0.52	0.30	0.24		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+155	+108

Nomenclature: See separate page