

POTEAU, OK, USA

WMO: 722178

Lat: 35.021N

Lon: 94.621W

Elev: 138

StdP: 99.68

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53953

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.9	-5.6	-15.0	1.0	-3.6	-12.2	1.3	-1.7	10.1	15.1	9.0	12.4	1.8	0	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	37.9	25.4	37.1	25.2	35.1	24.7	27.8	34.1	27.0	33.1	26.3	32.2	2.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	22.1	30.6	25.9	21.6	30.1	24.8	20.2	29.1	89.9	34.4	85.8	33.8	82.2	32.6	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.4	6.1	DB	-13.4	40.1	8.6	1.8	-19.5	41.4	-24.6	42.5	-29.4	43.5	-35.7	44.9	(4)
(5)			WB	-13.1	28.2	8.2	1.2	-19.0	29.0	-23.8	29.7	-28.4	30.3	-34.3	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	5.1	8.0	12.8	16.9	21.3	26.6	28.1	27.9	24.1	17.4	11.3	6.5
	DBStd	9.31	6.21	5.79	5.36	4.71	3.97	2.71	2.74	3.12	3.66	4.95	5.16	5.15
	HDD10.0	491	173	96	32	6	1	0	0	0	0	4	45	134
	HDD18.3	1653	412	291	183	80	19	0	0	0	3	79	218	368
	CDD10.0	3121	21	41	120	211	351	498	560	554	422	233	83	26
	CDD18.3	1241	1	2	13	36	111	248	302	296	175	49	6	1
	CDH23.3	13792	3	19	109	354	1042	2809	3591	3484	1819	508	49	4
	CDH26.7	6581	0	2	12	72	323	1380	1919	1878	843	147	4	0
(14) Wind	WSAvg	1.9	2.3	2.4	2.6	2.6	2.0	1.7	1.3	1.3	1.3	1.7	2.0	1.9
(15) Precipitation	PrecAvg	1190	61	70	102	111	157	101	90	71	114	105	108	93
	PrecMax	1846	236	214	232	313	398	273	272	220	303	418	251	272
	PrecMin	553	7	5	32	27	33	12	0	0	22	0	21	4
	PrecStd	282	46	46	52	62	95	69	60	46	64	86	71	60
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	26.1	27.9	31.2	33.7	37.9	39.0	41.1	37.7	32.4	27.2	23.7
		MCWB	15.8	18.1	18.5	22.5	24.6	25.3	24.5	25.2	24.6	22.1	19.4	19.0
	2%	DB	21.2	22.9	26.3	28.6	32.2	36.3	37.7	38.6	35.2	30.1	25.0	21.3
		MCWB	16.0	16.7	18.0	19.3	23.6	25.8	25.2	26.5	23.2	21.6	18.1	16.3
	5%	DB	18.0	21.1	24.0	27.2	30.1	34.8	37.1	37.1	33.0	27.9	22.5	17.9
		MCWB	13.0	15.5	17.4	19.3	21.9	24.9	25.2	25.4	23.2	20.5	17.4	13.5
	10%	DB	16.0	18.0	22.4	25.5	28.0	32.9	34.8	35.0	32.1	26.3	20.9	16.0
		MCWB	10.8	13.4	16.1	18.5	21.7	24.8	25.1	25.0	22.8	19.9	15.9	11.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.3	20.4	20.8	23.6	26.3	28.2	29.0	28.8	27.5	24.5	21.2	19.8
		MCDB	22.1	24.3	25.6	28.3	31.2	34.8	35.2	35.2	33.2	29.2	24.9	23.3
	2%	WB	17.2	18.1	19.6	22.2	24.8	27.2	27.7	27.8	25.8	23.4	19.6	17.6
		MCDB	19.8	21.7	24.5	26.7	29.6	33.6	33.4	34.4	31.5	27.8	23.4	19.8
	5%	WB	14.0	16.5	18.7	21.0	23.9	26.3	26.8	26.9	25.0	22.3	18.1	14.7
		MCDB	17.6	20.2	23.1	25.2	28.1	32.4	32.6	33.2	30.5	26.5	21.7	17.6
	10%	WB	11.1	14.1	17.2	19.7	22.9	25.5	26.0	26.1	24.0	21.2	16.4	12.2
		MCDB	15.0	17.5	21.1	24.1	27.0	31.2	31.9	32.1	29.1	24.7	19.6	15.0
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	12.0	12.4	12.4	11.2	11.5	11.7	12.0	12.9	13.0	12.8	11.5
		MCDBR	16.8	16.1	14.4	14.2	12.6	13.3	13.8	14.1	14.6	14.4	14.6	15.6
	5% WB	MCWBR	11.1	10.7	8.3	7.0	5.8	4.8	4.2	4.4	5.3	6.8	9.3	10.8
		MCWBR	12.9	13.8	11.9	10.7	10.9	11.4	11.3	12.1	12.1	11.4	12.1	13.1
(40) Clear-Sky Solar Irradiance	taub		0.316	0.321	0.358	0.393	0.427	0.441	0.462	0.461	0.403	0.356	0.330	0.309
		taud	2.487	2.483	2.406	2.311	2.280	2.272	2.253	2.235	2.363	2.476	2.500	2.522
	Ebn at Noon		890	926	913	892	862	846	825	820	855	873	865	877
		Edh at Noon	84	94	111	128	134	135	137	137	115	94	83	77
(44) All-Sky Solar Radiation	RadAvg		2.55	2.99	4.09	5.07	5.57	6.32	6.32	5.80	4.93	3.75	2.71	2.19
	RadStd		0.24	0.42	0.27	0.31	0.52	0.68	0.39	0.39	0.39	0.52	0.33	0.29

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page