

AUGUSTA, GA, USA

WMO: 722180

Lat: 33.364N

Lon: 81.963W

Elev: 132

StdP: 14.63

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03820

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	26.1	7.4	8.1	34.5	11.9	10.1	36.8	22.9	51.6	20.5	50.5	2.2	290	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	97.1	75.9	94.9	75.6	92.8	75.3	79.3	90.5	78.3	89.2	77.5	88.0	8.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.4	138.6	83.4	75.5	134.1	82.6	74.7	130.4	81.7	42.7	90.4	41.7	89.4	40.9	87.9	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	16.5	14.0	16.5	100.5	3.7	3.2	13.8	102.8	11.7	104.7	9.6	106.5	6.9	108.8
			15.0	81.7	3.4	1.3	12.5	82.6	10.5	83.3	8.5	84.1	6.0	85.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.5	46.3	49.9	56.6	63.9	71.8	78.6	81.4	80.6	75.3	65.1	54.6	48.9	(6)
	DBStd	14.30	9.68	8.87	8.34	6.95	5.97	4.13	3.24	3.64	5.14	7.45	7.95	9.05	(7)
	HDD50	507	190	103	35	2	0	0	0	0	0	2	41	134	(8)
	HDD65	2325	581	426	279	103	15	0	0	0	3	92	322	504	(9)
	CDD50	5797	77	101	239	418	675	858	974	950	758	469	179	99	(10)
	CDD65	2142	3	5	19	68	225	408	509	485	311	94	11	4	(11)
	CDH74	21587	17	54	276	912	2452	4124	5316	4712	2691	889	114	30	(12)
	CDH80	9774	0	4	47	258	1022	2013	2712	2301	1163	243	10	1	(13)
(14) Wind	WSAvg	5.2	6.0	6.2	6.6	6.2	5.5	4.8	4.6	4.0	4.5	4.4	4.6	5.1	(14)
(15) Precipitation	PrecAvg	44.3	3.9	4.0	4.4	3.1	3.3	4.4	4.4	4.4	3.3	2.7	2.5	3.5	(15)
	PrecMax	66.0	10.1	9.4	11.9	8.4	9.6	10.8	11.4	12.3	9.5	14.8	7.8	9.0	(16)
	PrecMin	30.3	0.6	0.7	0.9	0.6	0.4	0.7	1.0	0.6	0.2	0.0	0.1	0.9	(17)
	PrecStd	6.9	2.2	1.9	2.3	1.8	2.0	2.3	2.5	2.4	2.2	2.5	1.8	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.5	79.6	84.9	89.0	95.3	98.7	99.5	100.5	95.6	89.5	81.6	77.8	(19)
		MCWB	64.5	64.8	65.3	68.5	72.9	75.4	76.5	76.2	73.4	72.9	67.3	65.6	(20)
	2%	DB	71.6	75.0	80.5	85.9	91.9	95.7	97.0	96.4	92.7	85.7	77.4	73.3	(21)
		MCWB	61.8	61.6	63.8	67.3	71.7	75.0	76.2	76.9	73.7	70.3	64.7	64.0	(22)
	5%	DB	67.4	70.8	77.0	83.2	89.0	93.2	94.6	93.5	90.0	82.6	73.8	69.1	(23)
		MCWB	59.5	58.9	61.5	66.4	70.9	74.8	76.3	76.3	73.4	68.7	61.9	61.7	(24)
	10%	DB	63.4	66.3	73.1	79.8	86.1	90.4	92.2	90.9	87.1	79.2	70.0	64.9	(25)
		MCWB	57.1	56.7	59.8	64.1	69.7	74.3	76.2	75.9	72.6	67.1	61.8	59.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.2	67.8	68.9	72.6	76.4	79.4	80.7	80.7	78.3	77.2	71.3	69.7	(27)
		MCDB	72.2	75.3	78.5	82.0	87.9	90.9	92.2	91.8	88.5	83.7	75.1	73.0	(28)
	2%	WB	64.3	64.8	66.5	70.6	74.7	78.0	79.4	79.3	77.0	74.5	68.4	66.2	(29)
		MCDB	69.4	72.1	75.5	80.3	86.2	89.6	90.9	90.2	86.4	80.9	72.8	70.7	(30)
	5%	WB	61.7	62.1	64.6	68.9	73.2	77.0	78.3	78.3	75.9	72.3	66.4	63.6	(31)
		MCDB	66.3	68.0	73.0	78.5	84.0	88.3	89.5	88.7	84.6	78.2	70.8	67.8	(32)
	10%	WB	58.1	59.0	62.5	67.1	71.8	76.1	77.5	77.4	74.8	70.2	63.6	60.1	(33)
		MCDB	62.4	64.2	69.7	76.1	81.7	86.6	88.3	87.3	82.6	76.1	69.2	64.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	23.4	24.2	25.5	26.3	25.0	22.0	21.2	20.5	21.6	24.6	25.8	23.0	(35)
		MCDBR	27.5	28.8	30.5	30.2	28.2	26.1	24.6	24.1	25.6	27.2	29.6	26.2	(36)
	5% WB	MCWBR	18.1	17.2	15.3	13.5	11.2	8.9	7.7	7.6	9.2	13.1	17.1	17.3	(37)
		MCWBR	22.5	23.7	24.0	23.8	23.2	21.8	21.1	20.8	20.4	19.8	21.0	22.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.326	0.333	0.369	0.405	0.468	0.504	0.548	0.535	0.440	0.401	0.354	0.323	(40)
		taud	2.490	2.466	2.396	2.285	2.156	2.102	1.997	2.025	2.277	2.351	2.441	2.532	(41)
	Ebn at Noon		282	292	288	280	263	252	240	241	262	264	268	277	(42)
		Edh at Noon	28	31	36	42	48	51	56	54	40	35	29	25	(43)
(44) All-Sky Solar Radiation	RadAvg		897	1092	1436	1804	1963	2010	1925	1757	1526	1286	983	777	(44)
	RadStd		48	114	106	124	149	143	134	86	132	150	77	75	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+1.17	N/A	N/A	N/A	N/A	N/A	N/A	-189	+378	+275
(47)	Regional (51 neighbors)	+0.99	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+322	+225

Nomenclature: See separate page