

BURNETT COUNTY AP, WI, USAWMO: **722183**Lat: **45.823N**Lon: **92.373W**Elev: **989**StdP: **14.18**Time Zone: **-6.00 (NAC)**Period: **04-19**WBAN: **04972****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.6	-11.0	-24.1	1.5	-14.8	-18.9	2.0	-9.2	20.8	17.4	18.8	17.0	3.0	310	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	87.7	71.0	84.3	68.7	81.8	67.0	74.0	83.1	72.0	80.6	70.1	78.2	10.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.2	119.6	79.4	69.2	111.3	77.5	67.5	104.7	75.5	38.1	82.6	36.4	80.5	34.6	78.1	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.0	17.0	15.4	-24.1	93.0	4.3	3.3	-27.3	95.4	-29.8	97.4	-32.2	99.2	-35.3	101.6		
(5)			-24.5	77.3	4.3	2.2	-27.6	78.9	-30.0	80.2	-32.4	81.4	-35.5	83.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.1	13.7	16.2	30.2	42.7	55.1	64.2	69.4	66.2	59.5	46.3	33.0	19.1
	DBStd	21.84	13.31	12.51	12.68	9.71	8.97	6.70	6.21	6.49	8.52	8.97	10.95	12.06
	HDD50	4677	1127	946	625	258	46	2	0	1	16	182	517	957
	HDD65	8389	1592	1366	1080	670	330	91	28	61	205	584	960	1422
	CDD50	2162	0	0	10	39	205	428	600	504	302	67	7	0
	CDD65	399	0	0	1	1	23	68	163	98	41	4	0	0
	CDH74	3967	0	0	3	13	318	731	1620	897	353	32	0	0
	CDH80	1006	0	0	0	0	89	163	480	200	72	2	0	0
Wind	WSAvg	6.2	6.3	6.5	6.5	7.3	6.8	5.9	5.5	5.1	6.1	6.5	6.5	6.1
Precipitation	PrecAvg	31.3	0.9	0.8	1.6	2.8	3.7	4.3	4.1	4.0	3.5	3.1	1.7	1.1
	PrecMax	42.0	2.2	1.8	3.1	8.0	6.7	6.0	6.5	9.4	7.5	6.9	5.1	2.0
	PrecMin	22.4	0.2	0.1	0.7	0.6	1.1	1.9	1.1	1.5	0.8	0.9	0.1	0.3
	PrecStd	4.9	0.5	0.5	0.7	1.5	1.5	1.3	1.5	1.8	1.9	1.7	1.4	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.0	50.1	70.4	76.0	88.5	89.5	94.6	88.5	86.9	78.8	65.8	46.2
		MCWB	36.7	43.8	57.6	57.5	67.0	71.3	75.5	72.6	69.7	64.4	51.4	41.9
	2%	DB	37.1	41.7	60.9	70.3	81.6	84.1	88.1	84.7	81.6	72.6	59.0	41.2
		MCWB	33.9	36.3	51.4	52.8	63.7	66.8	72.4	69.6	67.0	59.9	49.9	37.8
	5%	DB	34.5	36.8	53.9	64.7	77.1	81.3	85.1	81.7	78.5	65.9	54.1	37.0
		MCWB	32.7	32.7	45.6	49.6	60.6	65.8	70.0	66.9	65.9	55.4	46.0	34.8
	10%	DB	32.2	33.3	47.1	60.8	72.1	78.7	82.0	79.3	74.3	61.1	49.2	34.5
		MCWB	30.6	30.5	40.6	47.4	57.8	63.7	68.1	66.4	63.9	51.7	43.4	32.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.2	43.4	60.1	59.3	72.4	74.5	78.3	75.3	73.8	67.8	55.7	44.0
		MCDB	41.4	50.6	68.1	70.2	83.8	84.9	89.4	84.6	81.3	73.2	61.7	45.0
	2%	WB	34.9	37.2	52.5	55.4	66.5	71.1	74.6	73.1	70.1	60.5	50.9	37.6
		MCDB	37.2	41.9	58.7	65.6	76.5	80.5	84.0	80.6	77.7	69.2	58.3	40.0
	5%	WB	32.7	33.4	46.2	52.0	63.5	68.5	72.4	70.9	68.1	56.6	46.5	35.1
		MCDB	34.3	36.3	53.5	62.6	71.8	76.7	81.8	78.1	75.7	64.6	52.3	37.0
	10%	WB	30.6	30.8	41.3	48.8	60.5	66.2	70.5	68.7	65.6	53.6	43.5	33.0
		MCDB	32.1	33.0	46.8	59.4	69.6	74.6	79.2	76.3	72.9	59.1	49.6	34.3
Mean Daily Temperature Range	5% DB	MDBR	17.3	19.0	19.5	21.3	23.4	22.2	21.7	21.4	21.1	18.3	15.9	14.9
		MCDBR	15.2	19.3	25.0	30.6	29.9	25.5	23.8	23.8	24.1	25.7	23.0	15.1
		MCWBR	12.7	15.1	15.1	16.7	14.4	12.3	11.1	11.6	12.4	14.5	15.0	12.6
	5% WB	MCDBR	14.6	17.0	22.0	25.3	23.6	21.0	20.6	18.8	20.5	20.6	20.4	13.5
		MCWBR	12.6	13.6	14.6	15.4	12.7	12.0	10.9	10.5	11.8	13.4	14.4	11.6
Clear-Sky Solar Irradiance	taub		0.252	0.268	0.313	0.359	0.392	0.383	0.377	0.389	0.363	0.315	0.286	0.263
	taud		2.401	2.358	2.354	2.345	2.294	2.352	2.392	2.371	2.420	2.545	2.518	2.427
	Ebn at Noon		277	292	291	285	278	280	280	272	271	272	262	259
	Edh at Noon		22	28	33	37	40	38	36	36	31	24	20	20
All-Sky Solar Radiation	RadAvg		522	871	1224	1469	1691	1862	1969	1643	1263	785	491	364
	RadStd		57	79	109	141	134	135	71	121	87	103	46	43