

LEE GILMER, GA, USA

WMO: 722185

Lat: 34.272N

Lon: 83.830W

Elev: 1275

StdP: 14.03

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 53838

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	26.2	3.5	6.9	30.5	7.4	8.4	31.1	22.4	38.9	20.3	38.4	9.8	310	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	92.3	73.3	90.5	73.1	88.5	72.7	76.6	86.2	75.5	84.9	74.8	83.8	7.3	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.9	132.4	79.5	73.0	128.6	78.9	72.3	125.5	78.4	40.7	86.3	39.8	85.4	39.0	83.9	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	16.9	15.1	DB	16.0	95.3	4.3	3.3	12.8	97.6	10.3	99.6	7.9	101.4	4.8	103.8
			WB	13.5	79.8	3.9	3.8	10.7	82.6	8.4	84.8	6.2	87.0	3.4	89.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.6	42.2	46.1	53.0	61.6	69.3	76.3	78.8	78.3	72.9	62.6	52.2	45.4	(6)	
(7)		DBStd	14.72	9.34	8.50	8.75	7.18	5.99	4.24	3.49	3.80	5.35	7.21	7.55	8.38	(7)	
(8)		HDD50	780	277	162	72	7	0	0	0	0	0	5	63	194	(8)	
(9)		HDD65	2927	708	530	381	146	32	1	0	0	7	129	385	608	(9)	
(10)		CDD50	5028	34	53	164	354	597	790	893	878	688	395	130	52	(10)	
(11)		CDD65	1701	0	1	8	43	164	341	428	413	245	54	3	1	(11)	
(12)		CDH74	13762	0	2	61	347	1184	2872	3767	3510	1701	308	10	0	(12)	
(13)		CDH80	4905	0	0	4	46	291	1085	1494	1387	547	51	0	0	(13)	
(14)	Wind	WSAvg	6.7	7.9	7.9	8.0	7.4	6.3	5.9	5.7	5.4	5.7	6.1	6.6	7.3	(14)	
(15)	Precipitation	PrecAvg	56.2	5.7	5.0	6.1	4.5	4.3	4.4	4.6	4.1	4.4	3.7	4.3	4.7	(15)	
(16)		PrecMax	74.6	10.9	11.9	15.5	14.0	10.1	13.5	9.5	16.4	16.8	10.7	9.0	13.8	(16)	
(17)		PrecMin	38.4	1.2	0.7	1.3	0.8	0.8	0.5	0.6	1.0	0.1	0.0	1.6	0.7	(17)	
(18)		PrecStd	8.2	2.2	2.4	3.1	2.8	2.0	2.9	2.4	2.9	3.1	2.7	1.9	2.7	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.4	72.2	79.7	84.1	89.0	93.5	94.5	96.2	91.6	84.8	75.3	71.7	(19)	
(20)			MCWB	57.7	60.1	61.3	64.2	69.6	72.3	73.5	73.4	70.8	70.0	60.9	61.9	(20)	
(21)		2%	DB	63.7	66.7	75.0	81.2	85.9	91.0	91.7	92.1	88.8	80.6	71.9	66.4	(21)	
(22)			MCWB	57.2	56.3	59.7	64.1	68.6	72.8	74.1	73.6	70.6	66.7	58.7	60.4	(22)	
(23)		5%	DB	60.7	63.4	71.6	78.5	83.4	89.0	90.1	89.9	86.0	77.3	68.0	62.6	(23)	
(24)			MCWB	54.8	54.9	57.7	62.2	68.0	72.1	74.1	73.6	70.7	64.1	57.6	56.8	(24)	
(25)		10%	DB	56.6	59.9	67.5	74.9	80.9	86.4	87.9	87.6	82.9	74.1	64.3	58.5	(25)	
(26)			MCWB	51.5	51.8	55.8	60.9	67.4	71.4	73.6	73.2	69.7	63.7	56.3	53.0	(26)	
(27)		Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.4	64.0	64.3	69.3	74.7	76.5	78.7	77.9	75.4	73.6	67.2	65.8	(27)
(28)				MCD B	64.8	67.9	72.3	77.1	81.4	87.4	87.5	88.0	83.4	79.1	70.5	68.2	(28)
(29)	2%		WB	59.3	60.9	62.5	67.2	72.2	75.3	76.8	76.4	74.2	71.0	63.5	61.5	(29)	
(30)			MCD B	63.0	65.4	70.8	75.7	80.2	85.8	86.3	86.0	81.9	76.2	66.4	64.5	(30)	
(31)	5%		WB	56.1	57.3	60.5	65.2	70.6	74.3	75.6	75.4	73.0	68.6	61.0	58.3	(31)	
(32)			MCD B	59.1	60.9	68.3	73.9	78.8	84.1	84.9	84.6	80.5	73.6	64.9	61.7	(32)	
(33)	10%		WB	52.8	53.8	58.3	63.4	69.2	73.2	74.9	74.6	71.7	66.3	58.5	54.3	(33)	
(34)			MCD B	55.6	57.8	65.1	71.2	77.4	82.3	83.8	83.2	78.9	71.5	63.2	57.2	(34)	
(35)	Mean Daily Temperature Range		5% DB	MDBR	16.4	17.3	19.0	19.7	18.5	17.5	16.7	16.4	16.6	18.2	18.0	15.5	(35)
(36)				MCD BR	18.6	20.2	22.9	23.2	20.9	20.4	19.4	19.5	20.1	20.8	21.4	18.2	(36)
(37)		MCWBR		12.9	12.8	11.1	9.8	7.6	6.7	6.1	6.3	6.6	8.9	11.5	12.2	(37)	
(38)		5% WB	MCD BR	15.3	16.9	19.0	19.2	17.5	17.4	16.9	16.6	16.1	15.5	15.8	15.5	(38)	
(39)			MCWBR	12.8	13.3	11.4	10.4	8.3	7.0	6.3	6.0	6.3	8.6	11.7	12.6	(39)	
(40)																	(40)
(41)	Clear-Sky Solar Irradiance	taub	0.306	0.312	0.346	0.383	0.440	0.467	0.507	0.505	0.409	0.368	0.334	0.306	(41)		
(42)		taud	2.531	2.511	2.442	2.325	2.199	2.164	2.073	2.063	2.316	2.421	2.468	2.552	(42)		
(43)		Ebn at Noon	288	298	295	286	270	261	250	248	270	274	274	282	(43)		
(44)		Edh at Noon	26	29	34	40	46	48	52	52	38	32	27	24	(44)		
(45)	All-Sky Solar Radiation	RadAvg	843	1024	1366	1717	1900	1977	1872	1737	1499	1256	936	714	(45)		
(46)		RadStd	53	129	100	112	148	152	134	97	147	148	100	74	(46)		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+297	+198

Nomenclature: See separate page