

LEE GILMER, GA, USA

WMO: 722185

Lat: 34.272N

Lon: 83.830W

Elev: 389

StdP: 96.74

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 53838

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.9	(c) -3.2	(d) -15.8	(e) 1.0	(f) -0.8	(g) -13.7	(h) 1.2	(i) -0.5	(j) 10.0	(k) 3.8	(l) 9.1	(m) 3.5	(n) 4.4	(o) 310	(p) 0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	33.5	22.9	32.5	22.9	31.4	22.6	24.8	30.1	24.2	29.4	23.8	28.8	3.3	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.3	18.9	26.4	22.8	18.4	26.0	22.4	17.9	25.8	76.8	30.1	74.7	29.7	72.9	28.8	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.4	7.5	6.7	-8.9	35.1	2.4	1.8	-10.6	36.5	-12.0	37.5	-13.4	38.6	-15.1	39.9
			-10.3	26.6	2.2	2.1	-11.8	28.1	-13.1	29.4	-14.3	30.6	-15.9	32.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	5.6	7.8	11.6	16.4	20.7	24.6	26.0	25.7	22.7	17.0	11.2	7.4
	DBStd	8.18	5.19	4.72	4.86	3.99	3.33	2.36	1.94	2.11	2.97	4.00	4.20	4.66
	HDD10.0	433	154	90	40	4	0	0	0	0	0	3	35	108
	HDD18.3	1626	393	294	212	81	18	1	0	0	4	72	214	338
	CDD10.0	2793	19	29	91	197	332	439	496	488	382	219	72	29
	CDD18.3	945	0	1	4	24	91	189	238	229	136	30	2	1
	CDH23.3	7646	0	1	34	193	658	1596	2093	1950	945	171	6	0
	CDH26.7	2725	0	0	2	26	162	603	830	771	304	28	0	0
Wind	WSAvg	3.0	3.5	3.5	3.6	3.3	2.8	2.6	2.6	2.4	2.6	2.7	2.9	3.3
Precipitation	PrecAvg	1428	145	128	156	114	109	113	117	105	113	95	110	120
	PrecMax	1896	277	301	393	356	256	342	242	417	427	273	229	350
	PrecMin	975	30	18	33	21	20	13	16	26	3	0	40	18
	PrecStd	209	56	60	78	71	50	74	60	73	79	69	48	68
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.2	22.3	26.5	29.0	31.7	34.1	34.7	35.7	33.1	29.3	24.0	22.0
		MCWB	14.3	15.6	16.3	17.9	20.9	22.4	23.1	23.0	21.5	21.1	16.1	16.6
	2%	DB	17.6	19.3	23.9	27.3	29.9	32.8	33.2	33.4	31.6	27.0	22.2	19.1
		MCWB	14.0	13.5	15.4	17.8	20.4	22.7	23.4	23.1	21.5	19.3	14.9	15.8
	5%	DB	15.9	17.5	22.0	25.8	28.6	31.7	32.3	32.2	30.0	25.2	20.0	17.0
		MCWB	12.7	12.7	14.3	16.8	20.0	22.3	23.4	23.1	21.5	17.9	14.2	13.8
	10%	DB	13.7	15.5	19.7	23.8	27.2	30.2	31.1	30.9	28.3	23.4	17.9	14.7
		MCWB	10.8	11.0	13.2	16.1	19.7	21.9	23.1	22.9	20.9	17.6	13.5	11.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.9	17.8	18.0	20.7	23.7	24.7	26.0	25.5	24.1	23.1	19.6	18.8
		MCDB	18.2	19.9	22.4	25.1	27.4	30.8	30.8	31.1	28.6	26.2	21.4	20.1
	2%	WB	15.2	16.0	16.9	19.6	22.3	24.1	24.9	24.7	23.4	21.7	17.5	16.4
		MCDB	17.2	18.5	21.5	24.3	26.8	29.9	30.2	30.0	27.7	24.6	19.1	18.0
	5%	WB	13.4	14.0	15.8	18.5	21.4	23.5	24.2	24.1	22.8	20.3	16.1	14.6
		MCDB	15.0	16.1	20.2	23.3	26.0	28.9	29.4	29.2	26.9	23.1	18.3	16.5
	10%	WB	11.5	12.1	14.6	17.5	20.6	22.9	23.8	23.7	22.1	19.1	14.7	12.4
		MCDB	13.1	14.4	18.4	21.8	25.2	28.0	28.8	28.5	26.0	22.0	17.3	14.0
Mean Daily Temperature Range	5% DB	MDBR	9.1	9.6	10.6	10.9	10.3	9.7	9.3	9.1	9.2	10.1	10.0	8.6
		MCDBR	10.4	11.2	12.7	12.9	11.6	11.3	10.8	10.8	11.1	11.5	11.9	10.1
		MCWBR	7.2	7.1	6.2	5.5	4.2	3.7	3.4	3.5	3.6	5.0	6.4	6.8
	5% WB	MCDBR	8.5	9.4	10.5	10.6	9.7	9.7	9.4	9.2	8.9	8.6	8.8	8.6
		MCWBR	7.1	7.4	6.3	5.8	4.6	3.9	3.5	3.4	3.5	4.8	6.5	7.0
Clear-Sky Solar Irradiance	taub	0.306	0.312	0.346	0.383	0.440	0.467	0.507	0.505	0.409	0.368	0.334	0.306	
	taud	2.531	2.511	2.442	2.325	2.199	2.164	2.073	2.063	2.316	2.421	2.468	2.552	
	Ebn at Noon	909	940	929	903	851	824	789	783	851	863	864	888	
	Edh at Noon	82	92	108	127	146	151	164	163	121	100	86	76	
All-Sky Solar Radiation	RadAvg	2.66	3.23	4.31	5.41	5.99	6.23	5.90	5.47	4.73	3.96	2.95	2.25	
	RadStd	0.17	0.41	0.32	0.35	0.47	0.48	0.42	0.30	0.46	0.47	0.32	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+165	+110

Nomenclature: See separate page