

ATLANTA HARTSFIELD-JACKSON, GA, USA

WMO: 722190

Lat: 33.630N

Lon: 84.442W

Elev: 308

StdP: 97.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13874

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.7	-3.1	-15.2	1.0	-2.0	-12.8	1.3	-0.2	11.3	3.1	10.6	3.2	5.3	320	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	34.3	23.2	33.1	23.1	32.0	22.9	25.1	31.2	24.6	30.2	24.1	29.3	3.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.4	18.9	27.2	22.9	18.4	26.9	22.5	17.9	26.5	77.8	31.2	75.7	30.3	73.8	29.6	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.4	8.4	7.5	-9.5	35.8	2.6	2.0	-11.4	37.2	-13.0	38.3	-14.4	39.5	-16.3	40.9
			-10.8	25.9	2.5	0.6	-12.6	26.3	-14.0	26.7	-15.4	27.0	-17.2	27.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	6.8	9.0	12.9	17.3	21.7	25.3	26.8	26.5	23.6	17.9	12.1	8.4
	DBStd	8.15	5.59	5.18	4.98	4.01	3.43	2.43	1.86	2.07	3.03	4.10	4.51	5.03
	HDD10.0	360	132	74	29	3	0	0	0	0	0	2	29	92
	HDD18.3	1432	358	261	177	66	12	1	0	0	3	57	190	308
	CDD10.0	3063	32	47	119	221	362	460	519	512	408	247	93	42
	CDD18.3	1094	0	1	8	33	116	211	261	254	161	44	4	1
	CDH23.3	9507	0	4	55	253	912	1897	2507	2375	1230	259	16	1
	CDH26.7	3564	0	0	5	38	262	759	1057	984	413	47	1	0
Wind	WSAvg	3.6	4.1	4.1	4.2	3.8	3.4	3.1	3.0	2.9	3.3	3.4	3.6	3.8
Precipitation	PrecAvg	1275	119	117	133	101	99	100	125	101	93	76	99	112
	PrecMax	1781	258	324	296	301	252	254	450	220	347	221	255	318
	PrecMin	808	21	20	26	12	10	4	14	13	1	0	22	18
	PrecStd	222	49	57	62	52	53	58	82	54	66	53	51	65
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	23.7	27.1	29.5	32.7	34.8	35.9	36.3	34.4	30.2	25.5	22.4
		MCWB	16.2	17.2	17.0	19.4	21.6	22.8	23.6	23.5	21.7	21.0	17.7	17.0
	2%	DB	19.4	20.9	24.8	27.8	30.8	33.3	34.0	34.2	32.2	27.8	23.0	20.6
		MCWB	14.7	15.3	16.0	18.4	21.1	22.8	23.6	23.6	21.7	19.8	16.5	16.7
	5%	DB	17.5	19.1	23.0	26.3	29.4	32.2	32.8	32.7	30.6	26.1	21.3	18.5
		MCWB	14.4	14.4	15.2	17.6	20.5	22.6	23.5	23.4	21.6	18.6	15.9	15.3
	10%	DB	15.5	17.3	21.1	24.6	28.1	30.9	31.6	31.3	29.1	24.5	19.5	16.5
		MCWB	12.5	13.1	14.3	16.7	20.1	22.3	23.5	23.0	21.2	18.2	14.7	13.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.9	18.9	19.1	21.6	23.6	25.2	25.8	25.7	24.1	23.1	20.8	19.3
		MCDB	19.7	21.0	23.0	26.3	28.5	31.4	31.6	32.2	29.2	26.5	22.4	20.9
	2%	WB	16.6	17.4	17.8	20.2	22.5	24.5	25.2	25.1	23.5	21.7	19.0	17.7
		MCDB	18.4	19.9	22.0	24.7	28.1	30.5	31.2	31.2	28.3	25.7	21.1	19.4
	5%	WB	15.0	15.8	16.8	19.2	21.8	23.9	24.6	24.5	22.9	20.7	17.5	16.0
		MCDB	17.0	18.2	21.1	23.7	27.2	29.7	30.3	30.0	27.4	23.8	19.8	18.0
	10%	WB	13.1	14.1	15.6	18.3	21.2	23.3	24.1	24.0	22.4	19.7	16.0	14.0
		MCDB	15.0	16.2	19.5	22.7	26.2	28.6	29.4	29.0	26.7	22.8	18.7	16.1
Mean Daily Temperature Range	5% DB	MDBR	9.7	10.0	10.6	10.9	10.1	9.5	9.2	9.0	9.1	10.0	10.3	9.1
		MCDBR	10.7	11.2	12.3	12.0	11.0	11.0	10.7	10.7	10.7	11.2	11.3	10.4
		MCWBR	7.4	7.2	6.0	5.1	4.1	3.7	3.3	3.3	3.7	4.7	6.3	7.0
	5% WB	MCDBR	9.0	9.6	9.9	9.8	9.4	9.5	9.5	9.3	8.6	8.4	9.1	9.1
		MCWBR	7.2	7.3	6.1	5.2	4.1	3.8	3.5	3.3	3.7	4.9	7.0	7.4
Clear-Sky Solar Irradiance	taub	0.311	0.315	0.348	0.386	0.441	0.473	0.515	0.516	0.418	0.363	0.334	0.312	
	taud	2.537	2.520	2.452	2.324	2.212	2.168	2.065	2.051	2.312	2.460	2.483	2.553	
	Ebn at Noon	908	940	929	901	851	820	783	776	845	872	869	886	
	Edh at Noon	82	92	107	127	144	150	166	165	122	97	86	77	
All-Sky Solar Radiation	RadAvg	2.70	3.27	4.36	5.50	6.07	6.16	5.92	5.44	4.72	4.00	3.00	2.29	
	RadStd	0.16	0.40	0.37	0.36	0.51	0.51	0.42	0.31	0.47	0.51	0.31	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only		+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+136	+108
Regional (40 neighbors)		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+147	+103

Nomenclature: See separate page