

FULTON COUNTY AP, GA, USA

WMO: 722195

Lat: 33.779N

Lon: 84.521W

Elev: 840

StdP: 14.26

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03888

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	25.5	4.6	7.2	29.1	8.8	8.9	32.5	20.1	41.8	18.5	40.1	6.1	320	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	93.8	73.8	91.8	73.6	90.2	73.3	77.4	87.5	76.4	86.2	75.5	84.9	6.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.7	134.1	80.8	73.5	128.4	80.0	72.8	125.4	79.5	41.2	87.6	40.3	86.1	39.5	85.3	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.5	15.4	12.9	DB	15.4	96.1	4.6	3.4	12.0	98.6	9.3	100.6	6.7	102.5	3.4	105.0
			WB	13.1	79.1	4.4	1.4	9.9	80.1	7.4	81.0	4.9	81.8	1.7	82.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.4	43.4	47.1	54.3	62.0	70.0	77.0	79.7	79.1	73.5	63.0	52.5	46.3
	DBStd	14.66	9.66	8.86	8.57	6.90	5.89	4.17	3.27	3.59	5.32	7.41	7.87	8.73
	HDD50	706	251	147	56	5	0	0	0	0	0	4	62	181
	HDD65	2767	669	501	342	134	26	1	0	0	7	125	380	582
	CDD50	5236	47	67	189	366	619	809	920	903	705	409	137	65
	CDD65	1821	0	1	10	45	180	360	455	438	262	64	5	1
	CDH74	16846	1	8	120	533	1664	3351	4389	4102	2145	492	38	3
	CDH80	6648	0	0	11	93	515	1416	1929	1796	794	92	2	0
Wind	WSAvg	4.9	5.8	5.9	6.1	5.7	4.8	4.3	4.1	3.8	4.0	4.2	4.6	5.1
Precipitation	PrecAvg	52.6	4.7	4.8	5.2	3.8	4.1	4.2	5.2	4.3	3.9	3.3	4.3	4.2
	PrecMax	71.4	7.7	8.3	9.5	7.7	11.1	10.1	13.8	7.7	11.7	9.5	10.5	10.2
	PrecMin	31.3	2.4	1.9	1.9	0.9	1.7	1.7	1.7	1.2	0.4	0.2	1.0	1.3
	PrecStd	9.5	1.4	1.5	2.1	1.6	2.0	2.1	2.8	1.9	2.8	2.3	2.2	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.0	75.0	81.5	85.8	90.6	94.9	96.0	97.7	93.6	86.1	79.2	73.0
		MCWB	60.5	62.8	62.0	65.8	70.5	73.4	74.4	74.3	71.0	70.4	64.5	62.8
	2%	DB	67.1	70.0	77.4	82.4	88.0	92.5	93.2	93.8	90.5	82.2	73.6	69.3
		MCWB	58.4	59.2	61.1	64.8	69.9	73.1	74.4	74.4	71.2	67.3	61.4	62.2
	5%	DB	63.5	66.2	73.5	80.5	85.4	90.4	91.2	91.1	87.9	79.4	70.9	65.1
		MCWB	56.7	56.8	58.5	63.6	68.5	72.7	74.6	74.0	71.5	64.8	60.3	59.2
	10%	DB	59.6	63.1	70.2	77.0	82.7	88.0	89.6	89.0	84.6	76.1	66.9	61.4
		MCWB	53.9	54.2	57.5	62.0	68.1	72.1	74.3	73.7	70.6	64.6	58.4	55.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.1	65.3	66.1	70.4	74.4	77.7	78.8	78.5	76.1	74.4	69.4	67.0
		MCDB	67.5	70.9	73.7	79.7	82.7	87.3	88.6	88.8	84.8	80.2	73.2	70.3
	2%	WB	61.2	62.9	64.1	68.2	72.7	76.3	77.5	77.3	74.8	71.3	65.7	63.7
		MCDB	65.5	67.1	72.2	77.2	82.0	86.7	87.8	87.2	82.9	77.3	69.5	66.8
	5%	WB	58.3	59.5	62.2	66.5	71.3	75.1	76.5	76.3	73.7	69.3	63.1	60.7
		MCDB	62.7	64.1	70.3	75.2	81.0	85.6	86.4	85.9	81.5	75.0	68.1	64.7
	10%	WB	54.6	56.2	59.9	64.7	70.0	74.1	75.5	75.3	72.7	67.2	60.3	56.7
		MCDB	58.2	60.8	67.4	72.9	79.1	83.5	84.9	84.5	80.3	73.7	65.8	60.3
Mean Daily Temperature Range	5% DB	MDBR	19.5	20.3	21.9	22.9	21.3	19.1	18.1	18.2	19.5	21.4	21.8	18.8
		MCDBR	23.6	24.9	27.1	27.4	24.4	22.7	20.8	21.7	23.5	24.8	26.0	22.0
		MCWBR	15.8	15.3	13.4	11.5	9.0	7.3	6.5	6.6	7.9	11.4	14.7	15.2
	5% WB	MCDBR	19.1	19.7	21.4	20.9	19.7	18.5	18.0	17.7	17.9	17.2	19.0	18.6
		MCWBR	14.8	14.6	12.6	10.6	8.5	7.2	6.8	6.4	7.3	10.0	13.7	15.1
Clear-Sky Solar Irradiance	taub	0.313	0.317	0.351	0.392	0.449	0.480	0.524	0.524	0.423	0.367	0.337	0.314	
	taud	2.531	2.514	2.443	2.313	2.191	2.148	2.041	2.028	2.300	2.451	2.475	2.546	
	Ebn at Noon	287	297	293	284	268	258	246	244	266	275	274	279	
	Edh at Noon	26	30	34	41	47	49	54	54	39	31	28	24	
All-Sky Solar Radiation	RadAvg	847	1025	1373	1736	1918	1955	1874	1729	1497	1264	943	718	
	RadStd	52	128	116	114	159	159	136	100	148	160	99	75	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	+0.65	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+248	+220	
Regional (39 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+265	+185	

Nomenclature: See separate page