

FULTON COUNTY AP, GA, USA

WMO: 722195

Lat: 33.779N

Lon: 84.521W

Elev: 256

StdP: 98.29

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03888

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.1	-3.6	-15.2	1.0	-1.6	-12.9	1.3	0.3	9.0	5.5	8.3	4.5	2.7	320	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	34.3	23.2	33.2	23.1	32.3	23.0	25.2	30.8	24.7	30.1	24.1	29.4	3.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.7	19.2	27.1	23.0	18.3	26.7	22.7	17.9	26.4	78.0	30.9	75.8	30.1	73.9	29.6	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.9	5.8	DB	-9.2	35.6	2.6	1.9	-11.1	37.0	-12.6	38.1	-14.0	39.2	-15.9	40.6	(4)
(5)			WB	-10.5	26.2	2.4	0.8	-12.3	26.7	-13.7	27.2	-15.0	27.6	-16.8	28.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	6.4	8.4	12.4	16.7	21.1	25.0	26.5	26.2	23.1	17.2	11.4	7.9	(6)	
(7)		DBStd	8.14	5.37	4.92	4.76	3.84	3.27	2.31	1.82	1.99	2.96	4.11	4.37	4.85	(7)	
(8)		HDD10.0	392	139	82	31	3	0	0	0	0	2	34	101		(8)	
(9)		HDD18.3	1537	372	278	190	74	14	1	0	4	69	211	323		(9)	
(10)		CDD10.0	2909	26	37	105	203	344	449	511	502	392	227	76	36		(10)
(11)		CDD18.3	1012	0	1	6	25	100	200	253	243	146	36	3	1		(11)
(12)		CDH23.3	9359	1	4	67	296	924	1862	2438	2279	1192	273	21	2		(12)
(13)	CDH26.7	3693	0	0	6	52	286	787	1072	998	441	51	1	0		(13)	
(14)	Wind	WSAvg	2.2	2.6	2.6	2.7	2.5	2.1	1.9	1.8	1.7	1.8	1.9	2.0	2.3	(14)	
(15)	Precipitation	PrecAvg	1335	120	121	132	97	103	107	131	108	100	85	109	107	(15)	
(16)		PrecMax	1814	196	210	241	196	283	257	350	195	296	242	266	258	(16)	
(17)		PrecMin	796	62	48	47	24	43	42	42	31	11	6	25	32	(17)	
(18)		PrecStd	241	35	39	53	40	52	53	71	47	70	58	55	51	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	23.9	27.5	29.9	32.6	35.0	35.6	34.2	30.0	26.2	22.8		(19)	
(20)			MCWB	15.8	17.1	16.7	18.8	21.4	23.0	23.5	23.5	21.7	21.3	18.1	17.1		(20)
(21)		2%	DB	19.5	21.1	25.2	28.0	31.1	33.6	34.0	34.3	32.5	27.9	23.1	20.7		(21)
(22)			MCWB	14.7	15.1	16.1	18.2	21.0	22.9	23.6	23.6	21.8	19.6	16.4	16.8		(22)
(23)		5%	DB	17.5	19.0	23.0	26.9	29.6	32.4	32.9	32.8	31.0	26.3	21.6	18.4		(23)
(24)			MCWB	13.7	13.8	14.7	17.5	20.3	22.6	23.7	23.3	21.9	18.2	15.7	15.1		(24)
(25)	10%	DB	15.3	17.3	21.2	25.0	28.2	31.1	32.0	31.7	29.2	24.5	19.4	16.3		(25)	
(26)		MCWB	12.2	12.3	14.2	16.7	20.1	22.3	23.5	23.2	21.5	18.1	14.6	13.0		(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.8	18.5	18.9	21.3	23.6	25.4	26.0	25.8	24.5	23.5	20.8	19.5		(27)
(28)			MCD B	19.7	21.6	23.2	26.5	28.2	30.7	31.5	31.6	29.3	26.8	22.9	21.3		(28)
(29)		2%	WB	16.2	17.2	17.8	20.1	22.6	24.6	25.3	25.2	23.8	21.8	18.7	17.6		(29)
(30)			MCD B	18.6	19.5	22.3	25.1	27.8	30.4	31.0	30.7	28.3	25.2	20.8	19.3		(30)
(31)		5%	WB	14.6	15.3	16.8	19.2	21.9	24.0	24.7	24.6	23.2	20.7	17.3	15.9		(31)
(32)			MCD B	17.0	17.8	21.3	24.0	27.2	29.8	30.2	30.0	27.5	23.9	20.1	18.2		(32)
(33)	10%	WB	12.6	13.4	15.5	18.2	21.1	23.4	24.2	24.1	22.6	19.6	15.7	13.7		(33)	
(34)		MCD B	14.6	16.0	19.7	22.7	26.2	28.6	29.4	29.2	26.8	23.2	18.8	15.7		(34)	
(35)	Mean Daily Temperature Range	MDBR	10.8	11.3	12.2	12.7	11.8	10.6	10.1	10.1	10.8	11.9	12.1	10.4		(35)	
(36)		5% DB	MCD BR	13.1	13.9	15.1	15.2	13.6	12.6	11.5	12.0	13.1	13.8	14.4	12.2		(36)
(37)			MCWBR	8.8	8.5	7.4	6.4	5.0	4.1	3.6	3.7	4.4	6.4	8.2	8.5		(37)
(38)		5% WB	MCD BR	10.6	10.9	11.9	11.6	11.0	10.3	10.0	9.9	9.9	9.6	10.6	10.3		(38)
(39)			MCWBR	8.2	8.1	7.0	5.9	4.7	4.0	3.8	3.6	4.1	5.5	7.6	8.4		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.313	0.317	0.351	0.392	0.449	0.480	0.524	0.524	0.423	0.367	0.337	0.314		(40)	
(41)		taud	2.531	2.514	2.443	2.313	2.191	2.148	2.041	2.028	2.300	2.451	2.475	2.546		(41)	
(42)		Ebn at Noon	904	937	924	896	844	814	776	768	840	867	864	881		(42)	
(43)		Edh at Noon	82	93	108	129	147	153	170	169	123	98	87	77		(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.67	3.23	4.33	5.47	6.05	6.16	5.91	5.45	4.72	3.98	2.97	2.26		(44)	
(45)		RadStd	0.16	0.40	0.37	0.36	0.50	0.50	0.43	0.32	0.47	0.50	0.31	0.24		(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+138	+122
(47) Regional (39 neighbors)		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+147	+103

Nomenclature: See separate page