

CALHOUN COUNTY AP, TX, USA

WMO: 722209

Lat: 28.654N

Lon: 96.681W

Elev: 30

StdP: 14.68

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 12986

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.7	36.1	19.5	14.6	44.9	24.1	18.3	46.6	26.7	60.7	24.9	60.0	9.1	0	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.7	96.2	77.0	94.5	77.5	92.7	77.7	81.5	89.3	80.9	88.4	80.2	87.6	10.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.6	153.6	84.4	79.1	151.1	84.2	78.4	147.4	83.9	45.2	89.6	44.3	88.4	43.6	87.7	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.0	20.7	18.8	DB	27.8	99.5	5.3	2.3	24.0	101.2	20.9	102.5	17.9	103.7	14.1	105.4	(4)
(5)			WB	25.3	81.9	4.7	1.6	21.9	83.0	19.2	84.0	16.6	84.8	13.2	86.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	71.2	54.9	59.3	65.0	70.9	77.2	82.3	83.9	84.8	81.2	73.9	63.8	57.2
	DBStd	12.40	9.03	9.22	7.88	5.98	4.87	2.72	2.50	2.77	3.92	7.19	8.70	9.36
	HDD50	133	53	26	6	1	0	0	0	0	0	0	10	37
	HDD65	1068	330	200	100	20	2	0	0	0	0	17	125	274
	CDD50	7889	206	286	470	627	842	968	1050	1079	935	741	423	262
	CDD65	3346	17	39	99	196	379	518	585	614	485	293	88	33
	CDH74	33492	60	126	362	1143	3353	5765	6859	7444	5063	2670	514	133
	CDH80	13603	1	10	32	196	1035	2493	3155	3619	2119	874	65	4
Wind	WSAvg	8.7	9.3	10.0	10.5	10.7	9.8	7.6	7.0	6.9	7.2	8.3	8.7	9.0
Precipitation	PrecAvg	42.6	3.1	2.2	3.1	2.5	4.2	4.1	4.1	2.8	5.4	4.6	3.5	2.6
	PrecMax	63.7	10.1	7.1	12.2	6.8	12.8	12.3	17.1	6.2	13.1	12.2	8.9	7.8
	PrecMin	23.0	0.1	0.4	0.2	0.1	0.0	0.0	0.2	0.4	1.5	0.7	0.1	0.6
	PrecStd	11.9	2.4	1.8	2.7	1.9	3.0	3.0	4.1	1.9	3.1	3.1	2.6	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.9	81.1	83.2	89.5	91.1	96.8	97.3	98.6	97.3	92.1	84.4	80.5
		MCWB	67.2	69.2	69.6	66.5	76.0	77.0	76.8	76.2	76.2	77.5	72.5	69.6
	2%	DB	75.2	77.5	80.5	84.2	89.9	93.2	95.1	96.6	93.4	89.9	81.9	77.5
		MCWB	66.9	68.1	70.1	70.7	75.9	77.4	77.3	77.1	77.2	76.9	71.7	68.9
	5%	DB	72.8	75.0	78.3	81.9	87.9	91.2	93.1	94.9	91.3	87.7	80.0	74.9
		MCWB	65.3	67.8	68.9	71.5	75.4	77.4	77.9	77.8	76.9	75.6	71.0	68.9
	10%	DB	70.0	72.5	75.5	80.2	85.7	90.1	91.3	93.0	89.9	85.1	77.2	72.3
		MCWB	64.2	67.3	68.4	70.8	75.2	77.4	77.9	78.2	76.7	74.1	69.6	67.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.6	73.1	74.2	77.4	80.4	82.4	82.2	82.4	82.2	80.4	77.9	73.9
		MCDB	74.9	77.6	79.7	81.7	86.4	89.1	90.2	90.9	89.8	87.4	82.3	77.5
	2%	WB	69.8	71.3	72.8	75.8	79.2	81.2	81.1	81.4	81.1	79.3	75.2	72.5
		MCDB	73.0	74.7	77.4	80.8	84.5	87.8	89.2	89.9	88.0	86.0	78.7	75.6
	5%	WB	68.0	70.0	71.6	74.4	78.1	79.9	80.3	80.6	80.2	78.2	73.2	70.6
		MCDB	71.5	73.1	75.4	79.2	83.8	86.8	88.1	88.8	87.0	84.4	77.6	73.4
	10%	WB	65.7	68.4	70.4	73.3	77.1	78.8	79.6	79.8	79.1	77.0	71.3	68.6
		MCDB	68.7	71.3	73.9	77.7	83.0	85.9	87.1	87.9	85.8	82.9	75.3	71.5
Mean Daily Temperature Range	5% DB	MDBR	19.4	17.7	16.9	16.2	15.2	15.6	16.7	16.4	19.0	19.0	18.5	
		MCDBR	22.0	18.6	16.3	17.0	16.9	16.8	17.6	18.6	18.1	16.9	18.9	20.2
		MCWBR	14.6	11.6	8.7	8.7	6.3	5.1	5.1	5.2	6.0	7.4	11.0	13.7
	5% WB	MCDBR	18.1	15.6	14.2	13.2	12.8	14.4	15.4	15.8	14.8	15.4	15.9	17.0
		MCWBR	14.0	11.5	8.6	7.6	5.9	5.7	5.5	5.5	5.8	8.2	11.2	13.7
Clear-Sky Solar Irradiance	taub		0.352	0.368	0.384	0.441	0.483	0.459	0.483	0.457	0.445	0.391	0.380	0.343
	taud		2.481	2.441	2.391	2.240	2.153	2.285	2.229	2.308	2.304	2.447	2.422	2.523
	Ebn at Noon		281	286	287	273	260	265	258	265	265	274	268	279
	Edh at Noon		30	33	37	45	49	43	45	41	40	33	31	27
All-Sky Solar Radiation	RadAvg		933	1083	1438	1709	1928	2107	2074	1973	1649	1426	1073	846
	RadStd		101	178	132	154	129	126	188	110	148	150	119	104

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+187	+167

Nomenclature: See separate page