

DESTIN-FORT WALTON BEACH, FL, USA

WMO: 722210

Lat: 30.483N

Lon: 86.517W

Elev: 87

StdP: 14.65

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13858

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.0	31.9	12.0	10.2	37.2	17.0	13.0	40.1	23.9	58.8	21.0	55.4	7.6	0	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	93.0	76.7	91.1	76.9	90.0	76.9	80.8	87.9	79.9	87.1	79.1	86.2	9.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	151.0	84.4	77.8	145.2	83.7	77.1	141.6	83.2	44.3	88.1	43.3	86.9	42.5	86.3	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.3	18.2	16.5	DB	21.9	97.1	3.8	2.6	19.2	99.0	17.0	100.5	14.9	102.0	12.1	103.9	(4)
			WB	19.5	82.7	3.7	1.3	16.8	83.6	14.7	84.4	12.6	85.2	9.9	86.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	68.1	51.1	55.4	60.5	66.8	74.6	80.3	82.0	81.8	78.8	70.3	60.4	54.4	(6)
		DBStd	12.77	9.57	8.56	7.67	5.74	4.69	2.94	2.61	2.58	3.87	6.85	8.08	9.12	(7)
		HDD50	230	105	41	13	0	0	0	0	0	0	12	59		(8)
		HDD65	1503	436	281	176	49	3	0	0	0	32	182	344		(9)
		CDD50	6833	140	192	339	504	764	908	991	985	864	628	323	195	(10)
		CDD65	2630	6	11	37	103	302	458	526	520	415	195	43	14	(11)
		CDH74	24881	2	15	92	459	2584	4792	5781	5575	3904	1463	200	14	(12)
		CDH80	8921	0	0	4	30	682	1797	2362	2265	1434	334	13	0	(13)
(14)	Wind	WSAvg	7.6	8.3	8.3	8.8	8.7	8.1	6.3	6.2	7.0	7.4	7.6	7.8		(14)
(15)	Precipitation	PrecAvg	60.1	4.4	4.7	5.5	5.0	3.4	5.4	7.2	6.3	5.7	3.5	4.1	4.8	(15)
(16)		PrecMax	77.6	17.2	8.5	11.2	15.1	10.9	12.1	16.7	10.4	27.1	10.4	12.4	10.0	(16)
(17)		PrecMin	39.6	0.6	1.5	0.5	1.0	0.5	1.3	2.8	2.5	1.5	0.2	0.4	1.8	(17)
(18)		PrecStd	10.7	3.0	2.1	3.0	3.1	2.6	2.8	3.5	2.1	4.9	3.0	3.0	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	73.2	76.2	79.9	82.8	91.3	94.4	95.9	95.1	94.1	89.1	81.7	75.5		(19)
(20)		0.4% MCWB	67.2	66.8	66.3	68.1	71.4	76.6	78.3	77.1	74.6	74.1	71.1	69.4		(20)
(21)		2% DB	71.0	72.8	76.7	80.8	87.8	91.4	92.7	92.4	90.9	86.2	78.9	73.2		(21)
(22)		2% MCWB	66.8	65.5	66.4	68.8	72.9	76.8	77.6	77.6	75.2	73.4	69.6	68.7		(22)
(23)		5% DB	68.4	70.2	73.9	78.8	85.8	89.7	90.6	90.7	89.2	83.8	76.4	71.1		(23)
(24)		5% MCWB	65.0	64.8	65.3	68.1	73.3	76.8	77.5	77.8	75.3	72.1	68.7	67.6		(24)
(25)		10% DB	66.0	68.0	72.0	76.9	83.8	87.9	89.3	89.4	87.5	81.4	73.4	68.5		(25)
(26)		10% MCWB	63.0	63.9	64.9	67.6	73.0	76.4	77.4	77.6	75.3	70.8	66.3	65.6		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	70.1	70.4	71.8	75.1	78.5	81.8	81.9	82.5	80.1	78.5	75.8	72.6		(27)
(28)		0.4% MCDB	71.6	72.7	75.1	78.6	83.3	87.9	89.5	89.6	86.6	83.1	78.5	74.0		(28)
(29)		2% WB	68.2	68.6	70.2	73.4	77.3	80.1	80.4	81.0	78.6	77.1	73.6	70.4		(29)
(30)		2% MCDB	69.8	70.5	73.1	76.9	83.0	86.7	87.9	88.3	85.8	81.8	76.7	71.9		(30)
(31)		5% WB	66.1	67.0	68.9	72.3	76.2	79.0	79.5	80.0	77.9	75.5	71.1	68.5		(31)
(32)		5% MCDB	67.6	68.9	71.6	75.8	82.1	85.8	87.2	87.2	85.0	81.0	74.3	70.2		(32)
(33)		10% WB	63.5	65.1	67.1	70.8	75.1	78.1	78.7	79.0	77.1	73.9	68.7	66.2		(33)
(34)		10% MCDB	65.2	67.2	70.2	74.4	81.1	84.9	86.2	86.1	84.0	79.1	72.4	68.0		(34)
(35)	Mean Daily Temperature Range	MDBR	19.1	18.5	18.5	17.9	17.1	14.8	14.6	14.7	16.2	19.1	20.5	18.4		(35)
(36)		5% DB MCDBR	16.8	17.2	18.1	17.5	18.3	16.8	16.6	16.7	17.9	18.9	19.0	16.5		(36)
(37)		5% DB MCWBR	13.3	12.0	10.9	9.4	8.1	6.9	6.7	6.9	7.1	9.0	11.6	13.2		(37)
(38)		5% WB MCDBR	14.6	14.7	13.9	12.6	14.3	14.5	14.8	14.6	14.5	14.7	15.2	14.8		(38)
(39)		5% WB MCWBR	13.5	12.2	10.2	8.9	7.3	7.1	6.7	6.8	6.8	8.7	11.6	13.8		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.347	0.368	0.396	0.435	0.465	0.504	0.496	0.437	0.384	0.355	0.340		(40)
(41)		taud	2.541	2.504	2.439	2.370	2.293	2.262	2.171	2.190	2.330	2.456	2.476	2.528		(41)
(42)		Ebn at Noon	286	291	291	285	272	263	252	253	266	274	274	277		(42)
(43)		Edh at Noon	27	31	35	39	43	43	48	46	39	32	29	27		(43)
(44)	All-Sky Solar Radiation	RadAvg	991	1182	1603	1927	2135	2007	1893	1755	1640	1453	1121	871		(44)
(45)		RadStd	71	153	125	152	123	165	117	133	99	138	98	87		(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (38 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+270	+164	(47)

Nomenclature: See separate page