

DESTIN-FORT WALTON BEACH, FL, USA

WMO: 722210

Lat: 30.483N

Lon: 86.517W

Elev: 27

StdP: 101.01

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13858

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.2	(c) -0.1	(d) -11.1	(e) 1.5	(f) 2.9	(g) -8.3	(h) 1.9	(i) 4.5	(j) 10.7	(k) 14.9	(l) 9.4	(m) 13.0	(n) 3.4	(o) 0	(p) 0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.1	(c) 33.9	(d) 24.8	(e) 32.9	(f) 25.0	(g) 32.2	(h) 24.9	(i) 27.1	(j) 31.1	(k) 26.6	(l) 30.6	(m) 26.2	(n) 30.1	(o) 4.4	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.6	29.1	25.5	20.7	28.7	25.1	20.2	28.5	85.1	31.2	82.7	30.5	81.1	30.2	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.1	7.4	-5.6	36.2	2.1	1.5	-7.1	37.2	-8.3	38.1	-9.5	38.9	-11.0	39.9
			-7.0	28.1	2.0	0.7	-8.4	28.7	-9.6	29.1	-10.8	29.5	-12.3	30.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	10.6	13.0	15.8	19.3	23.7	26.8	27.8	27.6	26.0	21.3	15.8	12.4
	DBStd	7.10	5.32	4.76	4.26	3.19	2.61	1.63	1.45	1.43	2.15	3.81	4.49	5.07
	HDD10.0	128	58	23	7	0	0	0	0	0	0	0	7	33
	HDD18.3	835	242	156	98	27	2	0	0	0	0	18	101	191
	CDD10.0	3796	78	107	188	280	424	504	551	547	480	349	179	108
	CDD18.3	1461	3	6	21	57	168	254	292	289	231	108	24	8
	CDH23.3	13823	1	8	51	255	1436	2662	3212	3097	2169	813	111	8
CDH26.7	4956	0	0	2	17	379	998	1312	1258	797	186	7	0	
Wind	WSAvg	3.4	3.7	3.7	3.9	3.9	3.6	3.2	2.8	2.8	3.1	3.3	3.4	3.5
Precipitation	PrecAvg	1526	111	119	139	127	86	138	183	160	146	89	105	122
	PrecMax	1970	438	217	285	384	278	308	425	265	689	265	314	253
	PrecMin	1005	14	38	12	26	12	34	71	64	39	5	10	46
	PrecStd	273	77	53	76	80	67	70	88	53	124	75	77	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.9	24.6	26.6	28.2	32.9	34.7	35.5	35.1	34.5	31.7	27.6	24.2
		MCWB	19.5	19.3	19.1	20.0	21.9	24.8	25.7	25.1	23.7	23.4	21.7	20.8
	2%	DB	21.7	22.7	24.8	27.1	31.0	33.0	33.7	33.6	32.7	30.1	26.0	22.9
		MCWB	19.3	18.6	19.1	20.4	22.7	24.9	25.3	25.3	24.0	23.0	20.9	20.4
	5%	DB	20.2	21.2	23.3	26.0	29.9	32.1	32.6	32.6	31.8	28.8	24.7	21.7
		MCWB	18.3	18.2	18.5	20.1	22.9	24.9	25.3	25.4	24.1	22.3	20.4	19.8
	10%	DB	18.9	20.0	22.2	24.9	28.8	31.1	31.8	31.9	30.8	27.4	23.0	20.3
		MCWB	17.2	17.7	18.3	19.8	22.8	24.7	25.2	25.4	24.0	21.5	19.0	18.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	21.3	22.1	23.9	25.8	27.6	27.7	28.1	26.7	25.8	24.4	22.6
		MCDB	22.0	22.6	23.9	25.9	28.5	31.0	32.0	32.0	30.4	28.4	25.9	23.3
	2%	WB	20.1	20.4	21.2	23.0	25.1	26.7	26.9	27.2	25.9	25.1	23.1	21.3
		MCDB	21.0	21.4	22.8	24.9	28.4	30.4	31.1	31.3	29.9	27.6	24.8	22.2
	5%	WB	18.9	19.4	20.5	22.4	24.6	26.1	26.4	26.6	25.5	24.1	21.7	20.3
		MCDB	19.8	20.5	22.0	24.3	27.9	29.9	30.7	30.7	29.4	27.2	23.5	21.2
	10%	WB	17.5	18.4	19.5	21.6	24.0	25.6	25.9	26.1	25.1	23.3	20.4	19.0
		MCDB	18.5	19.6	21.2	23.6	27.3	29.4	30.1	30.0	28.9	26.2	22.4	20.0
Mean Daily Temperature Range	5% DB	MDBR	10.6	10.3	10.3	9.9	9.5	8.2	8.1	8.2	9.0	10.6	11.4	10.2
		MCDBR	9.3	9.5	10.1	9.7	10.2	9.3	9.2	9.3	9.9	10.5	10.5	9.2
		MCWBR	7.4	6.7	6.1	5.2	4.5	3.8	3.7	3.8	4.0	5.0	6.5	7.3
	5% WB	MCDBR	8.1	8.1	7.7	7.0	7.9	8.0	8.2	8.1	8.1	8.2	8.5	8.2
		MCWBR	7.5	6.8	5.6	4.9	4.1	3.9	3.7	3.8	3.8	4.8	6.4	7.6
Clear-Sky Solar Irradiance	taub	0.332	0.347	0.368	0.396	0.435	0.465	0.504	0.496	0.437	0.384	0.355	0.340	
	taud	2.541	2.504	2.439	2.370	2.293	2.262	2.171	2.190	2.330	2.456	2.476	2.528	
	Ebn at Noon	901	918	916	897	859	829	795	799	837	865	865	872	
	Edh at Noon	86	97	111	123	134	137	150	146	122	101	91	84	
All-Sky Solar Radiation	RadAvg	3.12	3.73	5.05	6.08	6.73	6.33	5.97	5.53	5.17	4.58	3.54	2.75	
	RadStd	0.23	0.48	0.39	0.48	0.39	0.52	0.37	0.42	0.31	0.43	0.31	0.28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (38 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+150	+91

Nomenclature: See separate page