

LEESBURG, FL, USA

WMO: 722213

Lat: 28.821N

Lon: 81.810W

Elev: 77

StdP: 14.66

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 12819

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.9	40.8	19.3	14.6	45.0	25.1	19.2	49.0	20.5	59.9	18.6	57.5	6.7	0	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.0	93.8	76.5	92.6	76.3	91.2	76.0	80.1	87.5	79.3	86.8	78.5	85.9	6.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.5	148.2	82.9	77.4	142.9	82.1	76.7	139.6	81.8	43.4	87.0	42.7	86.8	42.0	86.2	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.6	15.7	13.2	31.0	97.1	3.3	1.6	28.6	98.3	26.6	99.2	24.7	100.1	22.3	101.3		
			26.7	81.2	3.7	1.3	24.0	82.2	21.9	82.9	19.8	83.6	17.1	84.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.8	59.2	62.8	66.9	72.2	77.9	81.7	83.0	83.2	81.3	75.2	67.0	62.7
	DBStd	10.21	8.62	8.00	6.73	5.24	3.98	2.90	2.25	2.17	2.63	5.73	6.81	8.23
	HDD50	41	24	7	1	0	0	0	0	0	0	0	1	8
	HDD65	624	218	124	62	11	0	0	0	0	0	7	58	144
	CDD50	8362	307	364	526	665	865	952	1022	1030	938	781	510	402
	CDD65	3472	36	62	121	225	401	502	557	565	488	324	118	73
	CDH74	30538	170	350	778	1662	3522	4730	5602	5782	4469	2485	648	340
	CDH80	11065	10	48	133	456	1408	1926	2216	2301	1673	764	98	32
Wind	WSAvg	6.3	6.4	6.5	7.0	7.1	6.7	6.0	5.2	5.4	6.1	6.5	6.2	6.1
Precipitation	PrecAvg	49.1	2.8	2.4	3.6	2.4	3.1	7.6	6.5	7.4	6.3	3.2	1.6	2.3
	PrecMax	61.5	6.7	5.8	8.7	7.5	14.3	14.6	10.1	14.0	15.3	7.0	4.5	8.5
	PrecMin	29.6	0.4	0.5	0.0	0.4	0.4	1.0	3.3	4.4	2.1	0.6	0.4	0.4
	PrecStd	8.0	1.8	1.5	2.6	1.6	3.0	3.3	1.9	2.3	3.5	1.9	1.1	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.4	84.2	85.9	90.0	93.5	96.6	95.4	95.2	93.5	90.9	85.8	82.9
		MCWB	68.8	69.5	69.2	71.5	72.7	76.5	77.2	77.3	76.6	75.9	73.1	71.4
	2%	DB	78.7	81.4	83.4	86.8	91.4	93.3	93.3	93.3	91.5	88.8	82.4	80.8
		MCWB	67.2	68.2	68.1	69.8	72.2	76.1	77.3	77.4	75.9	75.0	70.7	69.7
	5%	DB	75.3	78.8	81.4	84.6	89.9	91.3	91.6	91.6	90.2	86.7	80.7	78.4
		MCWB	65.5	66.6	67.2	68.8	71.8	75.7	77.0	77.4	75.7	73.7	69.3	68.5
	10%	DB	72.4	75.2	79.0	82.5	87.7	89.7	90.1	90.2	88.5	84.3	78.2	74.8
		MCWB	64.4	65.0	65.7	67.9	71.4	75.6	77.1	77.5	75.5	72.3	67.7	67.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	72.1	73.4	75.1	77.1	80.3	81.1	81.2	80.3	79.3	75.5	73.2
		MCDB	77.4	78.8	78.8	83.1	86.1	88.5	88.7	88.3	86.6	84.5	81.7	79.3
	2%	WB	69.3	70.5	71.4	73.3	75.9	79.0	79.9	80.2	78.9	77.8	73.7	71.6
		MCDB	74.7	77.0	78.2	81.0	84.5	87.8	87.6	87.5	85.4	84.0	79.2	77.2
	5%	WB	67.8	69.1	70.0	72.0	75.0	78.1	79.0	79.3	78.1	76.5	72.0	70.3
		MCDB	73.4	75.5	76.7	80.0	83.3	86.4	86.7	86.7	84.8	82.8	77.1	75.5
	10%	WB	66.0	67.4	68.5	70.7	73.9	77.3	78.3	78.5	77.3	75.4	70.3	68.9
		MCDB	70.9	73.3	75.3	78.6	82.0	85.2	85.8	85.8	84.1	81.4	75.5	73.7
Mean Daily Temperature Range	5% DB	MDBR	19.7	19.5	20.1	19.7	18.9	15.9	15.1	15.0	15.2	17.4	18.9	18.7
		MCDBR	20.2	20.5	20.6	20.3	20.7	18.3	16.8	16.5	16.8	17.0	18.6	18.5
		MCWBR	10.5	9.2	8.0	6.7	5.9	5.5	5.2	5.3	4.9	5.8	8.4	8.9
	5% WB	MCDBR	17.2	17.9	17.1	17.6	17.2	15.9	15.1	15.0	14.6	14.3	15.5	15.9
		MCWBR	10.4	9.7	8.8	7.8	6.1	5.9	5.7	5.6	5.1	5.5	8.6	9.1
Clear-Sky Solar Irradiance	taub		0.338	0.350	0.368	0.389	0.426	0.456	0.481	0.467	0.419	0.393	0.355	0.343
	taud		2.518	2.492	2.436	2.353	2.301	2.288	2.218	2.272	2.393	2.433	2.492	2.528
	Ebn at Noon		286	292	292	287	276	266	259	262	272	273	278	279
	Edh at Noon		29	32	36	40	42	43	45	43	37	33	29	27
All-Sky Solar Radiation	RadAvg		1075	1275	1628	1945	2037	1820	1781	1702	1538	1405	1153	982
	RadStd		78	95	133	111	132	154	113	115	100	101	62	82

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.08	N/A	N/A	N/A	N/A	N/A	N/A	-126	+405	+288
(47)	Regional (44 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	-11	-88	+277	+198

Nomenclature: See separate page