

LEESBURG, FL, USA

WMO: 722213

Lat: 28.821N

Lon: 81.810W

Elev: 24

StdP: 101.04

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 12819

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.7	4.9	-7.1	2.1	7.2	-3.8	2.7	9.5	9.2	15.5	8.3	14.1	3.0	0	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.4	34.4	24.7	33.7	24.6	32.9	24.4	26.7	30.8	26.3	30.4	25.8	29.9	2.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.8	21.2	28.3	25.2	20.4	27.8	24.8	19.9	27.7	83.2	30.6	81.4	30.4	79.9	30.1	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.9	7.0	5.9	-0.6	36.2	1.9	0.9	-1.9	36.8	-3.0	37.3	-4.0	37.8	-5.4	38.5
			-2.9	27.3	2.1	0.7	-4.4	27.9	-5.6	28.3	-6.8	28.7	-8.3	29.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	15.1	17.1	19.4	22.3	25.5	27.6	28.3	28.5	27.4	24.0	19.4	17.1
	DBStd	5.67	4.79	4.44	3.74	2.91	2.21	1.61	1.25	1.20	1.46	3.19	3.79	4.57
	HDD10.0	23	13	4	1	0	0	0	0	0	0	0	1	4
	HDD18.3	347	121	69	34	6	0	0	0	0	0	4	32	80
	CDD10.0	4646	171	202	292	369	481	529	568	572	521	434	283	223
	CDD18.3	1929	20	34	67	125	223	279	309	314	271	180	66	41
	CDH23.3	16966	94	194	432	923	1957	2628	3112	3212	2483	1381	360	189
	CDH26.7	6147	6	27	74	253	782	1070	1231	1278	929	424	54	18
Wind	WSAvg	2.8	2.9	2.9	3.2	3.2	3.0	2.7	2.3	2.4	2.7	2.9	2.8	2.7
Precipitation	PrecAvg	1248	70	60	92	61	78	192	165	189	159	82	41	58
	PrecMax	1563	170	148	222	191	364	370	256	355	389	179	114	215
	PrecMin	753	10	13	0	10	11	26	83	113	54	16	9	10
	PrecStd	203	46	39	67	41	76	83	49	59	90	49	29	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.4	29.0	30.0	32.2	34.1	35.9	35.2	35.1	34.2	32.7	29.9	28.3
		MCWB	20.5	20.8	20.7	21.9	22.6	24.7	25.1	25.2	24.8	24.4	22.8	21.9
	2%	DB	26.0	27.4	28.5	30.5	33.0	34.1	34.1	34.0	33.0	31.5	28.0	27.1
		MCWB	19.6	20.1	20.0	21.0	22.3	24.5	25.2	25.2	24.4	23.9	21.5	20.9
	5%	DB	24.1	26.0	27.5	29.2	32.2	33.0	33.1	33.1	32.4	30.4	27.1	25.8
		MCWB	18.6	19.2	19.6	20.5	22.1	24.3	25.0	25.2	24.3	23.2	20.7	20.3
	10%	DB	22.4	24.0	26.1	28.0	31.0	32.1	32.3	32.3	31.4	29.1	25.7	23.8
		MCWB	18.0	18.3	18.7	20.0	21.9	24.2	25.1	25.3	24.2	22.4	19.8	19.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	22.3	23.0	23.9	25.1	26.8	27.3	27.4	26.8	26.3	24.2	22.9
		MCDB	25.2	26.0	26.0	28.4	30.1	31.4	31.5	31.3	30.3	29.2	27.6	26.3
	2%	WB	20.7	21.4	21.9	22.9	24.4	26.1	26.6	26.8	26.1	25.4	23.2	22.0
		MCDB	23.7	25.0	25.7	27.2	29.2	31.0	30.9	30.8	29.7	28.9	26.2	25.1
	5%	WB	19.9	20.6	21.1	22.2	23.9	25.6	26.1	26.3	25.6	24.7	22.2	21.3
		MCDB	23.0	24.2	24.8	26.7	28.5	30.2	30.4	30.4	29.3	28.2	25.0	24.2
	10%	WB	18.9	19.7	20.3	21.5	23.3	25.2	25.7	25.8	25.2	24.1	21.3	20.5
		MCDB	21.6	22.9	24.0	25.9	27.8	29.5	29.9	29.9	28.9	27.5	24.2	23.2
Mean Daily Temperature Range	5% DB	MDBR	11.0	10.9	11.2	10.9	10.5	8.9	8.4	8.4	8.4	9.7	10.5	10.4
		MCDBR	11.2	11.4	11.5	11.3	11.5	10.2	9.3	9.2	9.3	9.4	10.4	10.3
		MCWBR	5.8	5.1	4.5	3.7	3.3	3.1	2.9	2.9	2.7	3.2	4.7	4.9
	5% WB	MCDBR	9.6	9.9	9.5	9.8	9.5	8.8	8.4	8.3	8.1	7.9	8.6	8.9
		MCWBR	5.8	5.4	4.9	4.3	3.4	3.3	3.2	3.1	2.8	3.1	4.8	5.1
Clear-Sky Solar Irradiance	taub	0.338	0.350	0.368	0.389	0.426	0.456	0.481	0.467	0.419	0.393	0.355	0.343	
	taud	2.518	2.492	2.436	2.353	2.301	2.288	2.218	2.272	2.393	2.433	2.492	2.528	
	Ebn at Noon	903	920	921	906	869	837	815	826	858	861	875	880	
	Edh at Noon	90	100	112	126	133	134	143	135	116	105	92	86	
All-Sky Solar Radiation	RadAvg	3.39	4.02	5.13	6.13	6.42	5.74	5.61	5.37	4.85	4.43	3.64	3.10	
	RadStd	0.25	0.30	0.42	0.42	0.35	0.42	0.48	0.36	0.36	0.31	0.32	0.20	0.26

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.60	N/A	N/A	N/A	N/A	N/A	N/A	-70	+225	+160
(47)	Regional (44 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	-6	-49	+154	+110

Nomenclature: See separate page