

CRESTVIEW, FL, USA

WMO: 722215

Lat: 30.780N

Lon: 86.523W

Elev: 58

StdP: 100.63

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 13884

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.4	-11.0	1.5	1.8	-8.4	1.9	3.8	9.0	14.7	8.1	13.4	0.8	340	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	35.5	24.5	34.4	24.4	33.4	24.3	26.7	31.7	26.1	31.2	25.7	30.6	2.8	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.4	20.8	28.6	24.9	20.0	28.2	24.3	19.4	27.7	83.5	31.7	81.2	31.1	79.1	30.9	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.6	6.6	5.6	-7.4	37.2	2.0	1.4	-8.8	38.2	-10.0	39.0	-11.1	39.8	-12.6	40.8		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-8.1	27.6	2.0	0.6	-9.6	28.1	-10.8	28.4	-11.9	28.7	-13.4	29.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	10.1	12.0	15.2	18.9	23.0	26.6	27.4	27.2	25.2	20.0	14.3	11.4
	DBStd	7.38	5.67	4.95	4.57	3.61	2.86	1.82	1.46	1.56	2.53	4.23	4.67	5.30
	HDD10.0	174	71	32	10	1	0	0	0	0	0	1	13	47
	HDD18.3	995	261	183	118	37	4	0	0	0	1	33	137	222
	CDD10.0	3575	74	89	170	266	403	499	538	534	457	311	143	91
	CDD18.3	1355	5	6	19	53	149	249	280	276	208	85	17	8
	CDH23.3	13112	9	31	182	553	1623	2548	2749	2628	1837	795	127	29
	CDH26.7	5627	0	1	24	121	669	1237	1294	1217	805	246	13	0
Wind	WSAvg	2.1	2.4	2.5	2.6	2.5	2.1	1.8	1.7	1.5	1.8	1.9	1.9	2.2
Precipitation	PrecAvg	1486	97	118	137	134	85	133	183	151	130	82	100	129
	PrecMax	1976	384	217	350	382	309	296	435	243	660	265	278	272
	PrecMin	958	0	37	9	32	0	33	63	28	29	0	6	53
	PrecStd	311	75	51	91	72	76	69	93	57	121	78	79	58
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.4	26.3	29.1	31.0	35.2	37.2	36.4	36.4	35.6	32.5	28.3	25.8
		MCWB	19.1	18.7	18.9	21.2	22.3	24.3	25.5	25.0	23.9	22.5	20.8	20.4
	2%	DB	22.9	24.1	27.1	29.4	33.1	35.3	35.0	34.8	33.8	31.0	26.3	24.0
		MCWB	18.8	17.8	18.5	19.9	22.1	24.0	25.1	25.1	23.8	22.1	20.1	20.0
	5%	DB	21.6	22.4	25.4	28.1	31.8	34.0	33.8	33.7	32.5	29.3	24.8	22.4
		MCWB	18.3	17.7	17.9	19.2	21.7	23.9	25.0	25.0	23.6	21.6	19.2	19.5
	10%	DB	20.0	20.9	23.7	26.7	30.4	32.6	32.7	32.5	31.3	27.8	23.2	20.9
		MCWB	17.2	17.0	17.1	18.8	21.4	23.8	24.9	24.9	23.5	20.6	18.6	18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	21.2	22.0	23.5	24.8	26.7	27.4	27.4	26.1	25.2	23.7	22.7
		MCDB	22.7	23.3	24.8	26.9	29.4	32.1	32.5	32.3	30.5	28.7	25.5	24.3
	2%	WB	20.3	20.3	21.0	22.6	24.1	25.8	26.7	26.8	25.6	24.4	22.5	21.2
		MCDB	21.9	22.4	23.5	25.9	28.6	31.3	32.0	31.5	30.2	27.6	24.3	22.7
	5%	WB	19.1	19.2	20.1	21.8	23.6	25.4	26.1	26.2	25.1	23.5	20.9	20.2
		MCDB	20.9	21.4	22.9	25.2	28.2	30.8	31.4	30.9	29.8	27.0	23.4	21.8
	10%	WB	17.6	17.9	18.9	20.9	23.0	24.9	25.6	25.7	24.6	22.6	19.5	18.7
		MCDB	19.2	19.9	22.3	24.4	27.8	30.1	30.6	30.4	29.0	26.0	22.6	20.5
Mean Daily Temperature Range	5% DB	MDBR	13.3	13.7	14.5	14.5	14.3	12.2	11.1	10.8	11.7	13.9	14.7	12.8
		MCDBR	12.8	13.8	15.3	15.5	16.1	14.3	12.8	12.5	13.5	14.3	14.6	12.3
		MCWBR	8.9	8.5	7.9	7.1	6.4	4.8	4.6	4.5	5.1	6.7	8.7	8.7
	5% WB	MCDBR	10.0	10.6	11.0	11.2	12.3	11.8	11.1	10.6	10.6	10.6	11.1	10.2
		MCWBR	8.1	8.1	6.9	6.1	5.3	4.5	4.6	4.4	4.6	5.6	7.8	8.5
Clear-Sky Solar Irradiance	taub	0.327	0.341	0.364	0.392	0.434	0.466	0.511	0.499	0.436	0.379	0.351	0.335	
	taud	2.541	2.504	2.435	2.364	2.279	2.243	2.134	2.163	2.316	2.453	2.473	2.527	
	Ebn at Noon	906	922	920	901	860	828	789	795	837	869	867	876	
	Edh at Noon	86	97	111	124	135	140	155	149	124	101	91	83	
All-Sky Solar Radiation	RadAvg	3.06	3.65	4.95	5.99	6.61	6.26	5.95	5.52	5.12	4.51	3.47	2.68	
	RadStd	0.22	0.47	0.40	0.48	0.40	0.52	0.36	0.40	0.33	0.46	0.30	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+218	+121
Regional (42 neighbors)		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+154	+97

Nomenclature: See separate page