

DUBLIN, GA, USA

WMO: 722217

Lat: 32.564N

Lon: 82.985W

Elev: 309

StdP: 14.53

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 63881

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.3	27.9	7.4	8.1	33.2	12.3	10.4	38.8	21.0	56.3	18.5	52.4	1.8	320	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	97.4	75.8	95.0	75.4	92.7	75.4	81.5	88.6	79.9	87.3	78.6	86.7	6.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.4	154.5	84.2	78.7	150.7	83.7	76.7	140.6	82.1	45.4	89.5	43.6	87.7	42.2	86.5	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.4	13.5	11.7	19.3	100.3	3.3	3.7	16.9	102.9	14.9	105.1	13.0	107.2	10.6	109.9
			17.7	81.5	3.3	2.2	15.4	83.1	13.4	84.4	11.6	85.6	9.2	87.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.2	47.4	51.4	56.7	64.2	72.6	79.6	81.6	80.6	76.1	65.8	54.9	51.1	(6)
	DBStd	13.98	9.39	8.83	8.28	6.81	5.79	4.04	3.18	4.33	4.64	7.65	7.57	8.60	(7)
	HDD50	416	167	83	33	3	0	0	0	1	0	1	34	94	(8)
	HDD65	2158	549	385	278	95	12	0	0	3	1	86	314	435	(9)
	CDD50	5981	85	123	240	430	702	889	979	949	784	491	180	129	(10)
	CDD65	2247	2	5	19	72	249	439	514	486	335	111	10	5	(11)
	CDH74	22579	13	51	243	885	2568	4605	5327	4713	2989	1043	113	29	(12)
	CDH80	10197	0	2	33	217	1073	2310	2670	2255	1329	296	12	0	(13)
(14) Wind	WSAvg	4.1	4.7	4.9	5.2	4.8	4.2	3.6	3.4	3.2	3.4	3.7	3.8	4.0	(14)
(15) Precipitation	PrecAvg	47.5	4.1	4.2	4.9	2.7	2.4	5.2	4.6	5.0	4.1	3.5	2.8	3.8	(15)
	PrecMax	62.0	9.3	8.2	9.4	6.6	6.1	9.1	8.8	9.5	12.9	10.7	7.3	8.9	(16)
	PrecMin	35.9	1.1	1.3	0.2	0.6	0.2	1.1	1.7	2.3	0.1	0.3	0.5	1.6	(17)
	PrecStd	7.8	1.8	1.8	2.9	1.6	1.3	2.4	2.0	3.3	2.8	1.7	1.8	1.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.4	79.5	82.5	88.3	96.5	99.8	99.5	99.4	97.1	90.0	81.7	77.4	(19)
		MCWB	65.3	65.6	66.1	68.9	71.7	76.3	77.3	77.5	72.4	72.5	66.4	66.0	(20)
	2%	DB	71.9	74.8	80.8	85.5	91.2	97.1	97.1	96.6	92.9	86.2	77.3	72.9	(21)
		MCWB	63.2	62.4	64.9	67.3	71.5	75.8	76.5	76.9	72.9	70.0	63.3	64.4	(22)
	5%	DB	66.5	71.8	76.8	82.0	89.8	93.3	94.5	92.9	90.4	82.4	73.0	69.9	(23)
		MCWB	61.1	60.6	62.4	66.1	70.7	75.2	76.2	77.0	73.1	68.4	61.5	64.3	(24)
	10%	DB	63.5	67.8	72.6	80.5	86.3	90.8	91.2	90.6	88.1	80.8	70.2	65.7	(25)
		MCWB	58.8	59.1	60.2	64.9	69.9	74.5	76.3	76.6	73.1	67.3	61.3	61.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.4	67.4	69.5	72.9	76.4	81.9	83.2	83.9	78.9	77.1	71.0	70.1	(27)
		MCDB	70.6	75.1	76.9	81.2	85.6	92.3	91.5	92.6	85.6	82.1	74.7	73.1	(28)
	2%	WB	65.2	65.6	67.2	70.8	74.7	79.6	81.5	81.6	77.4	74.7	68.7	67.5	(29)
		MCDB	69.0	72.8	75.6	79.5	84.4	90.4	88.5	87.8	85.5	80.1	72.6	70.2	(30)
	5%	WB	63.1	63.3	65.5	69.3	73.4	78.1	79.9	80.0	76.2	72.9	65.9	64.7	(31)
		MCDB	65.5	67.5	74.0	77.1	82.7	88.7	87.6	86.0	84.0	78.3	71.8	67.7	(32)
	10%	WB	60.0	60.9	63.3	67.3	72.2	76.8	78.4	78.7	75.1	71.4	63.2	62.8	(33)
		MCDB	63.9	65.7	68.7	75.9	81.7	86.8	86.9	85.7	82.6	77.0	66.6	65.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.7	23.4	24.9	25.8	24.2	22.3	20.8	20.1	22.0	24.8	25.3	21.2	(35)
		MCDBR	24.6	28.0	28.9	29.0	28.0	25.6	24.0	23.7	26.2	26.8	29.3	24.1	(36)
		MCWBR	16.6	16.7	14.9	13.3	10.2	8.2	7.3	7.5	9.5	12.4	17.0	16.4	(37)
	5% WB	MCDBR	19.6	22.5	24.0	23.4	22.1	22.0	19.8	18.9	20.2	19.0	22.2	19.7	(38)
		MCWBR	15.6	16.3	14.1	13.1	9.5	8.6	8.3	8.0	8.4	10.5	15.3	15.5	(39)
(40) Clear-Sky Solar Irradiance	taub		0.323	0.329	0.356	0.386	0.434	0.478	0.517	0.516	0.423	0.380	0.348	0.324	(40)
	taud		2.513	2.490	2.440	2.347	2.248	2.189	2.086	2.083	2.333	2.426	2.465	2.532	(41)
	Ebn at Noon		285	295	293	287	272	259	248	247	268	272	272	279	(42)
	Edh at Noon		27	30	35	40	44	47	52	51	38	32	28	25	(43)
(44) All-Sky Solar Radiation	RadAvg		920	1110	1453	1817	1992	1984	1936	1756	1536	1314	1013	792	(44)
	RadStd		48	114	114	123	146	144	107	88	137	143	79	78	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	+0.90	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+311	+216

Nomenclature: See separate page