

PENSACOLA INTL, FL, USA

WMO: 722220

Lat: 30.478N

Lon: 87.187W

Elev: 125

StdP: 14.63

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.9	33.8	12.6	10.5	35.2	17.6	13.4	39.9	24.0	54.6	21.0	54.7	8.5	0	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	93.9	77.6	92.0	77.4	90.3	77.1	81.2	87.9	80.2	87.1	79.4	86.4	8.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	153.4	84.3	78.4	148.0	83.7	77.4	143.1	83.1	44.8	87.9	43.7	87.0	42.9	86.4	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.3	18.2	16.4	DB	23.8	97.7	3.8	2.6	21.0	99.5	18.8	101.0	16.7	102.5	13.9	104.3
			WB	20.5	82.9	3.5	2.1	18.0	84.4	15.9	85.7	13.9	86.8	11.4	88.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.9	52.4	56.2	61.8	67.9	75.6	81.2	82.7	82.3	79.3	70.8	61.1	55.1
	DBStd	12.66	9.54	8.74	7.62	5.65	4.55	3.11	2.82	2.73	3.96	6.80	7.93	9.15
	HDD50	194	86	37	9	0	0	0	0	0	0	0	10	52
	HDD65	1367	400	263	148	36	2	0	0	0	0	29	164	325
	CDD50	7103	161	211	375	536	794	935	1012	1003	879	644	343	210
	CDD65	2802	10	17	50	122	330	485	547	538	429	208	48	18
	CDH74	25788	6	23	152	534	2649	5044	6042	5731	3959	1434	190	24
	CDH80	9227	0	0	13	51	747	1947	2475	2273	1389	320	12	0
Wind	WSAvg	7.7	8.6	8.6	9.0	9.0	8.1	7.2	6.5	6.1	6.7	7.3	7.6	7.9
Precipitation	PrecAvg	62.5	4.7	5.0	5.7	4.2	4.0	6.5	7.7	7.0	5.7	3.9	4.1	4.3
	PrecMax	87.3	18.8	11.7	13.0	24.4	10.3	21.1	20.4	14.1	19.7	14.8	13.3	9.6
	PrecMin	39.4	0.2	0.8	0.2	0.4	0.1	0.9	1.7	2.1	0.4	0.0	0.3	0.6
	PrecStd	13.1	3.3	2.5	3.1	4.1	2.7	4.5	4.1	3.0	4.1	3.6	2.9	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.8	77.1	81.6	84.1	92.6	95.8	97.2	95.7	94.5	88.9	81.6	76.9
		MCWB	68.0	66.3	65.6	70.1	73.5	76.4	78.8	78.0	77.0	73.9	71.4	69.9
	2%	DB	72.1	73.8	78.0	81.4	88.5	92.6	93.5	92.9	90.9	85.9	78.7	73.9
		MCWB	66.9	66.2	66.8	69.4	73.1	76.7	78.4	78.2	75.7	73.3	70.2	68.9
	5%	DB	69.4	71.1	75.1	79.2	86.2	90.5	91.4	91.0	89.0	83.6	76.1	71.7
		MCWB	65.5	65.5	65.7	68.5	73.1	76.6	78.2	78.0	75.7	72.4	68.2	67.8
	10%	DB	66.9	68.7	72.6	77.2	84.2	88.5	89.7	89.3	87.2	81.3	73.5	69.3
		MCWB	63.3	64.2	65.3	67.9	72.7	76.4	77.8	77.9	75.4	71.3	66.7	66.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.4	70.7	72.2	75.4	78.3	81.8	82.4	83.1	81.4	78.6	75.3	72.8
		MCDB	72.7	73.7	75.9	79.8	84.9	87.9	90.0	90.1	87.6	82.5	78.2	74.7
	2%	WB	68.5	69.1	70.3	73.9	77.2	80.2	80.9	81.3	79.4	77.3	73.1	70.5
		MCDB	70.8	71.6	73.9	77.7	83.6	86.8	88.2	87.8	85.4	82.0	76.0	72.5
	5%	WB	66.5	67.4	69.0	72.5	76.2	79.1	80.0	80.2	78.3	76.0	70.8	68.8
		MCDB	68.7	69.9	72.5	76.2	82.2	86.0	87.6	86.9	84.5	80.7	74.3	71.0
	10%	WB	64.1	65.4	67.3	71.0	75.1	78.2	79.1	79.3	77.5	74.4	68.7	66.5
		MCDB	66.3	67.9	70.9	74.7	81.0	85.1	86.7	86.1	83.9	79.1	72.5	68.8
Mean Daily Temperature Range	5% DB	MDBR	17.5	17.2	17.2	16.4	16.0	14.6	14.2	14.1	15.2	17.6	18.8	17.2
		MCDBR	16.1	15.9	17.2	16.6	17.7	16.9	16.4	16.3	17.0	17.2	17.6	16.1
		MCWBR	12.2	10.5	9.1	8.3	6.9	6.3	6.2	6.2	6.5	7.8	10.5	12.3
	5% WB	MCDBR	14.7	14.1	14.0	12.7	14.3	14.3	14.9	14.2	14.0	13.4	15.1	14.8
		MCWBR	13.0	11.4	9.5	8.3	6.6	6.3	6.5	6.3	6.4	8.1	11.5	13.0
Clear-Sky Solar Irradiance	taub	0.332	0.348	0.372	0.401	0.438	0.465	0.509	0.497	0.441	0.383	0.356	0.341	
	taud	2.544	2.501	2.430	2.351	2.284	2.261	2.157	2.186	2.312	2.455	2.472	2.527	
	Ebn at Noon	286	291	290	283	272	263	251	253	264	274	274	277	
	Edh at Noon	27	31	36	40	43	43	48	46	39	32	29	27	
All-Sky Solar Radiation	RadAvg	980	1167	1582	1906	2116	1995	1878	1747	1642	1449	1113	861	
	RadStd	74	156	124	151	111	156	128	132	97	141	97	81	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+277	+194
(47)	Regional (37 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+279	+173

Nomenclature: See separate page