

PENSACOLA INTL, FL, USA

WMO: 722220

Lat: 30.478N

Lon: 87.187W

Elev: 38

StdP: 100.87

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.2	1.0	-10.8	1.5	1.8	-8.0	1.9	4.4	10.7	12.6	9.4	12.6	3.8	0	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	34.4	25.3	33.3	25.2	32.4	25.1	27.3	31.1	26.8	30.6	26.3	30.2	3.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.9	29.0	25.8	21.1	28.7	25.2	20.4	28.4	86.3	31.1	83.8	30.6	81.8	30.2	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	8.1	7.4	DB	-4.6	36.5	2.1	1.4	-6.1	37.5	-7.3	38.4	-8.5	39.2	-10.1	40.2	
			WB	-6.4	28.3	2.0	1.2	-7.8	29.1	-8.9	29.8	-10.0	30.5	-11.5	31.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	11.3	13.4	16.6	19.9	24.2	27.3	28.1	28.0	26.3	21.5	16.2	12.8	(6)
(7)		DBStd	7.03	5.30	4.86	4.23	3.14	2.53	1.73	1.56	1.51	2.20	3.78	4.41	5.09	(7)
(8)		HDD10.0	108	48	21	5	0	0	0	0	0	0	6	29		(8)
(9)		HDD18.3	759	222	146	82	20	1	0	0	0	0	16	91	181	(9)
(10)		CDD10.0	3946	89	117	208	298	441	519	562	557	488	358	191	117	(10)
(11)		CDD18.3	1557	6	9	28	68	183	269	304	299	238	116	27	10	(11)
(12)		CDH23.3	14327	3	13	84	297	1472	2802	3357	3184	2199	797	106	13	(12)
(13)	CDH26.7	5126	0	0	7	28	415	1082	1375	1263	772	178	7	0	(13)	
(14)	Wind	WSAvg	3.5	3.8	3.8	4.0	4.0	3.6	3.2	2.9	2.7	3.0	3.3	3.4	3.5	(14)
(15)	Precipitation	PrecAvg	1587	120	128	146	107	101	166	196	178	146	99	104	108	(15)
(16)		PrecMax	2218	477	296	329	621	262	537	517	359	501	377	337	243	(16)
(17)		PrecMin	1000	5	20	6	10	2	22	43	53	10	0	8	14	(17)
(18)		PrecStd	333	84	64	78	105	68	114	105	77	104	91	74	47	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.8	25.0	27.6	28.9	33.7	35.4	36.2	35.4	34.7	31.6	27.5	24.9	(19)
(20)		0.4%	MCWB	20.0	19.0	18.7	21.2	23.1	24.7	26.0	25.6	25.0	23.3	21.9	21.1	(20)
(21)		2%	DB	22.3	23.2	25.5	27.4	31.4	33.7	34.2	33.8	32.7	30.0	26.0	23.3	(21)
(22)		2%	MCWB	19.4	19.0	19.3	20.8	22.8	24.9	25.8	25.7	24.3	22.9	21.2	20.5	(22)
(23)		5%	DB	20.8	21.7	23.9	26.2	30.1	32.5	33.0	32.8	31.7	28.7	24.5	22.1	(23)
(24)		5%	MCWB	18.6	18.6	18.7	20.3	22.8	24.8	25.7	25.5	24.3	22.4	20.1	19.9	(24)
(25)		10%	DB	19.4	20.4	22.5	25.1	29.0	31.4	32.0	31.8	30.6	27.4	23.1	20.7	(25)
(26)		10%	MCWB	17.4	17.9	18.5	19.9	22.6	24.6	25.5	25.5	24.1	21.8	19.3	18.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	21.5	22.4	24.1	25.7	27.7	28.0	28.4	27.5	25.9	24.1	22.7	(27)
(28)		0.4%	MCDWB	22.6	23.1	24.4	26.6	29.4	31.1	32.2	32.3	30.9	28.1	25.7	23.7	(28)
(29)		2%	WB	20.3	20.6	21.3	23.3	25.1	26.8	27.1	27.4	26.4	25.2	22.8	21.4	(29)
(30)		2%	MCDWB	21.5	22.0	23.3	25.4	28.6	30.4	31.2	31.0	29.6	27.8	24.5	22.5	(30)
(31)		5%	WB	19.2	19.7	20.5	22.5	24.5	26.1	26.7	26.8	25.7	24.4	21.6	20.4	(31)
(32)		5%	MCDWB	20.4	21.0	22.5	24.5	27.9	30.0	30.9	30.5	29.2	27.1	23.5	21.7	(32)
(33)		10%	WB	17.9	18.6	19.6	21.7	23.9	25.7	26.2	26.3	25.3	23.6	20.4	19.2	(33)
(34)		10%	MCDWB	19.1	19.9	21.6	23.7	27.2	29.5	30.4	30.0	28.8	26.1	22.5	20.4	(34)
(35)	Mean Daily Temperature Range	MDBR	9.7	9.6	9.6	9.1	8.9	8.1	7.9	7.9	8.4	9.8	10.4	9.6	(35)	
(36)		5% DB	MCDBR	8.9	8.8	9.5	9.2	9.8	9.4	9.1	9.1	9.4	9.5	9.8	9.0	(36)
(37)		5% DB	MCWBR	6.8	5.8	5.0	4.6	3.8	3.5	3.4	3.4	3.6	4.3	5.8	6.9	(37)
(38)		5% WB	MCDBR	8.2	7.8	7.8	7.1	7.9	7.9	8.3	7.9	7.8	7.5	8.4	8.2	(38)
(39)		5% WB	MCWBR	7.2	6.3	5.3	4.6	3.7	3.5	3.6	3.5	3.5	4.5	6.4	7.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.348	0.372	0.401	0.438	0.465	0.509	0.497	0.441	0.383	0.356	0.341	(40)	
(41)		taud	2.544	2.501	2.430	2.351	2.284	2.261	2.157	2.186	2.312	2.455	2.472	2.527	(41)	
(42)		Ebn at Noon	902	916	913	893	857	829	792	798	833	865	864	872	(42)	
(43)		Edh at Noon	86	98	112	125	135	137	152	146	124	101	91	84	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.09	3.68	4.99	6.01	6.67	6.29	5.92	5.51	5.17	4.57	3.51	2.71	(44)	
(45)		RadStd	0.23	0.49	0.39	0.48	0.35	0.49	0.40	0.41	0.31	0.44	0.30	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+154	+108	(46)	
(47) Regional (37 neighbors)		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+155	+96	(47)	

Nomenclature: See separate page