

PENSACOLA NAS, FL, USA

WMO: 722225

Lat: 30.350N

Lon: 87.317W

Elev: 28

StdP: 14.68

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03855

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.1	32.9	13.2	10.7	35.9	18.4	13.9	39.3	24.0	58.4	20.7	56.8	6.1	350	0.411

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	92.8	78.6	91.0	78.3	89.8	78.1	81.8	88.1	80.7	87.3	80.0	86.7	9.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.1	156.2	85.3	79.0	150.8	84.6	78.1	146.1	84.1	45.2	88.4	44.3	87.4	43.4	86.3	91.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.3	18.1	16.4	DB	23.3	97.0	3.6	3.5	20.7	99.6	18.6	101.6	16.6	103.6	14.0	106.1	(4)
(5)			WB	20.6	84.1	3.3	2.3	18.2	85.8	16.2	87.2	14.4	88.5	12.0	90.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.2	51.8	55.7	60.7	66.9	74.6	80.3	81.9	81.8	78.6	70.0	60.6	55.2		
	DBStd	12.60	9.49	8.64	7.70	6.06	4.96	3.29	2.78	2.74	4.02	7.19	8.11	9.19		
	HDD50	208	93	39	12	0	0	0	0	0	0	0	11	53		
	HDD65	1452	417	273	172	51	4	0	0	0	0	36	177	322		
	CDD50	6867	150	200	344	507	762	909	987	985	859	620	330	214		
	CDD65	2635	8	13	39	108	302	459	522	520	409	191	46	18		
	CDH74	24959	3	10	81	437	2614	4886	5752	5612	3867	1502	176	19		
	CDH80	8726	0	0	3	27	649	1822	2322	2247	1340	306	10	0		
(14) Wind	WSAvg	7.5	8.0	8.2	8.5	8.5	8.0	7.2	6.2	6.1	7.3	7.6	7.3	7.7		
(15) Precipitation	PrecAvg	58.0	5.1	4.8	5.4	3.7	3.9	5.0	6.9	6.1	6.4	3.9	3.6	4.3		
	PrecMax	83.1	20.0	13.1	15.5	10.5	13.8	16.1	13.7	12.4	18.9	18.0	10.5	8.5		
	PrecMin	30.3	0.2	0.5	0.3	0.4	0.0	0.7	1.4	0.4	0.6	0.0	0.6	0.5		
	PrecStd	14.0	4.0	3.0	3.1	2.7	3.2	3.5	3.5	2.7	4.4	4.0	2.4	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.2	75.8	79.5	83.4	90.8	94.4	96.6	95.1	92.8	88.8	81.2	76.6		
		MCWB	68.1	67.9	69.3	71.6	74.1	78.0	79.5	79.6	77.2	77.1	72.1	70.7		
	2%	DB	71.5	72.9	76.3	80.5	87.9	91.5	92.7	91.9	90.3	85.5	78.5	73.9		
		MCWB	67.0	66.0	67.5	70.3	74.7	78.1	78.9	79.3	77.1	75.1	69.8	69.3		
	5%	DB	69.3	70.5	73.8	78.6	85.6	89.6	90.7	90.4	88.4	83.4	76.0	72.0		
		MCWB	65.8	65.1	66.7	69.7	74.4	77.5	78.7	79.0	76.9	73.8	68.5	68.4		
	10%	DB	66.8	68.4	72.1	76.6	83.6	88.0	89.2	89.0	86.8	81.3	73.8	69.8		
		MCWB	63.7	64.2	66.0	68.7	74.1	77.3	78.4	78.6	76.5	72.6	67.8	66.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.3	70.7	72.4	76.0	79.2	82.0	83.1	83.4	82.2	80.2	75.1	72.7		
		MCDB	72.5	73.3	76.0	80.7	85.2	87.6	88.7	90.7	87.3	85.0	78.4	74.9		
	2%	WB	68.3	68.9	70.4	74.3	77.8	80.4	81.4	81.9	80.4	78.2	73.0	70.9		
		MCDB	70.2	71.3	73.5	78.2	83.8	87.1	88.3	88.6	86.3	82.7	76.0	72.7		
	5%	WB	66.6	67.1	69.1	72.9	76.8	79.5	80.4	80.7	79.4	76.7	71.0	69.3		
		MCDB	68.4	69.1	72.2	76.3	82.7	86.6	87.5	87.3	85.3	81.3	74.4	71.4		
	10%	WB	64.3	65.4	67.5	71.4	75.7	78.5	79.6	80.0	78.2	75.1	69.1	67.2		
		MCDB	66.3	67.3	70.6	74.5	81.5	85.5	86.9	86.5	84.2	79.6	72.9	69.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.3	17.9	17.7	17.0	16.5	14.3	14.3	14.2	15.6	18.7	20.2	18.0		
		MCDBR	15.7	15.8	16.5	16.6	17.5	16.2	16.4	16.4	16.9	17.4	18.5	15.9		
	5% WB	MCWBR	12.7	11.4	10.5	9.5	8.2	6.8	6.8	7.1	7.5	9.0	11.9	12.8		
		MCWBR	14.0	13.2	13.3	11.9	13.7	13.9	14.8	14.4	13.9	13.4	15.9	14.9		
(40) Clear-Sky Solar Irradiance	taub		0.336	0.351	0.375	0.404	0.440	0.466	0.508	0.497	0.443	0.386	0.359	0.344		
		taud	2.542	2.501	2.430	2.351	2.287	2.266	2.168	2.195	2.315	2.456	2.472	2.526		
	Ebn at Noon		285	290	289	282	271	263	251	253	264	274	273	276		
		Edh at Noon	27	31	36	40	43	43	48	46	39	32	29	27		
(44) All-Sky Solar Radiation	RadAvg		979	1171	1583	1908	2127	2002	1880	1748	1644	1448	1113	862		
(45)	RadStd		76	157	126	155	110	156	128	132	97	138	98	80		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+281	+180

Nomenclature: See separate page