

PENSACOLA NAS, FL, USA

WMO: 722225

Lat: 30.350N

Lon: 87.317W

Elev: 9

StdP: 101.22

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03855

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.6	0.5	-10.5	1.5	2.2	-7.6	2.0	4.1	10.7	14.7	9.2	13.8	2.7	350	0.411

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	33.8	25.9	32.8	25.7	32.1	25.6	27.7	31.2	27.1	30.7	26.7	30.4	4.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	29.6	26.1	21.5	29.2	25.6	20.9	28.9	87.4	31.3	85.1	30.8	83.0	30.2	33.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	8.1	7.3	-4.9	36.1	2.0	1.9	-6.3	37.5	-7.4	38.7	-8.6	39.8	-10.0	41.2		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-6.4	29.0	1.8	1.3	-7.7	29.9	-8.8	30.7	-9.8	31.4	-11.1	32.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	11.0	13.2	16.0	19.4	23.7	26.8	27.7	27.6	25.9	21.1	15.9	12.9
	DBStd	7.00	5.27	4.80	4.28	3.36	2.75	1.83	1.55	1.52	2.23	3.99	4.50	5.11
	HDD10.0	116	52	22	7	0	0	0	0	0	0	0	6	29
	HDD18.3	807	232	152	96	28	2	0	0	0	0	20	98	179
	CDD10.0	3815	83	111	191	282	423	505	548	547	477	344	183	119
	CDD18.3	1464	4	7	22	60	168	255	290	289	227	106	26	10
	CDH23.3	13866	2	6	45	243	1452	2714	3196	3118	2148	834	98	11
	CDH26.7	4848	0	0	2	15	361	1012	1290	1248	744	170	6	0
Wind	WSAvg	3.4	3.6	3.7	3.8	3.8	3.6	3.2	2.8	2.7	3.3	3.4	3.3	3.4
Precipitation	PrecAvg	1473	129	123	136	95	99	126	176	155	163	98	91	108
	PrecMax	2111	508	333	394	267	351	408	348	315	481	458	267	215
	PrecMin	769	5	13	7	9	0	19	36	9	15	0	14	13
	PrecStd	355	102	76	80	69	81	88	88	69	111	102	60	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.5	24.3	26.4	28.5	32.7	34.7	35.9	35.1	33.8	31.6	27.3	24.8
		MCWB	20.1	19.9	20.7	22.0	23.4	25.6	26.4	26.4	25.1	25.1	22.3	21.5
	2%	DB	21.9	22.7	24.6	26.9	31.0	33.1	33.7	33.3	32.4	29.7	25.9	23.3
		MCWB	19.4	18.9	19.7	21.3	23.7	25.6	26.1	26.3	25.1	24.0	21.0	20.7
	5%	DB	20.7	21.4	23.2	25.9	29.8	32.0	32.6	32.4	31.3	28.6	24.5	22.2
		MCWB	18.8	18.4	19.3	20.9	23.6	25.3	25.9	26.1	25.0	23.2	20.3	20.2
	10%	DB	19.3	20.2	22.3	24.8	28.7	31.1	31.8	31.7	30.5	27.4	23.2	21.0
		MCWB	17.6	17.9	18.9	20.4	23.4	25.2	25.8	25.9	24.7	22.5	19.9	19.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	21.5	22.4	24.4	26.2	27.8	28.4	28.6	27.9	26.8	23.9	22.6
		MCDB	22.5	22.9	24.4	27.0	29.5	30.9	31.5	32.6	30.7	29.5	25.8	23.8
	2%	WB	20.2	20.5	21.3	23.5	25.5	26.9	27.5	27.7	26.9	25.7	22.8	21.6
		MCDB	21.2	21.8	23.0	25.7	28.8	30.6	31.3	31.4	30.2	28.2	24.5	22.6
	5%	WB	19.2	19.5	20.6	22.7	24.9	26.4	26.9	27.1	26.3	24.9	21.7	20.7
		MCDB	20.2	20.6	22.3	24.6	28.2	30.3	30.8	30.7	29.6	27.4	23.6	21.9
	10%	WB	18.0	18.6	19.7	21.9	24.3	25.9	26.4	26.6	25.7	24.0	20.6	19.6
		MCDB	19.0	19.6	21.5	23.6	27.5	29.7	30.5	30.3	29.0	26.5	22.7	20.7
Mean Daily Temperature Range	5% DB	MDBR	10.2	9.9	9.8	9.4	9.2	7.9	7.9	7.9	8.6	10.4	11.2	10.0
		MCDBR	8.7	8.8	9.1	9.2	9.7	9.0	9.1	9.1	9.4	9.7	10.3	8.8
		MCWBR	7.1	6.4	5.9	5.3	4.5	3.8	3.8	3.9	4.2	5.0	6.6	7.1
	5% WB	MCDBR	7.8	7.4	7.4	6.6	7.6	7.7	8.2	8.0	7.7	7.4	8.8	8.3
		MCWBR	7.0	6.5	5.5	4.6	4.1	3.8	4.1	4.0	4.1	5.0	7.1	7.4
Clear-Sky Solar Irradiance	taub	0.336	0.351	0.375	0.404	0.440	0.466	0.508	0.497	0.443	0.386	0.359	0.344	
	taud	2.542	2.501	2.430	2.351	2.287	2.266	2.168	2.195	2.315	2.456	2.472	2.526	
	Ebn at Noon	898	913	910	890	855	828	792	798	831	863	861	869	
	Edh at Noon	86	98	112	125	134	137	150	145	124	101	92	84	
All-Sky Solar Radiation	RadAvg	3.09	3.69	4.99	6.01	6.70	6.31	5.93	5.51	5.18	4.57	3.51	2.72	
	RadStd	0.24	0.50	0.40	0.49	0.35	0.49	0.41	0.41	0.31	0.43	0.31	0.25	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+156	+100

Nomenclature: See separate page