

WHITING FIELD NAS NORTH, FL, USA

WMO: 722226

Lat: 30.717N

Lon: 87.017W

Elev: 199

StdP: 14.59

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 93841

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.6	30.9	11.2	9.8	35.7	16.3	12.6	39.2	24.2	57.2	20.8	58.7	5.7	0	0.378

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	94.9	76.9	93.0	76.6	91.3	76.3	80.5	88.8	79.7	88.0	78.7	86.8	6.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.5	149.0	84.3	77.4	143.6	83.4	76.6	139.5	82.7	44.2	88.9	43.2	87.8	42.3	87.0	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.8	17.4	15.4	21.0	98.4	3.4	2.9	18.5	100.5	16.5	102.2	14.6	103.8	12.1	105.9		
			19.2	82.3	4.0	1.3	16.3	83.3	14.0	84.1	11.7	84.8	8.8	85.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.7	50.6	55.5	60.8	66.5	74.3	80.2	81.7	81.5	78.3	68.7	59.1	54.7
	DBStd	12.89	9.53	9.32	8.50	6.09	5.01	3.64	2.53	2.88	3.79	7.06	8.04	9.68
	HDD50	252	110	48	16	0	0	0	0	0	0	0	16	62
	HDD65	1575	455	283	180	55	5	0	0	0	0	47	210	340
	CDD50	6719	128	204	351	496	754	906	981	977	848	579	287	208
	CDD65	2567	8	18	51	101	293	456	516	512	398	161	32	21
	CDH74	23005	11	61	301	746	2626	4435	5029	4925	3328	1272	195	76
	CDH80	9261	0	2	38	120	968	1977	2211	2197	1370	343	17	18
Wind	WSAvg	6.2	7.2	7.5	7.8	7.5	6.2	5.5	4.9	4.8	4.9	6.0	6.2	6.7
Precipitation	PrecAvg	64.4	5.4	5.2	5.9	4.1	4.7	7.4	7.8	6.3	5.3	3.3	3.9	4.7
	PrecMax	86.5	15.7	9.8	13.0	12.6	11.7	27.3	17.8	10.0	19.5	8.8	8.7	9.4
	PrecMin	36.5	0.8	1.4	0.9	0.4	0.0	1.6	2.0	2.8	0.6	0.0	0.4	1.1
	PrecStd	12.5	3.1	2.3	2.7	3.1	2.7	4.8	3.8	2.0	3.5	2.4	2.3	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.5	79.5	83.9	86.0	94.2	98.3	96.1	97.8	94.7	88.7	82.1	78.8
		MCWB	68.1	65.8	66.3	69.8	72.6	75.7	78.3	77.7	75.2	73.3	70.2	66.9
	2%	DB	72.6	75.6	80.5	83.2	90.4	94.4	93.8	94.2	91.9	86.2	78.9	75.5
		MCWB	65.7	65.8	66.3	68.1	72.1	76.3	77.7	77.7	75.1	71.5	68.0	68.3
	5%	DB	70.0	72.6	77.5	81.0	87.8	92.1	91.9	92.1	90.0	84.1	76.0	73.0
		MCWB	64.7	64.7	65.1	67.7	72.2	76.1	77.5	77.4	74.8	70.3	66.2	68.0
	10%	DB	66.3	70.0	74.3	78.7	85.4	89.8	90.1	90.1	87.9	81.5	73.2	70.1
		MCWB	61.2	64.0	64.3	66.8	71.6	76.0	77.4	77.1	74.7	69.6	65.2	65.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.1	71.4	72.6	75.3	77.8	81.2	81.6	82.3	80.3	78.0	74.5	74.0
		MCDB	72.9	74.0	76.5	81.2	84.8	88.8	90.5	90.6	87.4	84.1	77.7	76.5
	2%	WB	68.3	69.6	70.6	73.5	76.4	79.5	80.3	80.7	78.6	76.1	71.9	71.0
		MCDB	71.3	72.3	74.6	77.8	83.6	87.4	89.1	89.1	86.0	81.5	75.1	73.2
	5%	WB	65.9	67.9	68.9	71.8	75.2	78.4	79.5	79.7	77.6	74.6	69.4	68.8
		MCDB	68.9	70.9	73.4	76.5	82.5	86.6	88.1	88.0	84.8	79.9	73.8	71.4
	10%	WB	62.7	65.5	67.0	70.1	74.0	77.5	78.5	78.5	76.5	72.6	67.0	66.4
		MCDB	65.5	68.8	72.1	75.6	81.6	86.0	86.6	86.4	83.6	78.0	71.7	69.5
Mean Daily Temperature Range	5% DB	MDBR	21.1	21.5	22.2	21.6	21.3	18.5	17.6	17.7	18.9	21.8	23.1	19.9
		MCDBR	20.2	20.8	22.4	22.8	23.3	21.6	19.9	20.4	21.3	22.7	23.2	19.5
		MCWBR	14.4	12.8	11.2	10.8	9.1	7.5	7.4	7.7	8.1	10.7	14.1	13.9
	5% WB	MCDBR	17.6	16.6	17.6	17.3	18.7	18.5	17.8	17.8	17.3	17.1	19.8	17.0
		MCWBR	15.3	12.9	11.2	10.7	8.7	7.6	7.7	7.7	7.9	10.3	14.9	14.6
Clear-Sky Solar Irradiance	taub	0.328	0.344	0.368	0.397	0.435	0.466	0.513	0.499	0.440	0.380	0.352	0.336	
	taud	2.546	2.501	2.430	2.351	2.279	2.249	2.134	2.167	2.306	2.452	2.471	2.530	
	Ebn at Noon	287	292	291	284	272	263	250	252	264	275	275	278	
	Edh at Noon	27	31	36	40	43	44	49	47	40	32	29	26	
All-Sky Solar Radiation	RadAvg	967	1153	1563	1890	2090	1983	1878	1749	1629	1433	1099	848	
	RadStd	71	152	125	152	117	159	123	127	101	145	96	83	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	+277	+175

Nomenclature: See separate page