

MOREHOUSE, LA, USA

WMO: 722253

Lat: 32.756N

Lon: 91.881W

Elev: 167

StdP: 14.61

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 53992

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.5	27.5	10.8	9.6	30.7	16.9	13.0	36.1	18.0	58.6	16.3	57.5	1.4	0	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	99.0	77.8	96.8	77.5	94.7	77.2	82.3	90.3	81.1	88.9	80.1	88.3	4.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.9	161.2	86.3	79.3	152.9	84.0	78.4	148.5	83.3	46.0	89.1	44.7	88.5	43.7	88.5	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.7	12.5	10.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.0	46.3	50.9	58.3	65.4	73.5	80.9	82.4	82.4	78.7	67.2	55.6	49.7
	DBStd	15.18	10.29	10.60	9.68	7.64	6.26	4.09	4.13	3.80	5.10	8.16	9.63	10.08
	HDD50	531	195	110	37	3	0	0	0	0	0	1	51	134
	HDD65	2210	582	409	249	86	13	0	0	0	1	75	309	486
	CDD50	6373	82	134	294	464	729	927	1003	1003	860	533	218	126
	CDD65	2577	3	14	41	98	277	477	538	538	410	142	26	13
	CDH74	26203	10	81	311	909	2512	5129	5937	5781	3997	1323	170	43
	CDH80	12443	0	7	49	201	973	2562	3055	3074	2009	490	22	1
(14) Wind	WSAvg	3.4	4.1	4.6	4.8	4.6	3.5	3.0	2.6	2.3	2.1	2.7	3.3	3.7
(15) Precipitation	PrecAvg	55.9	5.4	5.0	5.6	5.4	5.3	4.5	4.1	3.1	3.1	3.8	4.7	5.6
	PrecMax	86.0	14.9	11.3	12.1	24.9	13.9	14.5	12.8	10.1	9.0	11.4	11.0	18.7
	PrecMin	36.1	0.5	1.0	0.6	0.4	0.6	0.6	0.9	0.3	0.4	0.0	1.1	0.6
	PrecStd	13.3	3.3	2.7	2.8	3.9	3.3	2.9	2.9	2.1	2.1	3.0	2.4	3.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.3	81.0	84.2	88.0	92.5	99.9	100.5	100.8	99.7	92.3	82.7	78.9
		MCWB	64.4	68.0	68.8	74.4	75.3	79.2	78.5	78.5	73.9	70.5	70.0	70.1
	2%	DB	71.6	76.6	81.2	84.4	90.4	97.3	97.7	98.6	97.1	89.2	79.2	74.3
		MCWB	62.7	67.0	68.7	71.1	74.4	79.5	79.3	77.9	73.9	72.8	67.8	68.7
	5%	DB	66.9	72.5	77.4	82.1	88.4	93.7	95.4	96.1	93.7	85.9	74.9	70.8
		MCWB	59.5	64.5	65.6	69.2	73.8	79.1	78.5	76.9	74.5	70.5	66.8	66.1
	10%	DB	63.3	68.4	73.4	79.7	86.0	91.4	93.2	93.6	90.9	81.8	71.6	67.0
		MCWB	57.4	62.3	63.6	67.8	73.4	78.2	78.0	77.0	74.3	69.6	65.9	63.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.4	72.3	73.2	76.9	81.2	84.3	85.2	82.3	79.9	78.3	73.5	72.7
		MCDB	72.1	76.4	79.7	84.2	85.6	94.6	93.4	90.3	85.5	84.1	77.6	75.6
	2%	WB	66.0	69.1	70.7	74.9	78.9	82.4	82.2	81.2	78.5	76.6	71.6	70.2
		MCDB	69.5	73.3	76.9	81.1	85.1	90.9	89.7	90.3	85.9	83.7	75.8	73.2
	5%	WB	63.0	66.8	69.0	72.8	77.2	81.0	80.8	80.2	77.6	74.8	69.6	67.9
		MCDB	65.6	71.5	75.3	78.5	84.2	88.8	88.4	89.6	86.4	81.7	74.1	70.6
	10%	WB	58.1	63.6	66.8	70.8	75.3	79.7	79.9	79.2	76.6	72.8	66.1	64.3
		MCDB	61.5	67.5	72.7	77.1	82.4	87.8	88.3	88.7	85.2	78.0	70.0	66.3
(35) Mean Daily Temperature Range	5% DB	MDBR	20.7	20.6	22.4	22.5	20.9	20.5	20.4	21.4	22.7	23.9	22.0	18.8
		MCDBR	24.8	24.3	24.2	24.0	22.6	22.6	23.0	24.8	26.5	26.5	23.7	21.8
	5% WB	MCWBR	16.6	15.6	13.6	11.7	9.3	8.4	7.4	7.1	8.0	11.1	14.2	15.7
		MCWBR	19.7	21.5	22.0	19.9	18.8	20.9	20.3	20.4	20.8	21.3	18.8	18.9
(40) Clear-Sky Solar Irradiance	taub	taub	0.326	0.337	0.369	0.405	0.437	0.488	0.492	0.491	0.432	0.366	0.346	0.325
		taud	2.514	2.482	2.399	2.291	2.261	2.148	2.168	2.167	2.313	2.465	2.476	2.523
	Ebn at Noon	Ebn at Noon	284	291	288	281	272	256	255	253	265	277	273	277
		Edh at Noon	27	31	36	42	43	49	48	47	39	31	28	26
(44) All-Sky Solar Radiation	RadAvg	RadAvg	841	974	1374	1716	1897	2036	1982	1837	1589	1305	950	739
	RadStd	RadStd	77	166	111	120	123	145	122	152	139	177	102	84

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page