

MOREHOUSE, LA, USA

WMO: 722253

Lat: 32.756N

Lon: 91.881W

Elev: 51

StdP: 100.72

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 53992

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.5	-11.8	1.4	-0.7	-8.4	1.9	2.3	8.0	14.8	7.3	14.2	0.6	0	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	37.2	25.4	36.0	25.3	34.8	25.1	27.9	32.4	27.3	31.6	26.7	31.3	2.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	23.0	30.2	26.3	21.8	28.9	25.8	21.2	28.5	89.1	31.7	86.0	31.4	83.7	31.4	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.0	5.6	4.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	8.0	10.5	14.6	18.5	23.1	27.2	28.0	25.9	19.5	13.1	9.9		
		DBStd	8.43	5.72	5.89	5.38	4.24	3.48	2.27	2.29	2.11	2.83	4.53	5.60		
		HDD10.0	295	108	61	21	2	0	0	0	0	1	28	74		
		HDD18.3	1228	323	227	138	48	7	0	0	1	42	172	270		
		CDD10.0	3541	46	74	163	258	405	515	557	478	296	121	70		
		CDD18.3	1432	2	8	23	54	154	265	299	228	79	14	7		
		CDH23.3	14557	6	45	173	505	1396	2849	3298	3212	2221	735	24		
		CDH26.7	6913	0	4	27	112	541	1423	1697	1708	1116	272	1		
(14)	Wind	WSAvg	1.5	1.8	2.1	2.1	2.1	1.6	1.3	1.2	1.0	0.9	1.2	1.5	1.7	
(15)	Precipitation	PrecAvg	1419	136	128	142	136	135	115	105	79	80	97	120	142	
(16)		PrecMax	2184	378	286	307	632	352	369	326	256	229	290	279	475	
(17)		PrecMin	916	13	25	15	9	16	15	23	7	10	1	28	16	
(18)		PrecStd	339	85	69	72	100	85	74	73	54	54	77	62	81	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	24.0	27.2	29.0	31.1	33.6	37.7	38.0	38.2	37.6	33.5	28.2	26.1		
(20)		0.4% MCWB	18.0	20.0	20.5	23.6	24.1	26.2	25.8	25.8	23.3	21.4	21.1	21.1		
(21)		2% DB	22.0	24.8	27.3	29.1	32.4	36.3	36.5	37.0	36.1	31.8	26.2	23.5		
(22)		2% MCWB	17.0	19.5	20.4	21.7	23.6	26.4	26.3	25.5	23.3	22.7	19.9	20.4		
(23)		5% DB	19.4	22.5	25.2	27.8	31.3	34.3	35.2	35.6	34.3	30.0	23.8	21.6		
(24)		5% MCWB	15.3	18.0	18.7	20.7	23.2	26.1	25.8	24.9	23.6	21.4	19.3	18.9		
(25)		10% DB	17.4	20.2	23.0	26.5	30.0	33.0	34.0	34.2	32.7	27.7	22.0	19.4		
(26)		10% MCWB	14.1	16.8	17.5	19.9	23.0	25.7	25.6	25.0	23.5	20.9	18.9	17.7		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	20.8	22.4	22.9	24.9	27.4	29.1	29.6	28.0	26.6	25.7	23.1	22.6		
(28)		0.4% MCDB	22.3	24.7	26.5	29.0	29.8	34.8	34.1	32.4	29.7	29.0	25.3	24.2		
(29)		2% WB	18.9	20.6	21.5	23.8	26.1	28.0	27.9	27.3	25.9	24.8	22.0	21.2		
(30)		2% MCDB	20.8	23.0	24.9	27.3	29.5	32.7	32.1	32.4	29.9	28.7	24.3	22.9		
(31)		5% WB	17.2	19.3	20.5	22.7	25.1	27.2	27.1	26.8	25.3	23.8	20.9	20.0		
(32)		5% MCDB	18.7	22.0	24.0	25.8	29.0	31.6	31.3	32.0	30.2	27.6	23.4	21.5		
(33)		10% WB	14.5	17.5	19.3	21.6	24.1	26.5	26.6	26.2	24.8	22.7	19.0	17.9		
(34)		10% MCDB	16.4	19.7	22.6	25.0	28.0	31.0	31.3	31.5	29.6	25.6	21.1	19.0		
(35)	Mean Daily Temperature Range	MDBR	11.5	11.5	12.4	12.5	11.6	11.4	11.4	11.9	12.6	13.3	12.2	10.4		
(36)		5% DB MCDBR	13.8	13.5	13.4	13.3	12.5	12.5	12.8	13.8	14.7	14.7	13.1	12.1		
(37)		5% WB MCWBR	9.2	8.7	7.6	6.5	5.2	4.6	4.1	3.9	4.4	6.2	7.9	8.7		
(38)		5% WB MCDBR	10.9	12.0	12.2	11.0	10.4	11.6	11.3	11.4	11.6	11.9	10.4	10.5		
(39)	Clear-Sky Solar Irradiance	taub	0.326	0.337	0.369	0.405	0.437	0.488	0.492	0.491	0.432	0.366	0.346	0.325		
(40)		taud	2.514	2.482	2.399	2.291	2.261	2.148	2.168	2.167	2.313	2.465	2.476	2.523		
(41)		Ebn at Noon	894	918	909	885	856	808	803	799	835	873	861	874		
(42)		Edh at Noon	85	97	114	132	137	153	150	148	123	98	88	81		
(44)	All-Sky Solar Radiation	RadAvg	2.65	3.07	4.33	5.41	5.98	6.42	6.25	5.79	5.01	4.11	3.00	2.33		
(45)		RadStd	0.24	0.52	0.35	0.38	0.39	0.46	0.39	0.48	0.44	0.56	0.32	0.27		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page