

OKEECHOBEE COUNTY AP, FL, USA

WMO: 722261

Lat: 27.267N

Lon: 80.850W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 00360

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.4	5.0	-2.7	3.0	7.6	-0.2	3.7	10.1	9.2	18.7	8.3	18.1	1.6	340	0.315

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	34.1	25.4	32.9	25.2	32.5	25.1	27.9	31.3	27.1	30.6	26.4	30.2	3.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	29.6	26.2	21.6	29.0	25.2	20.4	28.3	88.4	32.2	85.0	30.6	82.3	29.9	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.8	5.7	-0.1	35.0	1.2	1.5	-1.0	36.1	-1.8	37.0	-2.5	37.8	-3.4	38.9		
			-1.6	27.4	1.4	1.2	-2.6	28.3	-3.4	29.0	-4.2	29.6	-5.2	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	16.0	18.2	19.2	22.4	24.5	26.7	27.3	27.4	26.7	24.3	20.4	18.7
	DBStd	4.91	4.39	4.22	3.62	2.48	2.07	1.38	1.41	1.90	1.79	3.00	3.42	4.16
	HDD10.0	12	8	2	0	0	0	0	0	0	0	0	0	2
	HDD18.3	253	96	49	34	3	0	0	0	0	0	4	19	48
	CDD10.0	4638	193	232	286	373	450	501	537	540	500	442	313	271
	CDD18.3	1837	23	46	62	126	192	251	278	282	250	188	82	58
	CDH23.3	15796	177	372	538	1148	1762	2202	2566	2612	2088	1443	547	342
	CDH26.7	5838	14	61	104	345	691	950	1099	1119	839	472	102	42
Wind	WSAvg	2.2	2.5	2.5	2.6	2.6	2.4	2.0	1.7	1.8	1.8	2.3	2.2	2.3
Precipitation	PrecAvg	1372	62	60	83	75	103	196	169	198	184	123	60	60
	PrecMax	1824	224	176	252	194	285	454	283	426	534	364	176	154
	PrecMin	939	0	6	8	17	14	71	55	53	79	7	3	9
	PrecStd	224	55	39	65	41	65	85	62	80	85	90	48	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	30.1	31.1	32.4	34.1	35.1	35.1	36.0	35.0	32.7	30.9	29.1
		MCWB	21.4	22.0	22.5	22.0	23.2	24.4	26.9	27.2	27.3	25.4	24.0	23.1
	2%	DB	27.1	28.0	29.0	31.2	32.7	33.0	33.0	34.0	32.9	32.0	29.0	27.7
		MCWB	20.8	21.4	21.4	21.9	22.6	24.8	25.4	26.2	26.0	25.4	23.3	22.4
	5%	DB	25.8	27.3	27.6	30.1	32.0	32.5	32.6	32.8	32.3	30.9	27.7	27.1
		MCWB	19.6	20.5	20.4	21.4	22.6	24.7	25.4	25.9	25.7	24.7	22.0	21.9
	10%	DB	23.7	26.1	27.0	28.7	30.3	32.0	32.1	32.2	31.2	29.8	27.0	25.3
		MCWB	18.6	19.4	19.9	21.1	22.6	24.6	25.4	25.8	25.1	24.1	21.3	20.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.1	23.6	24.1	24.6	25.7	27.1	28.1	28.9	28.6	27.0	24.8	24.1
		MCDB	26.4	27.8	28.6	29.5	30.3	31.7	33.0	32.7	32.2	30.1	28.4	27.5
	2%	WB	22.2	22.6	22.9	23.9	24.8	26.2	27.2	28.2	27.6	26.2	24.0	23.3
		MCDB	25.5	26.5	26.8	28.5	29.8	30.9	31.3	31.4	30.5	29.3	28.1	26.8
	5%	WB	21.1	21.8	22.0	23.2	24.1	25.7	26.5	27.2	26.7	25.6	23.2	22.6
		MCDB	23.7	25.4	26.0	27.3	28.8	30.4	30.3	30.4	30.1	28.7	26.5	25.8
	10%	WB	20.0	20.8	21.0	22.5	23.6	25.2	25.9	26.4	25.8	24.9	22.3	21.9
		MCDB	22.4	24.1	24.5	26.6	28.2	29.9	29.8	30.2	29.5	28.3	25.4	24.5
Mean Daily Temperature Range	5% DB	MDBR	12.8	13.0	13.5	12.8	12.0	10.3	9.6	9.2	9.2	10.0	11.7	11.5
		MCDBR	13.3	12.8	13.3	13.2	13.4	11.6	10.1	10.1	9.9	9.7	11.2	10.9
		MCWBR	7.3	6.2	6.1	5.3	4.9	4.3	3.8	3.8	3.6	4.0	5.4	5.9
	5% WB	MCDBR	11.1	11.1	11.8	11.0	11.1	10.0	9.1	9.1	9.1	8.5	9.8	9.7
		MCWBR	7.2	5.8	6.2	5.2	4.7	4.3	3.9	3.9	3.7	3.9	4.9	5.6
Clear-Sky Solar Irradiance	taub	0.347	0.362	0.377	0.392	0.420	0.453	0.467	0.456	0.425	0.404	0.365	0.356	
	taud	2.511	2.482	2.429	2.370	2.337	2.317	2.270	2.328	2.411	2.428	2.486	2.510	
	Ebn at Noon	900	913	915	906	875	840	828	838	857	857	872	874	
	Edh at Noon	92	102	114	124	128	130	136	128	115	107	94	89	
All-Sky Solar Radiation	RadAvg	3.54	4.31	5.24	6.08	6.21	5.68	5.64	5.46	4.88	4.48	3.73	3.22	
	RadStd	0.24	0.23	0.31	0.24	0.47	0.48	0.38	0.33	0.24	0.28	0.18	0.23	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (43 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.41	+0.80	N/A	N/A	N/A	-1	-29	+154	+116

Nomenclature: See separate page