

EVERGREEN, AL, USA

WMO: 722276

Lat: 31.416N

Lon: 87.044W

Elev: 79

StdP: 100.38

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53820

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.9	(c) -2.3	(d) -12.0	(e) 1.3	(f) 1.4	(g) -9.0	(h) 1.8	(i) 4.2	(j) 8.4	(k) 17.7	(l) 7.7	(m) 15.7	(n) 1.1	(o) 340	(p) 0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.0	(c) 35.5	(d) 24.3	(e) 34.3	(f) 24.4	(g) 33.3	(h) 24.3	(i) 26.5	(j) 32.0	(k) 26.0	(l) 31.4	(m) 25.6	(n) 30.8	(o) 2.5	(p) 330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.1	20.4	28.6	24.5	19.7	28.2	24.0	19.1	27.8	82.7	31.8	80.5	31.5	78.5	31.0	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.4	(b) 6.3	(c) 5.4	(e) -7.2	(f) 36.9	(g) 2.1	(h) 1.7	(i) -8.7	(j) 38.1	(k) -9.9	(l) 39.2	(m) -11.1	(n) 40.1	(o) -12.6	(p) 41.4		
(a) 7.4	(b) 6.3	(c) 5.4	(e) -8.1	(f) 27.4	(g) 2.0	(h) 0.4	(i) -9.6	(j) 27.7	(k) -10.7	(l) 28.0	(m) -11.9	(n) 28.2	(o) -13.3	(p) 28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	9.3	11.5	15.1	18.7	22.8	26.3	27.3	27.3	25.0	19.4	13.7	10.6
	DBStd	7.58	5.74	5.21	4.66	3.70	3.01	1.80	1.41	1.72	2.65	4.30	4.58	5.23
	HDD10.0	209	84	40	11	1	0	0	0	0	0	1	16	57
	HDD18.3	1083	283	197	121	40	6	0	0	0	1	40	151	244
	CDD10.0	3481	63	83	168	261	397	488	536	536	450	293	127	77
	CDD18.3	1312	4	7	19	50	144	238	278	278	201	73	13	6
	CDH23.3	12323	18	37	181	528	1443	2293	2693	2608	1734	674	92	22
CDH26.7	5335	3	3	22	123	583	1093	1290	1256	752	200	10	0	
Wind	WSAvg	1.9	2.3	2.5	2.5	2.3	1.9	1.6	1.4	1.4	1.6	1.8	1.9	2.2
Precipitation	PrecAvg	1503	130	124	125	107	102	137	145	153	119	83	121	156
	PrecMax	2139	289	339	334	254	246	262	261	311	253	206	264	467
	PrecMin	1081	49	41	17	19	15	47	36	60	17	7	50	55
	PrecStd	252	50	68	76	67	56	64	65	66	66	61	62	93
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	26.8	28.8	30.9	34.4	36.4	36.5	37.4	35.3	32.5	27.9	25.6
		MCWB	18.3	19.8	18.5	20.8	22.8	23.2	24.6	24.3	24.3	22.2	20.2	19.8
	2%	DB	22.8	24.2	27.1	29.4	32.6	34.8	34.9	35.5	33.6	30.5	26.0	23.7
		MCWB	18.1	18.1	18.6	20.1	22.1	23.8	24.8	24.8	23.8	21.8	19.5	19.4
	5%	DB	21.1	22.4	25.5	28.0	31.4	33.6	33.8	33.9	32.4	28.8	24.0	22.0
		MCWB	17.5	17.5	17.6	19.4	21.8	23.8	24.9	24.9	23.8	20.9	18.2	18.5
	10%	DB	18.9	20.9	23.6	26.9	30.1	32.3	32.6	32.7	31.1	27.3	22.5	19.9
		MCWB	16.0	16.5	16.9	18.8	21.4	23.6	24.8	24.9	23.5	20.1	17.7	17.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	21.1	21.5	23.3	24.6	26.4	27.3	27.3	26.1	24.9	23.0	22.1
		MCDB	23.1	24.7	24.7	27.6	30.3	32.0	32.4	32.6	31.3	28.7	25.0	24.1
	2%	WB	19.5	20.0	20.4	22.2	23.9	25.7	26.4	26.6	25.5	24.0	21.7	20.4
		MCDB	21.7	23.0	23.9	26.1	29.3	31.3	32.2	32.0	30.5	27.6	23.7	22.3
	5%	WB	18.2	18.8	19.4	21.3	23.3	25.2	25.9	26.1	25.0	23.1	20.2	19.1
		MCDB	20.2	21.5	23.1	25.2	28.4	30.7	31.4	31.4	29.9	26.6	23.0	21.1
	10%	WB	16.7	17.5	18.4	20.4	22.7	24.7	25.5	25.6	24.4	22.1	18.6	17.5
		MCDB	19.0	19.6	22.1	24.4	27.7	29.7	30.8	30.6	29.1	25.4	21.2	19.3
Mean Daily Temperature Range	5% DB	MDBR	12.7	13.0	13.8	14.0	13.3	11.5	11.0	11.0	11.6	13.6	14.1	12.4
		MCDBR	13.1	13.6	14.7	15.1	14.6	13.7	12.6	12.9	12.9	14.5	14.6	13.0
		MCWBR	8.8	8.1	7.3	6.8	5.5	4.5	4.4	4.5	4.9	6.7	8.5	9.1
	5% WB	MCDBR	10.6	11.0	11.3	11.2	11.6	11.0	10.9	10.9	10.5	10.7	11.2	10.9
		MCWBR	8.1	8.1	6.6	5.9	4.9	4.4	4.4	4.4	4.5	5.5	7.7	8.8
Clear-Sky Solar Irradiance	taub	0.324	0.340	0.362	0.389	0.435	0.465	0.528	0.510	0.440	0.375	0.347	0.329	
	taud	2.542	2.500	2.433	2.359	2.264	2.235	2.070	2.116	2.291	2.448	2.474	2.539	
	Ebn at Noon	906	921	920	902	859	828	776	785	831	869	868	880	
	Edh at Noon	85	97	111	124	137	141	165	156	126	101	90	81	
All-Sky Solar Radiation	RadAvg	2.90	3.47	4.68	5.74	6.29	6.11	5.89	5.51	5.02	4.34	3.30	2.53	
	RadStd	0.21	0.45	0.41	0.48	0.40	0.50	0.37	0.35	0.35	0.50	0.30	0.26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-168	+256	+140
(47)	Regional (44 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+150	+95

Nomenclature: See separate page