

AUBURN UNIVERSITY, AL, USA

WMO: 722284

Lat: 32.616N

Lon: 85.433W

Elev: 776

StdP: 14.29

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03892

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 23.2	(c) 27.5	(d) 5.5	(e) 7.5	(f) 31.1	(g) 9.8	(h) 9.3	(i) 33.5	(j) 20.6	(k) 46.8	(l) 18.9	(m) 45.1	(n) 8.5	(o) 340	(p) 0.377

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	93.4	73.7	91.3	74.1	90.1	73.9	77.8	88.0	77.0	86.9	76.1	85.4	7.2	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.1	135.4	81.7	73.6	128.8	80.3	73.1	126.6	79.9	41.6	88.8	40.7	86.6	40.0	84.6	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 17.9	(b) 15.9	(c) 13.3	(e) 15.8	(f) 95.8	(g) 4.5	(h) 4.0	(i) 12.6	(j) 98.7	(k) 10.0	(l) 101.0	(m) 7.5	(n) 103.3	(o) 4.2	(p) 106.2		
(4) 17.9	(5) 15.9	(6) 13.3	(7) 14.0	(8) 79.0	(9) 4.1	(10) 1.3	(11) 11.0	(12) 79.9	(13) 8.6	(14) 80.6	(15) 6.2	(16) 81.3	(17) 3.2	(18) 82.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.1	46.3	50.1	56.3	63.3	71.5	77.4	80.0	79.4	74.6	65.2	55.2	48.6		
	DBStd	13.94	10.21	9.39	8.58	6.80	5.69	4.00	3.34	3.65	5.04	7.23	8.08	9.09		
	HDD50	527	196	106	41	3	0	0	0	0	0	2	40	139		
	HDD65	2322	582	420	286	110	17	0	0	0	4	89	303	511		
	CDD50	5660	80	110	237	401	666	823	928	911	738	473	197	96		
	CDD65	1978	1	4	16	57	218	373	463	446	292	95	10	3		
	CDH74	16409	1	10	107	426	1736	3220	4234	3911	2145	574	42	3		
	CDH80	6287	0	0	10	52	535	1326	1865	1656	739	101	3	0		
	WSAvg	6.4	7.3	7.5	7.6	6.8	6.1	5.4	5.3	5.1	5.8	6.2	6.5	7.1		
	PrecAvg	51.9	4.7	4.7	6.2	4.0	3.7	4.3	5.0	4.1	3.5	3.1	4.0	4.3		
(15) Precipitation	PrecMax	75.9	8.6	7.7	14.1	7.3	9.6	10.2	11.0	9.5	8.7	10.5	10.2	11.9		
	PrecMin	37.4	2.4	1.7	1.0	1.9	0.3	1.5	2.2	1.7	0.6	0.2	1.4	1.8		
	PrecStd	9.3	1.7	1.5	2.9	1.7	2.3	2.4	2.3	1.8	1.9	2.5	2.0	2.1		
	PrecStd	9.3	1.7	1.5	2.9	1.7	2.3	2.4	2.3	1.8	1.9	2.5	2.0	2.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.7	75.4	81.3	84.0	90.8	95.3	97.2	98.6	92.9	85.7	79.1	73.3		
		MCWB	62.7	62.7	63.7	67.5	71.3	72.5	74.3	75.0	71.1	71.1	65.3	63.7		
	2%	DB	68.3	71.8	77.0	81.5	88.2	92.1	93.4	93.2	90.3	82.3	74.4	69.7		
		MCWB	60.3	61.3	62.0	65.4	70.7	73.3	74.4	74.8	71.8	68.2	62.3	63.0		
	5%	DB	64.3	67.9	73.3	79.2	85.5	90.3	91.1	90.8	87.8	80.7	72.0	66.0		
		MCWB	58.7	59.3	59.6	64.0	69.8	73.4	75.0	74.9	72.0	67.0	61.2	61.4		
	10%	DB	62.5	64.3	70.4	75.8	82.4	88.0	89.8	88.4	84.1	77.1	68.4	63.3		
		MCWB	57.1	56.9	58.4	62.4	68.3	73.0	74.8	74.4	71.4	65.4	60.7	58.5		
	0.4%	WB	65.2	67.0	67.5	71.3	75.0	78.3	79.0	79.2	76.5	74.7	70.1	67.7		
		MCDB	68.5	71.8	74.9	78.6	83.0	87.8	88.5	89.7	85.2	81.5	72.4	69.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	63.0	64.4	65.4	68.8	73.3	77.0	77.8	77.9	75.4	72.6	67.1	65.0		
		MCDB	66.1	68.4	71.8	76.5	82.5	86.7	88.1	88.2	83.4	78.1	70.9	67.3		
	5%	WB	60.6	62.1	63.3	67.1	72.0	75.8	76.9	76.9	74.3	70.5	64.4	62.4		
		MCDB	64.0	66.0	70.2	74.9	81.2	85.1	87.1	86.6	81.8	75.7	68.6	64.9		
	10%	WB	58.0	59.4	61.0	65.4	70.8	74.7	76.0	75.9	73.2	68.5	61.7	59.5		
		MCDB	61.7	64.0	67.8	73.0	79.6	83.5	85.5	84.8	80.2	74.0	66.5	63.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.3	19.0	20.3	20.7	19.5	17.8	17.6	17.1	17.4	19.3	19.7	17.4		
		MCDBR	18.5	20.0	22.9	22.5	21.5	21.1	20.3	20.3	20.7	20.8	21.0	18.1		
		MCWBR	12.9	12.6	12.0	10.4	8.1	7.5	6.4	6.7	7.5	9.3	12.1	13.0		
		MCDBR	15.6	16.9	18.5	18.0	17.9	17.6	17.8	17.4	15.8	15.3	16.4	15.6		
	5% WB	MCWBR	13.0	13.3	12.1	10.1	8.1	7.6	6.7	6.6	7.1	8.9	12.1	13.3		
		MCWBR	13.0	13.3	12.1	10.1	8.1	7.6	6.7	6.6	7.1	8.9	12.1	13.3		
(40) Clear-Sky Solar Irradiance	taub		0.317	0.320	0.349	0.380	0.433	0.473	0.512	0.512	0.417	0.365	0.341	0.321		
	taud		2.531	2.520	2.455	2.354	2.248	2.189	2.091	2.083	2.337	2.464	2.476	2.531		
	Ebn at Noon		288	298	295	288	273	260	250	248	269	278	275	279		
	Edh at Noon		27	30	34	39	44	47	51	51	38	31	28	25		
(44) All-Sky Solar Radiation	RadAvg		887	1066	1423	1785	1971	1948	1912	1744	1535	1309	995	758		
	RadStd		54	128	122	125	154	152	129	102	134	167	93	83		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (45 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+281	+191

Nomenclature: See separate page