

PLATTSMOUTH, NE, USA

WMO: 722291

Lat: 40.948N

Lon: 95.917W

Elev: 367

StdP: 96.99

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 00470

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.1	-16.1	-23.0	0.5	-16.7	-21.2	0.6	-14.8	13.8	-2.9	12.4	-3.8	3.9	320	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	34.0	24.0	32.6	23.9	31.2	23.3	26.5	31.4	25.3	30.2	24.4	29.4	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	21.0	30.1	23.8	19.5	28.6	22.8	18.3	27.5	84.7	31.2	79.7	30.5	75.6	29.6	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.1	8.7	DB	-22.8	36.5	2.5	1.3	-24.6	37.4	-26.0	38.2	-27.4	38.9	-29.2	39.8	(4)
(5)			WB	-23.2	27.9	2.4	0.9	-24.9	28.5	-26.3	29.0	-27.7	29.5	-29.4	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-4.0	-2.6	5.5	11.3	17.8	23.2	24.8	23.4	19.8	12.5	5.2	-1.6	(6)	
	DBStd	11.48	6.56	6.84	6.81	5.74	4.92	3.30	3.09	2.97	4.33	5.06	5.87	5.95	(7)	
	HDD10.0	1574	433	356	173	53	4	0	0	0	1	32	162	360	(8)	
	HDD18.3	3213	692	587	401	219	72	3	1	2	34	191	394	618	(9)	
	CDD10.0	2062	0	2	33	92	245	394	458	417	294	109	18	1	(10)	
	CDD18.3	659	0	0	2	7	54	148	201	160	78	9	0	0	(11)	
	CDH23.3	6057	0	0	29	97	498	1386	1967	1348	647	84	3	0	(12)	
	CDH26.7	2224	0	0	5	26	165	518	794	488	211	17	0	0	(13)	
(14) Wind	WSAvg	4.0	4.4	4.4	4.7	5.0	4.3	3.7	2.8	2.8	3.3	3.9	4.4	4.2	(14)	
(15) Precipitation	PrecAvg	811	21	27	47	83	130	118	114	81	71	59	40	24	(15)	
	PrecMax	1312	41	85	116	186	243	212	408	210	161	189	84	62	(16)	
	PrecMin	593	3	4	0	16	36	32	26	14	16	1	0	0	(17)	
	PrecStd	170	11	20	32	38	66	52	85	57	40	44	23	18	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.4	19.3	27.1	30.0	34.1	35.1	37.0	35.3	33.6	28.7	22.9	14.9	(19)	
		MCWB	6.5	10.5	16.2	17.7	20.4	23.8	23.4	24.3	22.8	19.9	13.3	9.0	(20)	
	2%	DB	10.0	13.7	22.8	26.2	30.6	32.9	34.1	32.8	31.3	25.9	19.8	11.7	(21)	
		MCWB	5.7	8.5	12.9	15.4	19.3	23.9	24.9	24.2	22.6	16.7	12.9	7.6	(22)	
	5%	DB	7.2	10.1	19.4	22.9	28.0	31.4	32.6	31.3	29.2	23.0	16.6	9.0	(23)	
		MCWB	3.7	5.7	11.9	13.9	18.3	23.2	24.9	24.1	21.7	15.4	10.7	5.7	(24)	
	10%	DB	4.7	6.6	16.2	20.8	26.2	29.9	31.0	29.5	27.1	21.1	13.8	6.8	(25)	
		MCWB	2.5	3.6	10.4	12.9	17.7	22.2	24.0	23.0	20.3	14.2	8.8	4.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	12.1	17.6	18.6	23.0	27.2	28.0	27.4	25.0	21.9	15.7	11.7	(27)	
		MCDB	11.8	15.3	22.3	26.7	28.3	32.4	32.9	32.5	30.6	26.4	19.9	12.7	(28)	
	2%	WB	5.6	8.1	15.3	16.9	21.5	25.5	26.7	25.9	23.9	19.2	13.4	8.0	(29)	
		MCDB	9.3	13.7	20.1	23.4	27.5	30.8	31.8	30.5	29.1	23.0	17.9	10.2	(30)	
	5%	WB	4.0	5.7	12.8	15.6	20.2	24.3	25.5	24.9	23.0	17.1	11.2	5.9	(31)	
		MCDB	6.8	9.7	17.8	21.2	26.1	29.9	30.4	29.5	27.1	21.1	16.1	8.9	(32)	
	10%	WB	2.4	3.7	10.3	14.2	19.1	23.4	24.5	23.8	21.9	15.4	9.2	4.0	(33)	
		MCDB	4.8	6.6	16.5	19.2	24.4	28.4	29.4	28.3	25.8	19.6	13.7	6.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	9.5	11.2	11.5	10.8	10.3	10.1	10.2	11.3	11.2	10.5	8.7	(35)	
		MCDBR	12.7	13.9	16.5	15.5	13.4	11.7	11.3	12.0	12.9	14.4	14.4	12.6	(36)	
	5% WB	MCWBR	8.8	8.9	8.6	7.7	5.5	5.4	5.2	5.5	5.7	7.2	7.9	8.9	(37)	
		MCWBR	11.6	12.9	13.9	13.3	11.4	10.7	10.1	10.4	10.8	11.5	13.2	11.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.278	0.314	0.325	0.380	0.407	0.412	0.422	0.414	0.373	0.331	0.297	0.282	(40)	
		taud	2.471	2.383	2.413	2.277	2.270	2.308	2.276	2.308	2.378	2.485	2.506	2.467	(41)	
	Ebn at Noon		891	897	927	891	871	864	851	848	863	869	859	853	(42)	
		Edh at Noon	75	96	105	129	133	128	131	124	108	86	73	70	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.06	2.97	3.86	4.91	5.82	6.47	6.50	5.65	4.66	3.28	2.29	1.73	(44)	
	RadStd		0.17	0.18	0.35	0.33	0.46	0.49	0.43	0.33	0.31	0.38	0.17	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page