

NEW ORLEANS INTL, LA, USA

WMO: 722310

Lat: 29.997N

Lon: 90.278W

Elev: 4

StdP: 14.69

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12916

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.1	36.6	17.2	13.1	37.9	21.7	16.3	42.3	24.2	54.0	21.4	51.6	9.1	0	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.0	94.4	77.8	92.8	77.7	91.2	77.5	80.9	88.9	80.2	88.1	79.6	87.2	7.4	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	149.8	84.4	78.1	146.1	84.0	77.4	142.5	83.5	44.3	89.1	43.6	88.1	42.9	87.2	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.9	18.7	16.9	DB	27.9	97.0	4.3	2.0	24.8	98.4	22.3	99.6	19.9	100.7	16.8	102.2	(4)
			WB	24.4	82.4	3.8	1.2	21.7	83.2	19.5	83.9	17.4	84.5	14.6	85.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	70.3	54.0	57.8	63.5	69.9	77.1	82.0	83.4	83.7	80.6	72.3	62.6	56.5	(6)
(7)		DBStd	12.55	9.71	9.28	7.83	6.05	4.44	2.93	2.49	2.66	3.88	6.78	7.75	9.19	(7)
(8)		HDD50	149	70	30	6	0	0	0	0	0	0	0	5	38	(8)
(9)		HDD65	1193	359	234	123	26	1	0	0	0	0	19	136	295	(9)
(10)		CDD50	7574	193	249	424	596	841	959	1036	1044	919	692	382	239	(10)
(11)		CDD65	3143	17	33	76	172	377	509	571	579	470	246	63	30	(11)
(12)		CDH74	30203	38	100	312	1044	3245	5459	6421	6641	4740	1820	288	95	(12)
(13)		CDH80	11084	0	5	20	176	1052	2191	2657	2807	1702	441	30	3	(13)
(14)	Wind	WSAvg	7.9	9.1	9.2	9.0	9.3	8.0	6.6	5.9	5.9	6.9	7.8	8.1	8.6	(14)
(15)	Precipitation	PrecAvg	64.2	5.4	4.4	5.0	5.0	5.4	7.1	6.9	6.3	6.0	3.8	3.9	5.1	(15)
(16)		PrecMax	98.8	18.7	10.7	9.9	15.3	15.9	19.9	11.2	15.2	21.5	12.8	13.7	24.2	(16)
(17)		PrecMin	46.8	0.2	0.8	0.6	0.1	0.5	2.4	3.0	1.6	0.9	0.3	0.4	1.3	(17)
(18)		PrecStd	11.7	4.1	2.8	2.4	3.9	4.0	3.9	2.1	3.3	4.3	3.1	3.1	4.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.6	80.6	82.2	86.3	91.8	95.2	96.3	96.3	95.2	89.8	83.3	80.0	(19)
(20)		MCWB	69.1	71.2	70.5	72.4	75.0	76.4	78.5	78.3	77.1	75.6	72.2	71.5	(20)	
(21)		2%	DB	74.7	77.1	80.0	84.1	89.4	92.9	94.0	94.2	91.8	87.0	80.2	76.8	(21)
(22)		MCWB	67.5	69.2	69.3	71.9	74.6	76.9	78.3	78.3	76.7	74.3	71.1	69.9	(22)	
(23)		5%	DB	71.8	74.3	77.8	82.1	87.6	91.1	92.1	92.4	89.9	84.6	77.4	73.5	(23)
(24)		MCWB	65.8	67.5	68.5	71.0	74.3	76.8	78.2	78.3	76.2	73.4	69.3	68.5	(24)	
(25)		10%	DB	68.9	71.6	75.1	80.0	85.8	89.3	90.3	90.6	88.0	82.4	74.7	70.6	(25)
(26)		MCWB	64.5	66.3	67.3	69.7	73.5	76.6	78.0	78.2	75.9	72.6	68.0	66.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.2	73.4	73.4	76.2	78.9	80.7	82.0	82.3	80.5	79.5	75.6	73.4	(27)
(28)		MCDWB	74.8	76.9	77.9	82.1	86.8	89.1	90.4	90.1	87.9	84.4	78.8	77.1	(28)	
(29)		2%	WB	69.4	71.3	71.9	74.7	77.4	79.9	80.5	81.1	79.7	77.9	73.4	71.6	(29)
(30)		MCDWB	72.9	75.0	76.7	80.3	85.0	87.9	88.8	89.1	86.9	82.7	77.2	74.7	(30)	
(31)		5%	WB	67.5	69.4	70.5	73.4	76.4	79.0	79.9	80.3	78.8	76.6	71.4	69.7	(31)
(32)		MCDWB	70.7	73.0	75.4	78.8	83.6	86.8	88.3	88.0	85.5	81.4	75.9	72.8	(32)	
(33)		10%	WB	65.0	67.3	69.0	72.4	75.4	78.2	79.2	79.7	78.0	75.3	69.4	67.3	(33)
(34)		MCDWB	68.2	70.7	73.8	77.7	82.3	85.8	87.2	87.2	84.5	80.2	73.8	70.2	(34)	
(35)	Mean Daily Temperature Range	MDBR	16.5	16.4	16.6	16.4	15.6	14.5	14.1	14.0	14.0	15.6	16.9	16.0	(35)	
(36)		5% DB	MCDBR	17.8	16.8	16.5	16.5	16.5	16.3	16.2	16.1	15.9	16.0	17.4	17.3	(36)
(37)		MCWBR	12.1	10.5	8.5	7.8	6.1	5.5	5.4	5.6	5.7	6.9	10.0	11.7	(37)	
(38)		5% WB	MCDBR	15.4	15.3	14.7	14.6	14.9	14.3	14.6	14.3	13.6	12.9	15.9	16.1	(38)
(39)		MCWBR	12.0	11.5	9.7	8.8	6.3	5.9	5.9	5.8	5.8	7.1	11.5	12.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.339	0.361	0.375	0.420	0.446	0.468	0.513	0.507	0.450	0.385	0.360	0.347	(40)	
(41)		taud	2.530	2.481	2.426	2.305	2.268	2.250	2.154	2.165	2.295	2.464	2.474	2.523	(41)	
(42)		Ebn at Noon	284	287	289	278	270	262	250	251	262	275	273	275	(42)	
(43)		Edh at Noon	28	32	36	42	43	44	49	47	40	32	29	27	(43)	
(44)	All-Sky Solar Radiation	RadAvg	950	1123	1510	1837	2011	1913	1809	1709	1619	1435	1092	849	(44)	
(45)		RadStd	81	150	131	153	109	160	134	147	128	156	100	78	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.99	N/A	N/A	N/A	N/A	N/A	N/A	-126	+333	+241	(46)
(47)	Regional (23 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+254	+173	(47)

Nomenclature: See separate page