

HAMMOND, LA, USA

WMO: 722312

Lat: 30.521N

Lon: 90.418W

Elev: 44

StdP: 14.67

Time Zone: -6.00 (NAC)

Period: 02-19

WBAN: 03908

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.0	31.6	15.8	12.2	44.1	20.6	15.5	43.4	20.2	51.7	18.6	52.8	2.6	10	0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.4	97.4	79.1	96.5	78.4	93.3	77.3	83.3	92.0	82.1	90.0	81.0	88.5	5.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.4	163.4	86.9	80.7	159.5	86.3	79.1	151.2	84.8	47.1	91.7	45.6	91.4	44.4	86.8	93.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	16.1	13.3	DB	23.5	99.4	4.1	3.2	20.5	101.7	18.1	103.5	15.8	105.3	12.8	107.6	
			WB	21.8	82.5	4.0	2.5	18.9	84.3	16.6	85.8	14.4	87.2	11.5	89.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	51.0	56.4	62.6	68.0	75.6	81.9	83.2	83.6	80.1	70.7	59.8	53.9
	DBStd	13.49	9.85	9.38	8.30	6.51	5.52	3.26	2.83	3.35	4.02	7.67	8.71	9.42
	HDD50	235	108	37	8	1	0	0	0	0	0	0	16	65
	HDD65	1511	446	269	146	44	4	0	0	0	0	36	201	365
	CDD50	7154	138	215	399	541	793	956	1028	1043	902	643	311	185
	CDD65	2955	11	27	72	134	332	506	563	578	452	214	46	20
	CDH74	29547	39	129	485	1271	3300	5414	5953	6237	4331	1989	321	78
	CDH80	13041	1	11	71	288	1325	2662	2875	3086	1960	709	50	3
Wind	WSAvg	4.4	5.1	5.8	5.7	6.1	4.7	3.5	3.0	3.1	3.3	4.0	4.4	5.0
Precipitation	PrecAvg	62.8	5.8	5.1	5.6	5.1	5.2	5.9	6.4	5.6	4.3	4.4	4.1	5.2
	PrecMax	80.8	15.5	10.2	11.7	9.9	12.9	12.2	15.0	13.0	11.9	10.7	10.5	14.7
	PrecMin	43.5	0.6	0.8	0.7	0.4	0.4	1.5	3.0	2.0	0.7	0.0	0.8	1.7
	PrecStd	10.7	3.5	2.8	2.8	2.8	3.8	2.9	2.4	2.7	2.9	3.0	2.7	2.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.9	81.6	84.2	88.2	94.8	99.6	99.2	99.7	97.3	91.5	84.3	79.4
		MCWB	68.4	69.4	68.7	70.5	75.6	77.6	78.3	79.4	78.8	74.2	71.1	69.8
	2%	DB	73.3	78.6	81.9	85.6	91.2	96.9	96.9	97.4	94.6	90.3	81.3	76.6
		MCWB	65.7	67.4	67.9	71.1	75.6	77.5	78.5	80.3	76.8	73.5	69.2	68.9
	5%	DB	71.8	74.5	79.3	82.5	90.1	93.5	94.7	96.6	91.4	87.7	77.4	72.7
		MCWB	65.1	65.7	66.7	69.5	75.0	76.2	77.8	79.3	76.3	72.5	68.5	67.1
	10%	DB	67.7	71.9	76.8	81.4	87.8	91.2	91.4	92.9	90.4	83.9	74.7	69.8
		MCWB	62.6	65.7	66.0	68.6	73.6	76.8	78.2	78.6	75.9	71.3	66.2	64.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.3	72.3	73.5	77.0	80.3	83.9	83.7	85.8	83.1	81.1	75.8	73.0
		MCDB	75.0	77.9	78.8	81.4	88.1	93.0	92.9	95.5	91.7	87.1	80.3	76.5
	2%	WB	69.5	70.3	71.7	74.8	78.4	82.1	82.4	83.9	81.3	78.4	73.1	70.6
		MCDB	72.3	74.5	77.7	81.1	86.3	90.5	91.1	92.6	88.4	84.0	77.8	74.4
	5%	WB	66.3	69.0	70.2	73.3	77.2	80.5	81.3	82.3	79.7	76.5	70.8	68.5
		MCDB	70.1	72.7	75.5	79.0	85.7	88.5	89.3	90.1	86.5	82.4	75.5	72.0
	10%	WB	63.4	66.5	68.6	71.8	76.0	78.9	80.0	81.0	78.3	74.7	68.7	65.8
		MCDB	66.0	70.7	73.8	78.1	83.6	87.0	87.5	88.2	85.4	80.7	73.2	68.8
Mean Daily Temperature Range	5% DB	MDBR	21.4	20.8	22.7	23.4	21.7	20.0	19.0	19.4	20.1	23.9	24.1	21.0
		MCDBR	22.1	21.1	22.5	23.7	22.9	22.9	21.5	21.9	21.6	24.6	24.2	21.7
		MCWBR	15.0	12.5	11.1	11.3	8.7	7.3	7.0	7.6	8.1	10.2	14.2	14.8
	5% WB	MCDBR	18.7	17.5	18.3	18.8	19.4	19.6	18.3	19.0	17.9	17.4	18.8	18.3
		MCWBR	14.6	12.6	11.1	11.4	8.2	8.2	7.8	7.9	7.5	9.0	13.1	14.0
Clear-Sky Solar Irradiance	taub		0.332	0.357	0.372	0.412	0.440	0.469	0.512	0.505	0.449	0.380	0.353	0.341
	taud		2.526	2.457	2.410	2.304	2.262	2.226	2.136	2.152	2.278	2.448	2.469	2.513
	Ebn at Noon		286	287	289	280	272	262	250	251	262	275	275	276
	Edh at Noon		28	32	36	42	44	45	49	48	41	32	29	27
All-Sky Solar Radiation	RadAvg		921	1086	1455	1798	1963	1900	1837	1735	1608	1406	1062	822
	RadStd		83	154	127	144	118	164	135	140	127	167	98	81

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+254	+173

Nomenclature: See separate page