

NEW ORLEANS NAS, LA, USA

WMO: 722316

Lat: 29.817N

Lon: 90.017W

Elev: 2

StdP: 14.69

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12958

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.6	34.2	16.5	12.7	39.4	21.2	15.9	41.3	21.0	69.2	19.4	66.6	4.3	10	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.4	93.2	77.7	91.8	77.6	90.4	77.4	81.6	87.2	80.6	86.5	79.9	86.1	6.4	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.2	156.7	83.8	79.1	151.2	83.4	78.2	146.5	82.8	45.1	87.2	44.1	86.6	43.2	85.8	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.9	16.7	14.7	25.5	96.4	3.9	2.0	22.7	97.8	20.4	99.0	18.2	100.1	15.4	101.6		
			23.3	83.6	3.7	2.2	20.7	85.2	18.5	86.4	16.5	87.7	13.8	89.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.1	53.0	57.3	62.4	68.2	75.7	80.7	82.0	82.4	79.2	70.5	60.9	56.3
	DBStd	12.40	9.75	9.78	8.20	6.33	4.21	2.89	2.17	2.44	3.62	6.81	7.91	9.53
	HDD50	183	80	39	10	0	0	0	0	0	0	0	8	46
	HDD65	1322	388	249	146	41	1	0	0	0	0	29	169	299
	CDD50	7157	173	242	395	547	795	921	991	1004	875	636	336	242
	CDD65	2820	15	32	66	138	331	471	526	539	425	200	47	30
	CDH74	25583	30	91	273	843	2856	4835	5389	5551	3869	1526	229	91
	CDH80	9268	0	2	11	108	860	2006	2207	2303	1396	355	19	1
Wind	WSAvg	5.9	7.0	7.4	7.2	7.3	6.1	4.9	4.1	3.9	4.8	5.7	6.0	6.6
Precipitation	PrecAvg	61.7	5.4	5.0	5.1	5.4	4.9	5.6	6.3	6.0	6.4	3.4	4.2	4.7
	PrecMax	101.5	17.7	14.5	10.3	22.8	13.1	20.5	10.5	15.0	16.7	11.3	22.2	16.2
	PrecMin	36.7	0.9	0.4	0.7	0.2	0.2	0.4	2.4	1.7	1.2	0.0	0.3	1.5
	PrecStd	14.4	3.7	3.1	2.3	5.5	3.3	4.4	2.3	2.7	4.0	2.5	3.9	2.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	79.7	81.4	85.0	90.9	94.1	94.4	95.8	93.5	89.3	82.2	79.3
		MCWB	69.2	70.8	70.0	71.3	74.3	76.2	78.4	77.6	78.0	76.7	73.0	71.6
	2%	DB	74.3	76.9	79.3	82.9	88.3	92.0	92.6	93.3	90.7	86.1	79.3	76.9
		MCWB	67.6	69.6	69.1	71.6	74.5	76.9	78.0	78.1	77.0	74.0	70.9	70.0
	5%	DB	72.0	74.3	77.4	81.1	86.6	90.5	91.1	91.6	89.1	83.8	76.6	74.0
		MCWB	66.3	68.2	68.8	70.9	74.3	76.9	77.9	78.2	76.4	72.7	68.9	69.2
	10%	DB	68.8	71.9	74.8	79.0	84.8	89.0	89.6	90.0	87.4	81.7	74.0	71.2
		MCWB	64.4	67.0	67.7	69.5	73.7	76.7	77.9	78.1	76.1	71.7	67.4	67.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.9	74.4	74.2	75.9	79.4	82.0	83.1	82.7	81.9	79.3	76.1	74.4
		MCDB	74.6	77.1	77.9	80.3	85.8	87.8	87.7	88.3	86.6	85.1	79.5	77.0
	2%	WB	69.6	72.1	72.2	74.6	77.9	80.5	81.4	81.6	80.3	77.6	73.3	72.1
		MCDB	73.0	74.5	75.7	79.2	83.8	86.5	86.7	87.8	85.4	82.9	77.0	74.7
	5%	WB	67.6	70.1	70.7	73.3	76.7	79.6	80.3	80.5	79.1	76.1	71.2	70.0
		MCDB	70.8	73.0	74.8	78.1	82.7	85.9	86.2	86.9	84.7	80.7	74.6	72.9
	10%	WB	65.0	67.7	69.1	72.0	75.6	78.4	79.4	79.7	78.1	74.8	68.8	67.8
		MCDB	68.0	71.3	73.9	76.8	81.9	85.3	85.8	86.2	83.9	79.3	73.0	70.7
Mean Daily Temperature Range	5% DB	MDBR	18.2	18.1	18.1	17.7	17.1	16.1	15.4	15.4	15.7	18.2	19.8	17.7
		MCDBR	18.6	17.0	17.4	17.2	18.0	17.7	17.3	17.3	17.5	18.4	19.5	17.6
		MCWBR	13.1	11.0	9.8	8.8	7.3	6.3	6.4	6.1	6.8	9.0	12.7	12.3
	5% WB	MCDBR	15.2	14.7	15.1	14.2	15.4	15.6	15.3	15.1	14.8	14.2	17.2	16.2
		MCWBR	12.5	11.2	10.7	9.1	7.5	7.1	7.4	6.7	6.8	8.6	13.5	13.1
Clear-Sky Solar Irradiance	taub	0.342	0.360	0.376	0.420	0.446	0.465	0.508	0.503	0.448	0.387	0.362	0.348	
	taud	2.535	2.498	2.438	2.320	2.283	2.270	2.179	2.190	2.309	2.471	2.481	2.529	
	Ebn at Noon	284	287	289	278	270	263	252	252	263	274	273	275	
	Edh at Noon	28	31	35	41	43	43	47	46	40	32	29	27	
All-Sky Solar Radiation	RadAvg	958	1136	1531	1849	2026	1930	1803	1701	1622	1441	1099	857	
	RadStd	79	147	131	157	104	152	132	143	124	149	99	75	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+245	+160

Nomenclature: See separate page