

DERIDDER BEAUREGARD, LA, USA

WMO: 722334

Lat: 30.833N

Lon: 93.333W

Elev: 204

StdP: 14.59

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 03976

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.4	31.6	15.3	12.0	39.2	20.5	15.5	41.3	19.7	61.5	18.0	59.0	3.5	0	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.3	95.8	76.5	94.2	76.1	91.7	75.9	81.2	86.5	80.3	85.8	79.3	85.1	5.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.8	156.1	82.5	79.1	152.0	82.2	77.9	146.2	81.7	44.7	86.2	44.0	87.5	43.0	85.1	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.9	15.7	12.8	DB	23.0	98.4	4.5	3.3	19.7	100.8	17.1	102.7	14.6	104.6	11.3	107.1	(4)
			WB	21.3	81.6	3.9	2.2	18.5	83.2	16.2	84.4	14.0	85.6	11.1	87.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	49.8	54.0	60.3	66.9	74.2	80.6	81.8	82.2	78.1	68.6	58.8	52.5	(6)
		DBStd	13.65	9.42	10.00	8.89	6.80	5.65	3.47	3.12	3.09	4.45	7.89	9.20	9.53	(7)
		HDD50	315	119	66	21	1	0	0	0	0	1	25	82		(8)
		HDD65	1757	478	326	197	59	9	0	0	0	55	228	405		(9)
		CDD50	6667	113	178	339	507	752	919	986	1000	844	579	289	161	(10)
		CDD65	2636	7	19	51	115	296	469	521	535	394	168	42	19	(11)
		CDH74	24367	9	67	245	804	2456	4747	5338	5530	3442	1449	225	55	(12)
		CDH80	10170	0	5	21	129	854	2198	2438	2612	1448	439	26	0	(13)
(14)	Wind	WSAvg	4.4	5.2	5.7	5.8	6.1	4.9	3.7	3.2	3.0	3.1	3.7	4.2	4.8	(14)
(15)	Precipitation	PrecAvg	60.1	5.7	4.4	4.6	4.8	4.7	4.9	4.8	3.9	4.9	5.0	5.4	5.8	(15)
(16)		PrecMax	80.0	12.8	11.1	8.2	10.7	11.5	12.4	9.3	6.3	13.2	20.2	13.7	11.9	(16)
(17)		PrecMin	44.3	0.9	0.8	1.5	0.6	0.0	1.2	1.5	0.3	1.3	0.0	0.6	2.6	(17)
(18)		PrecStd	10.3	3.3	2.8	1.9	2.6	3.0	2.8	2.1	1.5	2.5	5.0	3.5	2.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	75.3	80.5	82.3	86.4	91.3	98.6	97.4	99.3	95.4	90.3	83.6	78.8		(19)
(20)		0.4% MCWB	64.5	65.8	66.6	70.3	73.6	77.2	77.5	74.3	73.6	72.6	72.0	70.3		(20)
(21)		2% DB	72.2	76.1	79.4	83.2	89.7	95.0	95.2	95.8	92.7	87.8	79.5	75.2		(21)
(22)		2% MCWB	63.9	65.9	66.3	69.3	73.0	77.2	77.3	75.8	74.0	72.6	68.8	69.7		(22)
(23)		5% DB	69.4	72.6	77.0	81.3	87.6	91.8	93.0	93.7	90.4	85.3	76.8	72.1		(23)
(24)		5% MCWB	63.8	66.2	65.5	68.0	72.7	76.7	76.6	75.7	74.7	71.6	68.4	68.3		(24)
(25)		10% DB	65.9	70.0	73.4	79.1	85.6	90.4	90.9	91.2	88.2	81.9	73.2	69.5		(25)
(26)		10% MCWB	60.8	64.9	64.6	66.9	71.9	76.2	76.8	75.8	74.6	69.5	66.8	66.0		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	69.7	71.6	72.2	75.8	77.4	81.3	81.5	82.6	81.2	79.4	74.5	73.4		(27)
(28)		0.4% MCDB	71.8	73.6	75.2	80.2	82.2	87.7	86.5	88.1	84.3	82.2	77.7	75.4		(28)
(29)		2% WB	67.3	70.0	70.4	73.6	76.2	80.3	80.8	81.4	79.2	77.5	72.7	71.0		(29)
(30)		2% MCDB	70.1	72.6	74.5	78.2	82.7	87.0	86.1	86.9	83.5	81.5	76.6	73.8		(30)
(31)		5% WB	64.8	68.0	68.9	72.3	75.2	79.3	79.9	80.5	78.0	75.6	70.7	69.1		(31)
(32)		5% MCDB	67.6	71.4	73.7	77.1	82.5	86.3	85.6	85.7	83.5	81.2	75.1	71.6		(32)
(33)		10% WB	62.2	65.4	67.4	70.9	74.2	78.4	79.0	79.2	76.9	73.6	68.4	66.2		(33)
(34)		10% MCDB	64.8	69.8	72.2	75.8	81.1	85.5	85.2	84.4	83.1	78.8	72.5	68.9		(34)
(35)	Mean Daily Temperature Range	MDBR	19.7	19.3	20.2	20.6	19.5	18.9	17.5	18.3	18.8	22.3	20.8	18.5		(35)
(36)		5% DB MCDBR	21.0	19.9	20.1	20.9	20.3	21.0	20.2	21.1	20.7	21.9	20.9	18.8		(36)
(37)		5% DB MCWBR	14.2	12.1	10.1	9.3	7.3	6.8	6.0	5.9	7.0	9.3	12.3	13.0		(37)
(38)		5% WB MCDBR	17.2	17.1	16.2	16.6	17.5	18.5	17.6	16.8	16.6	17.4	17.7	17.0		(38)
(39)		5% WB MCWBR	14.3	13.4	10.6	10.3	7.3	7.2	6.8	6.9	7.3	10.1	12.7	13.7		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.350	0.372	0.413	0.447	0.498	0.494	0.486	0.447	0.374	0.361	0.345		(40)
(41)		taud	2.521	2.476	2.411	2.301	2.244	2.134	2.193	2.211	2.289	2.469	2.454	2.485		(41)
(42)		Ebn at Noon	285	289	289	279	269	254	255	256	262	277	271	273		(42)
(43)		Edh at Noon	28	32	36	42	44	49	46	45	40	31	30	28		(43)
(44)	All-Sky Solar Radiation	RadAvg	887	999	1392	1695	1880	1898	1878	1784	1577	1351	1014	778		(44)
(45)		RadStd	84	169	120	122	130	149	146	165	148	182	102	88		(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (25 neighbors)	+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+198	+142	(47)

Nomenclature: See separate page