

BOOTHVILLE, LA, USA

WMO: 722336

Lat: 29.333N

Lon: 89.408W

Elev: 0

StdP: 101.32

Time Zone: -6.00 (NAC)

Period: 00-19

WBAN: 12884

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.0	2.7	-7.0	2.1	5.3	-3.9	2.7	6.6	10.5	12.2	9.2	12.0	2.5	0	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	33.9	25.1	32.8	25.2	32.2	25.3	27.3	30.6	26.9	30.1	26.6	29.9	2.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.8	28.7	26.1	21.5	28.7	25.8	21.0	28.6	85.9	30.7	84.1	30.2	82.6	29.6	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.7	7.7	7.0	-0.9	34.6	2.8	2.0	-2.9	36.0	-4.6	37.2	-6.2	38.3	-8.3	39.7		
			-2.5	28.0	2.7	0.5	-4.4	28.4	-6.0	28.7	-7.5	29.0	-9.4	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.2	12.3	13.7	17.1	20.7	24.4	27.6	28.5	27.0	22.9	17.5	13.8	(6)	(7)
		DBStd	6.79	4.99	4.56	3.92	3.02	2.44	1.73	1.31	1.43	1.80	3.81	4.81		
		HDD10.0	73	34	16	3	0	0	0	0	0	0	2	19		
		HDD18.3	647	194	138	70	14	1	0	0	0	11	65	153		
		CDD10.0	4156	104	119	223	321	445	528	568	573	511	399	228		
		CDD18.3	1688	7	8	32	84	187	278	310	314	261	152	41		
		CDH23.3	16362	14	19	112	429	1462	3096	3603	3692	2656	1108	143		
(14)	Wind	CDH26.7	5609	0	1	6	52	354	1168	1429	1499	863	228	8	(14)	(15)
		WSAvg	3.1	3.5	3.5	3.5	3.5	3.1	2.8	2.5	2.6	2.7	3.1	3.1		
		PrecAvg	1472	120	98	130	114	98	135	177	162	159	92	86		
		PrecMax	2363	458	239	311	520	260	403	303	281	398	287	358		
		PrecMin	871	0	15	11	3	10	31	67	67	43	7	5		
		PrecStd	301	105	59	65	104	62	84	60	63	80	75	77		
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.1	25.6	27.4	29.8	32.5	35.3	34.2	36.1	33.8	32.1	27.6	(20)	(21)
			MCWB	20.4	20.2	19.9	20.0	22.9	23.7	25.4	26.0	24.8	24.0	22.1		
		2%	DB	22.9	23.6	26.0	27.9	31.1	33.6	33.0	33.8	32.5	30.2	26.3		
			MCWB	19.3	19.8	20.3	21.4	23.1	24.2	25.8	25.7	24.4	24.2	22.1		
		5%	DB	21.6	22.3	24.6	27.1	29.6	32.3	32.4	32.7	31.3	28.8	25.1		
			MCWB	18.8	19.4	20.5	21.5	23.8	24.8	25.8	25.9	24.8	24.0	21.5		
		10%	DB	19.8	21.0	23.0	26.0	28.6	31.3	31.6	31.8	30.5	27.8	23.7		
			MCWB	17.7	18.9	19.8	21.6	23.6	25.0	25.8	25.9	25.0	23.3	20.6		
		0.4%	WB	21.9	22.5	23.1	24.8	26.1	27.3	28.0	27.9	27.2	26.7	24.4		
			MCDB	23.4	24.1	25.1	26.7	28.4	30.5	31.4	31.7	30.2	28.4	26.2		
		2%	WB	20.8	21.2	22.3	24.0	25.5	26.8	27.3	27.3	26.7	25.8	23.2		
			MCDB	22.1	22.6	24.3	26.1	28.3	30.0	30.6	30.7	29.7	28.1	25.1		
(35)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	19.4	20.1	21.5	23.4	24.9	26.5	26.8	26.9	26.2	25.2	22.3	(35)	(36)
			MCDB	20.9	21.4	23.5	25.5	27.9	29.6	30.2	30.3	29.3	28.0	24.3		
		10%	WB	18.0	19.0	20.7	22.6	24.4	26.0	26.4	26.6	25.7	24.5	21.2		
			MCDB	19.3	20.4	22.6	24.8	27.4	29.3	29.9	30.0	28.9	27.3	23.2		
		5% DB	MDBR	8.5	8.6	8.6	8.3	7.4	6.9	6.4	6.4	6.6	7.6	8.3		
			MCDBR	10.0	9.6	9.5	9.7	9.1	9.3	7.8	8.3	8.3	7.8	8.6		
			MCWBR	7.1	6.7	5.6	4.8	3.6	3.2	3.0	3.0	3.3	3.8	5.4		
			MCWBR	8.7	8.0	7.8	6.8	6.1	5.9	6.1	6.2	5.9	5.9	7.0		
(40)	Clear-Sky Solar Irradiance	taub	0.348	0.364	0.378	0.416	0.440	0.458	0.489	0.488	0.445	0.393	0.366	0.355	(40)	(41)
		taud	2.536	2.506	2.449	2.338	2.312	2.309	2.246	2.250	2.331	2.474	2.491	2.527		
		Ebn at Noon	889	904	910	881	856	836	809	807	833	861	860	863		
		Edh at Noon	88	98	110	127	131	131	139	138	123	100	91	85		
(44)	All-Sky Solar Radiation	RadAvg	3.05	3.68	4.97	5.92	6.54	6.25	5.73	5.35	5.13	4.56	3.49	2.75	(44)	(45)
		RadStd	0.24	0.45	0.42	0.54	0.30	0.42	0.40	0.41	0.36	0.41	0.32	0.22		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (20 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+140	+94

Nomenclature: See separate page