

JACKSON INTL, MS, USA

WMO: 722350

Lat: 32.321N

Lon: 90.078W

Elev: 101

StdP: 100.12

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03940

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.8	(c) -2.9	(d) -11.8	(e) 1.4	(f) -0.7	(g) -9.3	(h) 1.7	(i) 0.9	(j) 9.3	(k) 11.8	(l) 8.5	(m) 11.2	(n) 2.0	(o) 340	(p) 0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.5	(c) 35.8	(d) 24.4	(e) 34.6	(f) 24.4	(g) 33.5	(h) 24.3	(i) 26.3	(j) 32.3	(k) 25.8	(l) 31.5	(m) 25.4	(n) 31.0	(o) 3.0	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 24.8	(b) 20.1	(c) 28.7	(d) 24.4	(e) 19.5	(f) 28.1	(g) 23.9	(h) 19.0	(i) 27.7	(j) 82.1	(k) 32.4	(l) 80.0	(m) 31.7	(n) 78.1	(o) 31.1	(p) 28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.2	(b) 7.3	(c) 6.2	(e) -8.0	(f) 37.2	(g) 2.2	(h) 1.9	(i) -9.6	(j) 38.6	(k) -10.9	(l) 39.7	(m) -12.2	(n) 40.7	(o) -13.8	(p) 42.1		
			DB													
			WB													
				-9.0	27.2	2.1	0.7	-10.5	27.6	-11.7	28.0	-12.9	28.4	-14.5	28.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	8.3	10.5	14.3	18.4	22.8	26.4	27.7	27.6	24.9	19.1	13.1	9.6		
	DBStd	8.16	5.99	5.73	5.11	4.06	3.20	2.10	1.71	1.93	2.97	4.42	4.87	5.65		
	HDD10.0	288	106	58	20	1	0	0	0	0	0	1	24	79		
	HDD18.3	1228	314	225	142	49	7	0	0	0	2	46	166	277		
	CDD10.0	3424	53	72	154	252	396	491	548	546	447	282	118	66		
	CDD18.3	1323	3	7	18	50	144	241	289	288	198	69	11	5		
	CDH23.3	12694	6	35	130	419	1261	2396	2972	2964	1814	612	68	18		
	CDH26.7	5506	0	2	14	81	444	1102	1424	1458	791	183	7	1		
(14) Wind	WSAvg	2.5	3.1	3.2	3.2	3.0	2.4	2.0	1.8	1.8	2.1	2.3	2.5	2.9		
(15) Precipitation	PrecAvg	1424	129	123	147	145	123	94	120	107	91	85	118	138		
	PrecMax	2356	358	267	384	405	275	215	337	292	323	249	254	450		
	PrecMin	884	19	33	23	31	7	2	26	7	1	0	13	23		
	PrecStd	269	71	64	74	100	72	54	67	66	64	68	62	65		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	26.9	28.3	30.2	33.3	36.2	36.8	38.0	35.7	32.5	27.8	25.7		
		MCWB	18.0	19.3	19.0	21.6	22.9	24.0	24.6	24.0	23.3	21.7	20.4	20.0		
	2%	DB	22.1	24.1	26.6	28.8	31.7	34.6	35.3	36.0	34.1	30.4	25.3	23.0		
		MCWB	17.3	17.7	18.4	20.3	22.7	24.0	24.9	24.5	23.4	21.5	19.0	18.8		
	5%	DB	20.1	22.0	24.8	27.5	30.6	33.3	34.1	34.6	32.7	28.7	23.4	21.0		
		MCWB	16.4	16.7	17.4	19.7	22.1	23.9	24.9	24.6	23.2	20.6	18.0	17.8		
	10%	DB	18.0	20.0	22.9	26.0	29.4	32.1	33.0	33.2	31.2	27.0	21.6	19.0		
		MCWB	15.1	15.9	16.7	18.8	21.5	23.8	24.8	24.6	22.8	19.8	17.2	16.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.9	20.7	21.1	23.4	25.0	26.2	27.1	26.9	25.8	24.7	22.1	21.1		
		MCDB	22.2	23.9	24.6	27.6	30.2	32.4	33.1	33.1	31.1	28.5	25.1	23.9		
	2%	WB	18.5	19.5	20.0	22.0	24.0	25.6	26.4	26.4	25.1	23.6	20.7	19.7		
		MCDB	21.0	22.7	23.6	26.3	29.0	31.6	32.2	32.4	30.2	27.4	23.4	22.4		
	5%	WB	17.4	18.3	19.1	21.2	23.4	25.1	25.8	25.8	24.6	22.6	19.5	18.4		
		MCDB	19.4	21.3	22.8	25.2	28.2	30.8	31.5	31.4	29.4	26.5	22.3	20.6		
	10%	WB	15.6	16.7	18.0	20.4	22.7	24.7	25.4	25.4	24.0	21.6	18.1	16.7		
		MCDB	17.9	19.6	21.8	24.2	27.4	30.0	31.1	30.7	28.6	25.1	20.7	18.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	11.6	12.1	12.3	11.4	10.8	10.5	10.9	11.5	12.7	12.5	11.1		
		MCDBR	12.1	13.0	13.3	12.7	12.1	12.1	11.8	12.8	13.0	13.6	13.6	12.2		
	5% WB	MCWBR	8.0	7.4	6.6	5.7	4.5	3.9	3.6	3.7	4.3	5.8	7.9	8.2		
		MCWBR	9.8	11.1	10.8	10.4	10.2	10.4	10.5	10.5	10.2	10.2	11.1	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.325	0.332	0.365	0.397	0.430	0.453	0.500	0.501	0.434	0.371	0.345	0.326		
		taud	2.515	2.495	2.410	2.317	2.275	2.244	2.145	2.138	2.307	2.449	2.472	2.523		
	Ebn at Noon		898	925	914	894	862	838	797	791	833	869	865	876		
		Edh at Noon	86	96	113	129	136	140	153	152	124	100	89	81		
(44) All-Sky Solar Radiation	RadAvg		2.72	3.21	4.41	5.52	6.09	6.37	6.08	5.69	5.04	4.21	3.11	2.38		
	RadStd		0.24	0.49	0.33	0.42	0.36	0.45	0.33	0.43	0.38	0.57	0.30	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144	+102
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+70

Nomenclature: See separate page