

NATCHEZ-ADAMS COUNTY AP, MS, USA

WMO: 722357

Lat: 31.617N

Lon: 91.300W

Elev: 272

StdP: 14.55

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03961

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.0	27.7	10.3	9.4	30.6	16.2	12.6	35.7	21.5	56.3	19.8	55.7	4.6	10	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	93.4	77.3	91.6	77.0	90.6	76.8	79.8	89.8	78.9	88.8	78.1	87.8	6.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	142.9	84.6	75.7	135.7	83.8	75.1	133.2	83.4	43.5	89.2	42.5	88.6	41.6	88.7	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.5	16.4	14.4	DB	18.7	96.0	4.4	2.9	15.6	98.1	13.0	99.8	10.5	101.5	7.4	103.6
			WB	17.2	81.1	4.0	1.2	14.3	82.0	11.9	82.7	9.6	83.3	6.7	84.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.6	47.9	52.4	58.4	65.2	73.1	78.9	81.0	80.7	76.0	66.3	56.4	50.5
	DBStd	14.10	10.93	10.50	9.26	7.41	5.77	3.50	3.06	4.27	5.37	8.02	9.17	10.40
	HDD50	470	174	90	33	2	0	0	0	1	0	2	42	126
	HDD65	2086	536	370	242	89	13	0	0	3	4	84	282	463
	CDD50	6173	111	156	292	457	715	866	960	953	779	508	235	141
	CDD65	2314	7	16	36	93	263	416	495	490	334	126	25	13
	CDH74	20846	13	65	199	700	2201	3905	4905	4827	2847	1025	124	35
	CDH80	8345	0	4	13	114	728	1639	2211	2224	1130	273	9	0
(14) Wind	WSAvg	6.0	7.5	7.7	7.6	7.2	6.0	5.0	4.4	4.1	4.5	5.1	6.1	7.0
(15) Precipitation	PrecAvg	56.1	5.7	5.3	5.5	4.5	4.4	4.3	4.3	4.6	3.9	3.6	4.9	4.9
	PrecMax	74.4	12.6	11.5	13.2	11.8	10.2	11.3	7.2	11.9	13.8	9.6	11.2	8.5
	PrecMin	39.8	1.3	0.8	0.7	0.4	0.2	0.8	1.0	1.5	0.6	0.0	0.4	2.0
	PrecStd	10.2	3.0	3.0	2.6	2.8	2.4	2.7	1.8	2.9	3.0	2.6	3.1	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.2	80.4	81.6	85.6	90.4	93.4	96.7	97.4	94.0	89.7	81.4	78.8
		MCWB	66.2	67.5	67.4	72.2	75.2	76.4	78.0	77.2	75.6	73.3	69.8	68.2
	2%	DB	72.3	75.3	79.2	82.5	88.4	91.4	93.2	93.5	91.1	85.8	78.5	73.4
		MCWB	63.8	64.6	65.8	69.6	74.2	76.4	77.7	77.6	75.4	72.7	67.6	66.5
	5%	DB	69.6	72.4	75.4	81.2	86.7	90.3	91.3	91.5	89.8	82.4	74.5	71.6
		MCWB	62.3	63.5	64.0	68.3	73.3	76.5	77.5	77.5	75.1	70.1	65.4	65.0
	10%	DB	65.6	69.7	72.9	78.9	84.1	88.4	90.3	90.4	87.5	80.8	72.0	67.8
		MCWB	60.7	62.3	62.8	66.5	72.1	75.9	77.4	77.4	74.4	68.6	64.2	62.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.8	69.6	70.5	74.5	77.4	79.6	81.1	81.2	78.5	77.1	72.6	70.7
		MCDB	73.8	76.2	77.8	82.6	87.4	89.8	90.6	90.9	88.0	85.1	78.0	75.4
	2%	WB	65.7	67.5	68.4	72.2	76.0	78.4	79.8	80.0	77.7	75.1	70.1	68.1
		MCDB	70.9	73.3	75.6	80.0	85.2	88.2	89.8	89.9	87.1	82.3	75.2	73.3
	5%	WB	63.3	65.4	66.8	70.6	74.9	77.7	78.9	79.0	76.6	73.4	67.7	65.8
		MCDB	66.6	70.7	73.7	78.1	83.5	87.2	88.8	88.9	85.7	79.6	73.7	70.6
	10%	WB	60.4	62.8	65.0	69.0	73.5	76.8	78.1	78.1	75.5	71.3	65.1	63.0
		MCDB	65.2	68.2	71.7	76.2	81.7	85.9	87.8	87.6	84.0	77.2	69.7	66.6
(35) Mean Daily Temperature Range	5% DB	MDBR	19.5	19.9	20.5	21.2	19.8	18.0	17.6	18.2	19.6	22.0	21.5	19.2
		MCDBR	19.2	20.6	21.5	21.1	20.6	19.4	19.0	19.9	21.4	22.3	22.4	19.8
		MCWBR	13.5	12.7	12.3	11.3	9.3	8.4	7.8	8.0	8.7	11.3	13.9	13.7
	5% WB	MCDBR	17.4	18.6	18.6	17.8	17.9	17.4	17.4	17.8	17.9	17.5	18.7	18.0
		MCWBR	14.7	13.4	12.4	10.9	9.0	8.3	7.7	8.0	8.1	9.6	13.6	13.7
(40) Clear-Sky Solar Irradiance	taub		0.324	0.342	0.373	0.408	0.440	0.474	0.500	0.496	0.441	0.370	0.347	0.330
	taud		2.536	2.483	2.392	2.296	2.252	2.199	2.152	2.161	2.294	2.457	2.477	2.525
	Ebn at Noon		287	291	288	281	271	260	253	252	263	277	275	278
	Edh at Noon		27	31	36	42	44	46	48	47	40	32	28	26
(44) All-Sky Solar Radiation	RadAvg		875	1032	1405	1759	1938	1983	1935	1818	1607	1360	1012	777
	RadStd		75	163	114	130	118	158	116	146	133	179	104	84

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+221	+144

Nomenclature: See separate page