

MCCOMB PIKE COUNTY AP, MS, USA

WMO: 722358

Lat: 31.183N

Lon: 90.471W

Elev: 413

StdP: 14.48

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 93919

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.0	29.2	12.2	10.4	34.4	17.0	13.2	38.3	20.5	52.6	18.8	52.4	4.5	350	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.9	95.1	76.1	93.1	75.8	91.2	75.7	79.5	88.9	78.5	87.6	77.9	86.8	6.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	143.7	83.0	76.3	139.3	82.3	75.4	134.9	81.5	43.1	88.8	42.3	87.7	41.5	86.6	92.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.9	15.8	13.0	DB	19.5	98.2	3.9	3.1	16.7	100.5	14.4	102.3	12.2	104.1	9.4	106.4	(4)
(5)			WB	17.7	81.9	3.7	3.0	15.0	84.0	12.8	85.8	10.7	87.4	8.0	89.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.6	49.4	53.4	59.7	66.0	73.6	79.5	81.2	81.4	77.3	67.8	57.6	51.6
	DBStd	13.58	10.24	10.02	8.69	6.80	5.38	3.42	2.61	3.02	4.55	7.63	8.33	9.83
	HDD50	359	139	72	22	1	0	0	0	0	0	1	25	99
	HDD65	1852	491	341	206	69	8	0	0	0	1	60	248	428
	CDD50	6425	120	168	323	481	733	885	967	972	820	554	252	150
	CDD65	2442	8	17	41	100	275	435	502	507	371	148	25	13
	CDH74	21518	12	70	255	748	2370	4068	4671	4855	3136	1168	134	31
	CDH80	8942	0	5	22	122	852	1855	2158	2297	1287	332	11	1
Wind	WSAvg	5.3	6.5	6.8	6.7	6.6	5.3	4.2	3.7	3.6	4.2	4.7	5.3	6.0
Precipitation	PrecAvg	62.0	5.8	5.8	6.0	5.4	5.2	4.8	5.5	5.3	4.7	3.5	4.7	5.9
	PrecMax	82.6	12.7	13.6	15.9	16.0	11.2	15.9	12.8	13.3	11.7	12.8	12.3	14.4
	PrecMin	36.9	0.8	1.0	1.5	0.2	0.6	0.6	1.6	1.5	0.9	0.0	0.4	3.1
	PrecStd	12.1	3.1	3.1	3.0	3.9	3.0	3.5	3.0	3.0	2.6	3.1	2.7	2.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.6	80.6	82.5	85.8	92.3	98.0	97.2	98.6	94.8	90.0	81.5	77.5
		MCWB	65.3	67.7	67.2	71.1	73.7	73.5	76.7	75.9	74.7	71.1	69.6	68.9
	2%	DB	72.4	76.0	79.8	83.3	89.4	93.6	94.2	95.0	91.8	86.7	77.7	74.0
		MCWB	64.2	65.1	66.1	69.3	72.8	74.5	76.6	76.5	74.2	71.2	66.9	67.7
	5%	DB	69.4	72.4	77.0	81.2	87.4	91.3	92.1	92.8	89.7	83.8	74.8	70.8
		MCWB	63.1	63.8	65.0	68.1	72.4	74.6	76.6	76.7	73.8	70.1	65.5	65.4
	10%	DB	65.8	69.4	73.8	78.8	85.2	89.4	90.2	90.7	87.4	80.9	72.0	67.8
		MCWB	61.1	62.8	63.7	66.5	71.4	74.9	76.7	76.6	73.6	68.7	64.6	63.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.7	70.2	72.0	74.4	77.8	79.3	81.1	80.9	78.9	77.1	73.0	72.4
		MCDB	72.3	74.9	77.2	81.5	87.6	88.6	90.8	90.2	86.5	83.7	76.8	74.6
	2%	WB	67.0	68.3	69.5	72.7	75.9	78.1	79.5	79.5	77.5	75.2	70.7	69.0
		MCDB	70.0	73.3	74.2	78.7	84.2	87.1	89.3	88.8	85.5	81.0	74.4	72.4
	5%	WB	64.7	66.4	68.0	71.2	74.6	77.3	78.5	78.6	76.5	73.6	68.7	66.9
		MCDB	67.7	71.1	73.4	77.0	82.4	86.0	87.8	87.7	84.3	79.3	72.9	69.8
	10%	WB	62.3	64.1	66.3	69.9	73.4	76.4	77.8	77.8	75.5	72.1	66.2	64.4
		MCDB	65.3	68.1	72.0	75.2	80.9	84.8	86.8	86.8	83.2	77.7	70.3	67.0
Mean Daily Temperature Range	5% DB	MDBR	20.6	21.0	22.0	22.0	20.8	19.4	18.6	18.9	19.4	22.0	22.2	20.0
		MCDBR	20.9	21.6	22.6	21.9	22.0	22.0	21.2	21.8	21.8	22.4	22.8	20.5
		MCWBR	14.2	12.5	11.5	10.1	8.3	7.2	7.2	7.2	7.8	9.7	13.3	14.2
	5% WB	MCDBR	17.1	18.3	18.0	17.5	18.9	18.5	18.8	19.0	17.8	17.2	18.8	17.4
		MCWBR	13.7	12.5	11.4	9.9	8.4	7.5	7.6	7.5	7.2	8.9	13.3	13.7
Clear-Sky Solar Irradiance	taub	0.324	0.343	0.363	0.399	0.428	0.455	0.499	0.497	0.440	0.372	0.346	0.331	
	taud	2.529	2.475	2.420	2.323	2.283	2.256	2.157	2.164	2.295	2.450	2.475	2.521	
	Ebn at Noon	287	291	292	283	274	266	253	253	264	277	276	279	
	Edh at Noon	27	31	36	41	43	44	48	47	40	32	29	26	
All-Sky Solar Radiation	RadAvg	893	1062	1423	1776	1935	1931	1860	1767	1601	1377	1031	790	
	RadStd	79	153	119	134	119	153	113	134	121	171	101	83	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (22 neighbors)		+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+245	+160	(47)

Nomenclature: See separate page