

EDWARDS COUNTY AP, TX, USA

WMO: 722363

Lat: 29.947N

Lon: 100.173W

Elev: 723

StdP: 92.94

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 23098

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.4	(c) -0.2	(d) -12.8	(e) 1.4	(f) 6.5	(g) -11.2	(h) 1.6	(i) 7.7	(j) 10.6	(k) 10.5	(l) 9.2	(m) 11.8	(n) 2.1	(o) 30	(p) 0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.7	36.3	21.2	35.1	21.0	33.9	21.2	24.1	29.4	23.7	28.9	23.3	28.3	4.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	19.1	25.4	22.5	18.7	25.2	22.3	18.5	25.1	76.6	30.0	74.9	28.3	73.2	28.2	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.3	8.4	7.8	-4.8	37.9	1.6	1.5	-6.0	39.0	-6.9	39.9	-7.8	40.7	-9.0	41.8
			-6.7	25.3	1.7	1.5	-7.9	26.4	-8.9	27.3	-9.8	28.2	-11.0	29.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	9.9	12.7	15.9	19.5	23.0	26.8	27.5	27.9	25.1	20.3	14.6	10.7
	DBStd	7.42	5.00	5.24	4.67	3.56	3.20	1.95	1.80	1.71	2.53	4.19	4.86	4.84
	HDD10.0	177	64	30	11	1	0	0	0	0	0	2	17	52
	HDD18.3	954	263	164	100	28	4	0	0	0	1	30	126	238
	CDD10.0	3645	61	106	193	285	402	503	541	553	452	321	155	73
	CDD18.3	1382	2	7	24	62	149	253	283	295	202	90	14	2
	CDH23.3	13356	17	71	175	472	1253	2626	3033	3301	1732	592	68	18
	CDH26.7	6080	1	13	34	134	484	1274	1534	1717	726	153	7	2
Wind	WSAvg	3.9	3.6	3.8	4.4	4.6	4.4	4.6	4.0	3.6	3.2	3.6	3.5	3.6
Precipitation	PrecAvg	657	27	29	48	49	75	71	66	66	85	68	46	25
	PrecMax	1106	69	84	163	149	171	205	236	391	227	234	199	142
	PrecMin	296	0	1	1	0	21	1	6	8	9	0	0	2
	PrecStd	211	23	27	37	39	40	60	65	78	52	63	57	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	28.6	29.1	32.8	35.2	37.4	37.3	37.4	36.3	32.2	27.6	26.0
		MCWB	12.9	14.9	14.8	15.8	19.5	20.6	21.2	21.1	20.1	19.8	17.2	12.9
	2%	DB	22.5	25.9	27.5	30.0	32.7	35.8	36.1	36.2	33.7	29.9	25.3	22.6
		MCWB	12.6	13.5	15.5	16.4	20.3	21.1	21.1	21.5	20.7	20.2	16.6	13.9
	5%	DB	19.9	22.8	25.8	27.7	31.3	33.8	34.2	35.0	32.3	28.0	23.0	20.2
		MCWB	12.5	13.5	15.6	17.0	20.2	21.2	21.5	21.4	20.7	19.5	16.1	13.3
	10%	DB	17.6	20.9	22.8	26.2	29.0	32.6	33.0	33.8	31.0	27.2	22.0	17.8
		MCWB	11.7	13.6	15.1	16.9	20.0	21.3	21.3	21.4	20.6	19.1	15.6	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.6	18.8	19.9	21.8	24.1	25.3	24.6	24.3	24.1	23.9	21.1	18.7
		MCDB	18.7	21.7	23.8	25.7	28.7	31.2	30.8	30.6	29.3	27.2	23.4	20.1
	2%	WB	16.3	17.6	19.1	21.0	23.2	24.2	23.9	23.8	23.4	22.5	19.5	17.5
		MCDB	18.7	19.1	22.4	24.5	27.7	29.2	29.3	29.7	28.1	25.9	21.6	18.5
	5%	WB	14.7	16.8	18.2	20.2	22.5	23.6	23.3	23.4	22.9	21.7	18.5	16.0
		MCDB	17.8	18.9	20.9	23.8	26.9	28.4	28.6	29.2	27.3	25.2	20.6	18.0
	10%	WB	12.8	15.5	17.5	19.5	21.9	23.0	22.9	22.9	22.4	21.0	17.5	14.3
		MCDB	16.1	18.9	19.7	23.0	26.3	27.7	28.1	28.7	26.8	24.4	19.5	16.8
Mean Daily Temperature Range	5% DB	MDBR	11.0	11.4	11.4	11.5	10.9	11.4	11.3	11.7	10.5	10.8	10.6	10.8
		MCDBR	13.6	13.9	13.8	13.7	13.4	13.3	12.9	13.4	12.3	11.3	11.6	13.2
		MCWBR	7.3	6.9	6.3	6.5	5.0	3.6	3.5	3.6	4.1	5.1	6.1	7.3
	5% WB	MCDBR	10.9	10.0	9.8	9.7	10.3	10.5	10.8	11.3	9.5	9.4	9.6	9.8
		MCWBR	8.0	7.1	5.5	5.4	4.6	4.3	3.3	3.5	3.4	5.0	6.6	7.6
Clear-Sky Solar Irradiance	taub	0.293	0.298	0.319	0.349	0.373	0.378	0.390	0.376	0.366	0.335	0.311	0.295	
	taud	2.568	2.558	2.510	2.441	2.426	2.463	2.473	2.500	2.462	2.541	2.545	2.564	
	Ebn at Noon	952	975	969	944	916	905	893	906	907	920	922	932	
	Edh at Noon	83	92	103	115	117	112	111	107	107	93	85	80	
All-Sky Solar Radiation	RadAvg	3.23	3.92	4.91	5.80	6.04	6.85	6.79	6.42	5.26	4.30	3.37	2.91	
	RadStd	0.36	0.57	0.45	0.53	0.64	0.54	0.57	0.35	0.46	0.62	0.44	0.39	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+87

Nomenclature: See separate page