

TUNICA, MS, USA

WMO: 722364

Lat: 34.681N

Lon: 90.347W

Elev: 59

StdP: 100.62

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 23903

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.0	-3.0	-12.4	1.3	-3.5	-9.9	1.6	-1.5	11.9	8.7	11.0	8.6	3.6	0	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	36.0	24.1	34.8	24.3	32.9	23.9	26.5	32.2	25.8	31.6	25.3	31.2	3.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.3	29.2	24.1	19.1	28.8	23.0	17.9	27.8	82.8	31.1	79.8	31.4	77.3	31.0	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	8.9	7.9	DB	-8.1	37.2	2.2	1.6	-9.6	38.3	-10.9	39.3	-12.1	40.2	-13.7	41.3	(4)
(5)			WB	-8.4	27.3	2.8	0.7	-10.4	27.8	-12.0	28.2	-13.6	28.6	-15.6	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	5.5	7.0	11.8	16.7	21.6	26.1	26.9	26.7	23.5	16.9	10.4	6.6	(6)	
	DBStd	9.01	5.51	5.50	5.50	4.48	3.89	2.32	2.23	2.48	3.31	4.73	4.99	4.89	(7)	
	HDD10.0	518	162	116	44	6	0	0	0	0	0	4	56	131	(8)	
	HDD18.3	1722	399	319	212	81	18	0	0	0	3	85	242	363	(9)	
	CDD10.0	2964	21	32	100	207	360	484	523	518	407	218	67	27	(10)	
	CDD18.3	1123	0	1	9	32	119	234	265	260	159	41	3	0	(11)	
	CDH23.3	11232	0	2	56	257	1028	2460	2790	2673	1525	416	25	1	(12)	
(14) Wind	WSAvg	3.2	4.0	4.0	4.1	4.0	3.3	2.7	2.3	2.1	2.5	2.9	3.3	3.6	(14)	
	PrecAvg	1322	132	108	133	135	129	98	103	75	75	94	120	138	(15)	
	PrecMax	1781	216	232	250	460	278	228	252	172	249	267	306	295	(16)	
	PrecMin	896	64	45	30	35	21	14	21	6	4	0	35	31	(17)	
	PrecStd	269	40	54	57	88	66	56	62	42	54	61	72	69	(18)	
	DB	21.2	22.7	27.3	30.1	32.9	36.2	36.4	37.5	36.0	32.2	26.3	22.3		(19)	
	MCWB	17.8	18.0	18.4	19.7	21.8	23.6	24.3	24.8	22.1	21.3	18.1	18.8		(20)	
(22) Mean Coincident Wet Bulb Temperatures	DB	18.6	21.0	25.0	27.7	32.1	34.9	35.2	36.1	33.6	30.1	22.9	19.8		(21)	
	MCWB	16.0	17.4	17.9	19.1	21.8	23.7	25.0	24.5	23.0	21.1	16.9	16.9		(22)	
	DB	17.1	18.0	22.6	26.3	30.3	32.9	33.9	34.8	32.4	27.7	21.3	17.3		(23)	
	MCWB	14.7	14.9	16.7	18.4	21.1	23.3	24.9	24.7	22.8	19.5	16.2	15.2		(24)	
	DB	14.9	16.3	20.9	24.8	28.7	32.4	32.6	32.6	31.0	25.9	18.8	15.1		(25)	
	MCWB	12.0	13.2	15.5	17.8	21.0	23.2	24.6	24.4	22.4	18.2	15.1	12.7		(26)	
	WB	18.4	19.2	20.0	22.1	24.1	26.2	27.3	27.4	25.3	23.7	20.3	19.1		(27)	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	20.6	21.6	25.0	27.0	29.5	32.1	32.5	33.6	31.5	29.4	23.9	21.8		(28)	
	WB	16.8	17.7	18.9	20.9	23.4	25.4	26.5	26.6	24.7	22.7	18.9	17.3		(29)	
	MCDB	18.2	19.6	23.6	25.5	28.6	31.7	31.9	32.6	30.8	27.8	22.3	18.5		(30)	
	WB	15.2	16.0	17.6	19.8	22.7	24.9	25.8	25.8	24.1	21.5	17.3	15.6		(31)	
	MCDB	16.9	18.2	21.3	24.5	27.7	31.1	31.5	31.6	29.9	25.4	19.4	17.1		(32)	
	WB	12.4	13.8	16.5	18.9	21.9	24.3	25.4	25.3	23.4	20.1	15.6	13.3		(33)	
	MCDB	14.0	16.4	20.0	23.3	26.9	30.1	31.2	30.9	28.4	23.7	18.5	15.3		(34)	
(35) Mean Daily Temperature Range	MDBR	8.8	9.1	10.6	11.2	10.8	11.1	10.4	10.8	12.2	12.5	11.2	8.4		(35)	
	5% DB	11.4	12.0	12.4	12.6	12.6	12.2	11.9	12.6	13.9	14.7	14.0	10.5		(36)	
	MCWBR	9.4	8.5	7.3	5.9	4.7	4.0	3.9	3.8	5.0	6.5	8.5	8.6		(37)	
	5% WB	10.6	10.6	11.0	10.5	10.4	10.8	10.4	10.8	11.4	11.7	11.3	10.0		(38)	
	MCWBR	9.7	8.5	7.1	6.1	4.8	4.3	4.2	4.3	4.6	6.4	8.4	8.8		(39)	
(40) Clear-Sky Solar Irradiance	taub	0.320	0.329	0.365	0.404	0.441	0.466	0.499	0.491	0.424	0.363	0.337	0.319		(40)	
	taud	2.495	2.464	2.390	2.274	2.230	2.170	2.113	2.122	2.301	2.450	2.475	2.513		(41)	
	Ebn at Noon	888	917	907	882	850	825	795	795	835	866	858	866		(42)	
	Edh at Noon	84	97	113	133	141	150	157	153	122	97	85	78		(43)	
(44) All-Sky Solar Radiation	RadAvg	2.46	2.98	4.16	5.27	5.93	6.54	6.24	5.78	4.95	3.89	2.78	2.13		(44)	
	RadStd	0.21	0.42	0.39	0.34	0.33	0.38	0.32	0.40	0.36	0.48	0.29	0.21		(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page