

POLK AAF, LA, USA

WMO: 722390

Lat: 31.050N

Lon: 93.183W

Elev: 330

StdP: 14.52

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03931

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.5	30.4	13.9	11.3	34.7	18.5	14.1	39.5	20.7	54.7	18.9	54.4	6.4	10	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.5	97.1	75.2	94.7	75.7	92.6	75.7	79.4	88.0	78.6	87.1	78.1	86.5	6.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	144.1	81.8	76.8	141.5	81.5	76.0	137.3	81.0	43.0	88.0	42.3	87.3	41.6	86.6	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.6	16.5	14.5	21.7	99.9	3.9	3.9	18.9	102.7	16.7	105.0	14.5	107.2	11.7	110.1		
			DB	WB	19.7	81.2	3.4	1.6	17.2	82.3	15.2	83.2	13.3	84.1	10.8	85.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.6	50.4	54.4	60.4	67.1	74.6	80.5	82.6	83.0	78.2	68.4	58.6	51.9
	DBStd	13.85	10.20	10.28	9.07	7.14	5.36	3.63	3.04	3.45	4.87	7.57	8.73	9.86
	HDD50	330	122	65	22	1	0	0	0	0	0	1	23	96
	HDD65	1746	462	318	196	61	5	0	0	0	1	55	227	421
	CDD50	6751	135	188	344	515	764	915	1012	1024	847	570	281	156
	CDD65	2693	10	21	53	125	304	465	547	559	399	159	35	16
	CDH74	25205	14	68	271	865	2508	4574	5826	6005	3596	1266	172	40
	CDH80	10708	0	2	26	161	871	2057	2741	2922	1550	363	15	0
Wind	WSAvg	6.6	7.4	7.7	7.9	8.1	7.1	6.0	5.3	5.0	5.5	5.9	6.5	7.1
Precipitation	PrecAvg	55.3	5.5	4.6	4.8	5.1	4.6	3.8	4.6	3.5	4.3	3.9	5.2	5.2
	PrecMax	81.6	14.5	11.4	12.3	11.0	12.9	12.7	9.2	6.0	9.5	14.9	12.9	9.9
	PrecMin	30.5	0.7	0.9	0.7	1.1	0.1	0.2	1.0	0.6	0.9	0.0	0.6	1.8
	PrecStd	11.7	3.3	2.9	2.6	2.5	3.2	2.8	2.1	1.3	2.0	4.3	3.3	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.7	79.5	82.8	87.3	92.1	98.7	99.3	100.9	96.8	90.0	82.2	78.3
		MCWB	65.9	66.6	67.8	71.2	72.7	73.9	75.5	74.9	73.4	72.1	70.1	69.9
	2%	DB	72.7	76.1	80.0	84.0	89.6	94.6	96.0	97.2	93.3	87.1	78.7	74.6
		MCWB	64.5	65.2	66.9	69.5	72.9	75.2	76.0	75.6	73.9	71.7	68.0	68.4
	5%	DB	70.0	72.8	77.1	81.6	87.4	91.7	93.5	94.7	90.9	84.2	75.4	71.6
		MCWB	64.1	64.7	65.8	68.0	73.3	75.4	76.3	76.2	74.2	70.4	66.7	67.2
	10%	DB	66.9	70.0	73.9	79.3	85.3	90.0	91.4	92.5	88.5	81.4	72.8	68.4
		MCWB	61.7	64.0	64.7	66.9	72.2	75.2	76.5	76.3	73.8	69.3	66.0	64.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.2	70.4	72.8	74.8	77.5	79.6	80.3	80.5	79.1	77.4	73.4	72.2
		MCDB	72.8	74.4	76.6	80.7	85.8	86.7	88.7	89.2	86.6	83.2	77.6	75.3
	2%	WB	67.7	68.8	70.3	73.0	76.3	78.5	79.3	79.5	78.0	75.9	71.5	69.8
		MCDB	70.6	72.9	75.0	79.2	83.8	86.0	88.3	88.4	85.6	81.9	75.2	72.9
	5%	WB	65.7	67.3	68.9	71.7	75.2	77.9	78.4	78.7	77.1	74.6	69.7	68.3
		MCDB	69.1	71.1	73.8	77.8	82.2	85.6	87.2	87.5	84.6	80.3	73.8	71.2
	10%	WB	63.0	65.5	67.3	70.4	74.2	77.1	77.9	78.0	76.1	72.7	67.3	65.3
		MCDB	65.7	69.4	72.4	76.1	81.1	84.9	86.6	86.7	83.4	78.0	71.4	67.9
Mean Daily Temperature Range	5% DB	MDBR	19.3	19.7	20.1	20.3	18.9	18.0	17.8	18.5	19.0	20.9	19.9	18.3
		MCDBR	20.2	19.7	20.2	20.2	19.6	20.3	20.2	21.4	21.5	21.7	21.2	18.7
		MCWBR	13.5	11.1	10.3	8.4	6.5	5.7	5.3	5.4	6.7	9.0	12.2	12.8
	5% WB	MCDBR	17.0	16.8	17.2	16.4	17.0	17.0	17.5	18.1	17.2	17.1	17.9	16.7
		MCWBR	13.8	12.1	11.2	8.9	7.1	6.1	6.0	5.7	6.4	9.4	12.7	12.7
Clear-Sky Solar Irradiance	taub	0.329	0.347	0.369	0.407	0.439	0.485	0.488	0.484	0.440	0.369	0.356	0.341	
	taud	2.527	2.481	2.416	2.316	2.265	2.176	2.207	2.217	2.306	2.481	2.468	2.493	
	Ebn at Noon	286	290	290	281	271	258	256	256	264	279	273	274	
	Edh at Noon	27	31	36	41	43	48	46	45	40	31	29	27	
All-Sky Solar Radiation	RadAvg	882	997	1390	1700	1885	1909	1894	1796	1582	1347	1008	774	
	RadStd	83	170	118	124	130	150	148	164	148	183	102	89	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+194	+137

Nomenclature: See separate page