

SALT POINT, LA, USA

WMO: 722403

Lat: 29.572N

Lon: 91.531W

Elev: 4

StdP: 14.69

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12968

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.1	35.6	18.7	14.1	36.7	24.3	18.4	41.8	15.3	54.9	13.2	52.7	4.1	350	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	91.9	79.2	90.6	79.1	89.6	78.9	81.5	88.3	80.8	87.6	80.2	86.9	4.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.4	152.6	85.4	78.9	150.2	85.2	78.3	146.8	84.7	45.0	88.9	44.3	87.8	43.7	86.9	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.9	11.6	10.4	28.3	95.7	3.9	3.5	25.5	98.2	23.2	100.2	21.0	102.2	18.2	104.7		
(5)			25.3	82.9	4.1	0.6	22.4	83.3	20.0	83.6	17.7	83.9	14.7	84.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	69.7	52.7	55.9	62.5	69.3	76.0	81.8	83.3	83.3	80.3	72.2	62.8	56.0	(6)
(7)		DBStd	12.70	9.25	8.64	7.65	5.60	4.50	2.89	2.61	2.79	3.97	6.84	7.84	8.85	(7)
(8)		HDD50	178	79	39	10	1	0	0	0	0	0	0	6	43	(8)
(9)		HDD65	1271	391	266	136	26	2	0	0	0	0	21	130	299	(9)
(10)		CDD50	7384	162	206	396	579	806	954	1032	1033	910	687	390	229	(10)
(11)		CDD65	3003	10	13	57	154	343	504	567	568	460	243	64	20	(11)
(12)		CDH74	28934	39	13	89	581	2619	5571	6771	6662	4497	1809	251	32	(12)
(13)		CDH80	10317	8	0	0	20	492	2098	2812	2808	1625	423	28	3	(13)
(14)	Wind	WSAvg	4.1	5.1	5.3	5.0	4.9	4.1	3.2	3.0	2.9	2.9	3.6	4.2	4.8	(14)
(15)	Precipitation	PrecAvg	61.9	5.1	3.9	4.0	4.3	4.1	7.3	7.2	5.9	5.9	4.9	4.4	4.7	(15)
(16)		PrecMax	82.4	14.3	8.7	11.2	12.8	13.1	16.5	11.4	10.5	11.9	15.0	14.0	17.0	(16)
(17)		PrecMin	46.3	0.7	0.5	0.3	0.2	0.2	1.9	3.7	2.5	2.4	0.4	1.5	1.5	(17)
(18)		PrecStd	10.8	3.7	2.6	2.6	3.2	2.9	3.5	2.1	2.2	2.5	3.9	3.0	3.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.2	76.2	78.5	82.0	87.1	92.2	92.5	93.6	95.7	90.1	83.1	77.4	(19)
(20)			MCWB	69.3	70.4	70.4	74.0	75.4	78.6	79.1	79.4	77.5	76.7	73.3	71.6	(20)
(21)		2%	DB	71.8	72.5	76.5	80.4	85.3	90.2	91.1	91.8	91.0	86.7	79.4	73.9	(21)
(22)			MCWB	66.3	67.6	69.4	72.9	75.5	78.3	79.4	79.6	78.4	76.5	72.2	69.3	(22)
(23)		5%	DB	68.1	70.1	74.7	79.0	84.1	88.9	90.1	90.5	89.0	84.3	76.9	71.5	(23)
(24)			MCWB	64.3	66.0	68.6	71.9	75.4	78.0	79.3	79.5	78.0	75.1	69.6	67.7	(24)
(25)		10%	DB	65.3	67.5	72.6	77.4	82.8	87.8	88.8	89.5	87.4	82.2	74.3	68.7	(25)
(26)			MCWB	62.2	64.0	67.5	70.9	75.0	77.7	78.9	79.3	77.2	74.4	68.3	65.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.5	71.3	72.8	76.3	78.5	81.9	82.1	82.5	81.4	80.4	75.8	72.7	(27)
(28)			MCDWB	77.8	75.2	76.2	79.8	83.7	88.7	89.5	89.9	87.8	84.2	78.8	74.7	(28)
(29)		2%	WB	67.8	69.2	71.3	75.1	77.6	80.5	81.1	81.7	80.4	78.7	73.2	70.3	(29)
(30)			MCDWB	70.5	71.7	74.7	78.6	82.7	87.0	88.4	88.7	86.8	82.9	76.6	72.9	(30)
(31)		5%	WB	65.6	67.3	70.1	73.9	76.9	79.8	80.4	81.0	79.6	77.5	71.4	68.3	(31)
(32)			MCDWB	67.8	69.6	73.4	77.7	82.0	86.4	87.5	87.9	86.0	82.0	74.5	70.6	(32)
(33)		10%	WB	63.3	65.1	68.9	72.7	76.1	79.0	79.9	80.4	78.5	76.0	69.5	66.3	(33)
(34)			MCDWB	64.9	67.0	71.9	76.5	81.1	85.6	86.9	87.1	84.5	80.5	72.6	68.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.7	14.0	14.0	13.0	11.7	11.2	10.6	11.5	13.2	15.2	16.3	14.4	(35)
(36)			MCDBR	14.9	13.7	12.4	11.7	11.4	12.0	11.3	12.4	14.3	15.0	15.8	14.4	(36)
(37)			MCWBR	10.8	9.4	7.7	6.7	5.4	5.1	4.9	4.9	5.0	6.6	8.5	10.6	(37)
(38)		5% WB	MCDWB	12.7	11.6	11.0	10.2	10.0	10.5	10.4	10.6	11.6	11.6	13.3	12.9	(38)
(39)			MCWBR	10.4	9.3	7.7	7.1	5.4	5.5	5.2	5.4	5.4	7.0	10.3	10.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.346	0.360	0.378	0.424	0.449	0.466	0.492	0.485	0.441	0.386	0.362	0.354	(40)	
(41)		taud	2.516	2.485	2.420	2.297	2.260	2.266	2.222	2.240	2.328	2.465	2.475	2.500	(41)	
(42)		Ebn at Noon	282	287	288	277	269	263	256	257	265	275	273	273	(42)	
(43)		Edh at Noon	28	32	36	42	44	43	45	44	39	32	29	28	(43)	
(44)	All-Sky Solar Radiation	RadAvg	956	1134	1539	1854	2045	1997	1849	1744	1633	1464	1105	860	(44)	
(45)		RadStd	91	150	140	131	105	146	123	147	144	154	105	79	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+241	+166

Nomenclature: See separate page