

SALT POINT, LA, USA

WMO: 722403

Lat: 29.572N

Lon: 91.531W

Elev: 1

StdP: 101.31

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12968

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.1	2.0	-7.4	2.0	2.6	-4.3	2.6	5.5	6.8	12.7	5.9	11.5	1.9	350	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	33.3	26.2	32.6	26.2	32.0	26.1	27.5	31.3	27.1	30.9	26.8	30.5	1.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.8	29.7	26.1	21.5	29.5	25.7	21.0	29.3	86.8	31.6	85.3	31.0	83.7	30.5	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.8	5.2	4.7	-2.0	35.4	2.2	1.9	-3.6	36.8	-4.9	37.9	-6.1	39.0	-7.7	40.4		
			-3.7	28.3	2.3	0.3	-5.3	28.5	-6.7	28.7	-7.9	28.9	-9.6	29.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	11.5	13.3	16.9	20.7	24.4	27.7	28.5	28.5	26.9	22.3	17.1	13.3
	DBStd	7.05	5.14	4.80	4.25	3.11	2.50	1.60	1.45	1.55	2.20	3.80	4.36	4.92
	HDD10.0	99	44	22	6	1	0	0	0	0	0	0	3	24
	HDD18.3	706	217	148	76	14	1	0	0	0	0	12	72	166
	CDD10.0	4102	90	114	220	322	448	530	573	574	506	382	217	127
	CDD18.3	1668	6	7	32	86	191	280	315	316	256	135	36	11
	CDH23.3	16074	22	7	49	323	1455	3095	3762	3701	2498	1005	139	18
	CDH26.7	5732	4	0	0	11	273	1166	1562	1560	903	235	16	2
Wind	WSAvg	1.8	2.3	2.4	2.3	2.2	1.8	1.4	1.4	1.3	1.3	1.6	1.9	2.1
Precipitation	PrecAvg	1573	129	99	102	110	103	185	184	150	149	124	113	119
	PrecMax	2094	364	221	285	324	332	418	290	267	303	381	355	432
	PrecMin	1176	18	12	7	5	6	49	94	63	62	11	37	39
	PrecStd	275	94	67	66	81	74	90	54	57	64	100	76	87
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.8	24.6	25.8	27.8	30.6	33.5	33.6	34.2	35.4	32.3	28.4	25.2
		MCWB	20.7	21.4	21.3	23.3	24.1	25.9	26.1	26.3	25.3	24.8	23.0	22.0
	2%	DB	22.1	22.5	24.7	26.9	29.6	32.3	32.8	33.2	32.8	30.4	26.3	23.3
		MCWB	19.0	19.8	20.8	22.7	24.2	25.7	26.4	26.5	25.8	24.7	22.3	20.7
	5%	DB	20.0	21.1	23.7	26.1	29.0	31.6	32.3	32.5	31.7	29.0	24.9	21.9
		MCWB	17.9	18.9	20.3	22.1	24.1	25.5	26.3	26.4	25.6	24.0	20.9	19.9
	10%	DB	18.5	19.7	22.6	25.2	28.2	31.0	31.6	31.9	30.8	27.9	23.5	20.4
		MCWB	16.8	17.8	19.7	21.6	23.9	25.4	26.1	26.3	25.1	23.6	20.2	18.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.0	21.8	22.7	24.6	25.8	27.7	27.9	28.1	27.5	26.9	24.3	22.6
		MCDB	25.5	24.0	24.6	26.5	28.7	31.5	31.9	32.2	31.0	29.0	26.0	23.7
	2%	WB	19.9	20.7	21.8	24.0	25.3	26.9	27.3	27.6	26.9	25.9	22.9	21.3
		MCDB	21.4	22.1	23.7	25.9	28.2	30.6	31.3	31.5	30.4	28.3	24.8	22.7
	5%	WB	18.7	19.6	21.2	23.3	24.9	26.6	26.9	27.2	26.5	25.3	21.9	20.2
		MCDB	19.9	20.9	23.0	25.4	27.8	30.2	30.8	31.1	30.0	27.8	23.6	21.5
	10%	WB	17.4	18.4	20.5	22.6	24.5	26.1	26.6	26.9	25.8	24.5	20.8	19.1
		MCDB	18.3	19.4	22.2	24.7	27.3	29.8	30.5	30.6	29.2	26.9	22.5	20.2
Mean Daily Temperature Range	5% DB	MDBR	8.1	7.8	7.8	7.2	6.5	6.2	5.9	6.4	7.4	8.5	9.0	8.0
		MCDBR	8.3	7.6	6.9	6.5	6.3	6.7	6.3	6.9	7.9	8.3	8.8	8.0
		MCWBR	6.0	5.2	4.3	3.7	3.0	2.8	2.7	2.7	2.8	3.7	4.7	5.9
	5% WB	MCDBR	7.1	6.4	6.1	5.7	5.6	5.8	5.8	5.9	6.4	6.4	7.4	7.2
		MCWBR	5.8	5.2	4.3	3.9	3.0	3.0	2.9	3.0	3.0	3.9	5.7	5.8
Clear-Sky Solar Irradiance	taub	0.346	0.360	0.378	0.424	0.449	0.466	0.492	0.485	0.441	0.386	0.362	0.354	
	taud	2.516	2.485	2.420	2.297	2.260	2.266	2.222	2.240	2.328	2.465	2.475	2.500	
	Ebn at Noon	890	906	909	874	848	829	806	809	836	866	862	860	
	Edh at Noon	89	100	114	133	138	137	143	139	123	101	92	87	
All-Sky Solar Radiation	RadAvg	3.01	3.57	4.85	5.84	6.45	6.29	5.83	5.50	5.15	4.62	3.48	2.71	
	RadStd	0.29	0.47	0.44	0.41	0.33	0.46	0.39	0.46	0.45	0.49	0.33	0.25	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+134	+92

Nomenclature: See separate page