

CORSICANA, TX, USA

WMO: 722469

Lat: 32.031N

Lon: 96.399W

Elev: 448

StdP: 14.46

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53912

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.2	28.9	11.9	10.3	33.4	16.2	12.7	37.9	26.1	59.8	24.3	57.9	8.9	0	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.0	100.3	74.7	98.3	75.1	96.1	75.1	78.5	90.5	78.0	90.0	77.4	89.2	8.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.5	135.8	82.2	75.0	133.6	82.0	74.3	130.3	81.7	42.3	90.9	41.6	90.1	41.0	89.2	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.9	19.9	18.0	DB	18.4	103.9	5.6	2.9	14.3	105.9	11.1	107.6	7.9	109.2	3.9	111.3	
			WB	17.1	79.7	3.3	1.1	14.7	80.6	12.7	81.2	10.9	81.8	8.5	82.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.5	48.3	51.9	59.6	66.9	74.3	81.4	84.4	85.3	79.2	69.0	58.4	49.7
	DBStd	15.15	10.01	10.62	9.17	7.29	5.83	3.70	3.27	3.94	5.61	7.94	9.37	9.67
	HDD50	433	152	96	27	2	0	0	0	0	1	30	125	
	HDD65	1961	523	381	213	64	8	0	0	0	1	53	235	483
	CDD50	6803	99	148	323	508	754	943	1066	1096	877	590	282	117
	CDD65	2858	6	13	45	120	297	493	601	631	428	177	37	10
	CDH74	31170	30	68	254	855	2586	5462	7452	8191	4505	1510	214	43
	CDH80	15038	2	5	31	183	910	2604	3971	4613	2175	512	30	2
(14) Wind	WSAvg	8.9	9.5	9.9	10.2	10.1	9.4	8.6	7.9	7.6	7.2	8.2	8.9	9.1
(15) Precipitation	PrecAvg	37.8	2.4	3.0	3.1	3.3	4.9	3.2	2.0	2.1	3.1	4.1	3.1	3.4
	PrecMax	52.0	8.7	7.1	9.7	12.4	13.6	8.1	5.9	9.8	9.7	11.1	9.6	10.1
	PrecMin	19.1	0.0	0.2	0.2	0.1	0.3	0.3	0.0	0.0	0.0	0.0	0.2	0.3
	PrecStd	8.3	1.8	1.6	1.8	2.6	2.9	2.3	1.6	2.1	2.1	3.1	2.1	2.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.5	80.3	83.3	89.3	93.3	99.6	102.0	104.2	101.1	92.4	83.7	79.1
		MCWB	61.8	62.7	66.5	71.1	73.9	74.1	74.7	74.3	72.5	71.2	68.7	65.3
	2%	DB	73.0	75.7	80.1	84.3	90.3	96.0	99.2	101.1	96.7	88.9	79.4	73.7
		MCWB	61.2	62.5	66.1	69.6	74.2	74.7	75.4	74.6	73.6	71.2	66.1	63.8
	5%	DB	69.6	72.2	76.8	81.7	88.0	93.6	97.1	99.1	93.3	85.7	76.0	69.9
		MCWB	60.6	62.3	64.4	69.0	73.7	74.8	75.6	75.2	73.2	69.4	64.6	62.1
	10%	DB	65.2	68.6	73.3	79.2	85.2	91.3	94.7	97.0	90.9	82.3	72.8	66.1
		MCWB	57.6	60.4	62.8	67.6	72.3	75.5	75.7	75.3	73.1	67.9	64.3	59.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.1	68.5	70.4	75.2	78.1	79.4	79.5	79.3	78.2	76.4	72.2	69.2
		MCDB	72.4	74.2	78.4	84.1	87.5	90.0	91.9	93.3	89.3	84.8	78.2	74.4
	2%	WB	65.1	66.6	68.6	72.9	76.5	78.3	78.5	78.3	77.2	74.8	69.9	66.7
		MCDB	70.0	72.0	75.7	81.1	85.6	88.9	90.7	91.9	88.1	82.8	74.9	71.6
	5%	WB	62.4	64.6	67.2	71.2	75.4	77.5	77.9	77.6	76.3	73.4	68.1	64.1
		MCDB	67.5	69.6	73.4	78.8	84.3	88.1	90.1	90.8	86.5	80.8	73.7	68.3
	10%	WB	58.4	62.1	65.6	69.7	74.2	76.7	77.3	77.0	75.3	71.8	65.9	60.8
		MCDB	63.8	67.8	71.9	76.3	82.7	86.9	89.2	89.8	85.0	78.6	71.8	65.3
(35) Mean Daily Temperature Range	5% DB	MDBR	19.8	19.3	19.7	19.9	18.6	18.3	19.8	21.0	20.6	21.4	19.9	19.3
		MCDBR	24.8	22.6	21.3	20.8	20.3	21.2	22.8	24.2	23.2	23.0	22.3	23.2
	5% WB	MCWBR	14.9	13.9	11.1	10.4	8.1	5.8	5.3	5.5	6.8	9.2	12.1	15.3
		MCWBR	20.1	19.0	18.1	17.1	17.7	17.4	19.1	20.3	18.8	18.6	18.1	19.7
(40) Clear-Sky Solar Irradiance	taub		0.319	0.338	0.362	0.400	0.431	0.440	0.447	0.447	0.403	0.362	0.347	0.324
		taud	2.502	2.457	2.405	2.315	2.284	2.294	2.314	2.300	2.372	2.470	2.459	2.492
	Ebn at Noon		287	292	292	283	273	269	267	266	274	279	274	279
		Edh at Noon	28	32	36	41	43	42	41	41	37	31	29	27
(44) All-Sky Solar Radiation	RadAvg		904	1031	1387	1703	1830	2052	2096	1947	1639	1304	963	795
	RadStd		88	176	119	121	145	178	143	128	136	189	121	103

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+135

Nomenclature: See separate page