

CORSICANA, TX, USA

WMO: 722469

Lat: 32.031N

Lon: 96.399W

Elev: 137

StdP: 99.69

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53912

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.8	-1.7	-11.2	1.5	0.8	-8.8	1.8	3.3	11.7	15.5	10.8	14.4	4.0	0	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.7	37.9	23.7	36.9	23.9	35.6	24.0	25.8	32.5	25.6	32.2	25.2	31.8	3.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.2	19.4	27.9	23.9	19.1	27.8	23.5	18.6	27.6	80.5	32.7	78.9	32.3	77.5	31.8	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.2	8.9	8.1	-7.6	39.9	3.1	1.6	-9.8	41.1	-11.6	42.0	-13.4	42.9	-15.6	44.1
			-8.3	26.5	1.9	0.6	-9.6	27.0	-10.7	27.3	-11.7	27.7	-13.1	28.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	9.1	11.0	15.3	19.4	23.5	27.5	29.1	29.6	26.2	20.6	14.7	9.9
	DBStd	8.42	5.56	5.90	5.09	4.05	3.24	2.05	1.82	2.19	3.11	4.41	5.20	5.37
	HDD10.0	241	84	53	15	1	0	0	0	0	0	1	17	69
	HDD18.3	1089	291	212	118	36	4	0	0	0	1	29	131	268
	CDD10.0	3779	55	82	179	282	419	524	592	609	487	328	157	65
	CDD18.3	1588	3	7	25	67	165	274	334	351	238	98	21	6
	CDH23.3	17317	17	38	141	475	1437	3034	4140	4551	2503	839	119	24
	CDH26.7	8354	1	3	17	102	506	1447	2206	2563	1208	284	17	1
Wind	WSAvg	4.0	4.2	4.4	4.6	4.5	4.2	3.8	3.5	3.4	3.2	3.7	4.0	4.1
Precipitation	PrecAvg	961	62	76	78	84	124	81	50	54	78	104	78	86
	PrecMax	1320	222	180	246	314	345	205	150	250	246	281	245	256
	PrecMin	485	1	6	6	2	7	7	0	0	1	0	6	8
	PrecStd	212	45	41	46	66	73	58	41	54	54	80	54	61
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.3	26.8	28.5	31.8	34.0	37.6	38.9	40.1	38.4	33.5	28.7	26.2
		MCWB	16.5	17.1	19.2	21.7	23.3	23.4	23.7	23.5	22.5	21.8	20.4	18.5
	2%	DB	22.8	24.3	26.7	29.0	32.4	35.6	37.3	38.4	36.0	31.6	26.3	23.2
		MCWB	16.2	16.9	19.0	20.9	23.5	23.7	24.1	23.7	23.1	21.8	18.9	17.7
	5%	DB	20.9	22.4	24.9	27.6	31.1	34.2	36.2	37.3	34.1	29.8	24.4	21.1
		MCWB	15.9	16.8	18.0	20.5	23.2	23.8	24.2	24.0	22.9	20.8	18.1	16.7
	10%	DB	18.5	20.4	22.9	26.2	29.6	32.9	34.8	36.1	32.7	27.9	22.7	18.9
		MCWB	14.2	15.8	17.1	19.8	22.4	24.2	24.3	24.1	22.8	20.0	17.9	15.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.5	20.3	21.3	24.0	25.6	26.3	26.4	26.3	25.7	24.7	22.3	20.7
		MCDB	22.4	23.5	25.8	28.9	30.8	32.2	33.3	34.1	31.8	29.4	25.7	23.5
	2%	WB	18.4	19.2	20.3	22.7	24.7	25.7	25.8	25.7	25.1	23.8	21.0	19.3
		MCDB	21.1	22.2	24.3	27.3	29.8	31.6	32.6	33.3	31.2	28.2	23.8	22.0
	5%	WB	16.9	18.1	19.6	21.8	24.1	25.3	25.5	25.4	24.6	23.0	20.1	17.8
		MCDB	19.7	20.9	23.0	26.0	29.1	31.2	32.3	32.7	30.3	27.1	23.1	20.2
	10%	WB	14.7	16.7	18.7	21.0	23.5	24.8	25.2	25.0	24.1	22.1	18.8	16.0
		MCDB	17.7	19.9	22.2	24.6	28.2	30.5	31.8	32.1	29.5	25.9	22.1	18.5
Mean Daily Temperature Range	5% DB	MDBR	11.0	10.7	10.9	11.1	10.3	10.2	11.0	11.7	11.4	11.9	11.0	10.7
		MCDBR	13.8	12.6	11.9	11.5	11.3	11.8	12.7	13.5	12.9	12.8	12.4	12.9
		MCWBR	8.3	7.7	6.2	5.8	4.5	3.2	2.9	3.0	3.8	5.1	6.7	8.5
	5% WB	MCDBR	11.2	10.5	10.0	9.5	9.8	9.7	10.6	11.3	10.5	10.3	10.0	10.9
	MCWBR	8.3	7.7	6.4	5.4	4.7	3.5	3.2	3.0	3.5	5.1	6.8	8.5	
Clear-Sky Solar Irradiance	taub		0.319	0.338	0.362	0.400	0.431	0.440	0.447	0.447	0.403	0.362	0.347	0.324
	taud		2.502	2.457	2.405	2.315	2.284	2.294	2.314	2.300	2.372	2.470	2.459	2.492
	Ebn at Noon		906	920	919	891	861	849	841	838	864	881	864	878
	Edh at Noon		87	100	113	129	134	133	130	130	116	98	90	84
All-Sky Solar Radiation	RadAvg		2.85	3.25	4.37	5.37	5.77	6.47	6.61	6.14	5.17	4.11	3.04	2.51
	RadStd		0.28	0.56	0.38	0.38	0.46	0.56	0.45	0.40	0.43	0.59	0.38	0.33

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+75

Nomenclature: See separate page