

SHREVEPORT REGIONAL, LA, USA

WMO: 722480

Lat: 32.4511N

Lon: 93.8414W

Elev: 280

StdP: 14.55

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13957

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.9	29.0	10.9	9.7	32.3	15.5	12.2	36.9	24.5	53.8	21.3	56.1	6.2	10	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.8	99.4	75.6	96.9	75.9	94.6	75.9	79.7	90.9	78.9	89.8	78.2	88.9	7.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.0	142.0	83.5	76.2	138.0	83.0	75.4	134.3	82.6	43.2	90.7	42.4	90.2	41.7	89.1	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.0	17.9	16.1	DB	19.8	102.3	3.3	3.2	17.4	104.5	15.5	106.4	13.6	108.2	11.2	110.5	
			WB	17.7	80.7	3.2	1.0	15.4	81.4	13.5	82.0	11.7	82.6	9.4	83.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.8	48.1	51.9	58.9	66.1	74.2	80.9	83.8	84.1	78.4	67.6	57.0	49.5
	DBStd	14.97	10.25	10.23	9.13	7.27	5.77	3.84	3.40	4.15	5.66	7.78	8.89	9.63
	HDD50	446	161	91	28	2	0	0	0	0	0	1	33	130
	HDD65	2043	530	381	229	74	8	0	0	0	2	65	265	489
	CDD50	6572	103	143	305	485	749	926	1047	1056	853	546	244	115
	CDD65	2694	7	13	40	107	292	476	582	591	405	145	27	9
	CDH74	28513	21	69	283	846	2596	5079	6921	7153	4115	1245	151	34
	CDH80	13249	0	7	42	173	933	2385	3553	3810	1929	397	19	1
Wind	WSAvg	7.2	8.1	8.4	8.6	8.6	7.6	6.5	5.9	5.6	5.9	6.2	7.0	7.5
Precipitation	PrecAvg	48.6	4.1	4.1	4.3	4.3	4.8	4.3	3.6	2.8	3.3	4.1	4.3	4.6
	PrecMax	82.0	13.0	9.2	12.8	21.9	11.8	17.1	10.6	9.2	9.6	20.4	10.8	11.3
	PrecMin	30.0	0.3	0.4	0.6	0.4	0.2	0.1	0.2	0.0	0.0	0.0	0.5	0.4
	PrecStd	11.6	2.6	2.0	2.3	3.5	3.2	3.4	2.4	2.0	2.5	3.4	2.5	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.9	80.7	84.2	87.6	93.1	99.0	101.7	104.1	100.1	91.3	82.8	78.1
		MCWB	63.7	64.2	67.4	71.4	73.6	75.5	75.2	74.9	73.4	72.2	69.7	67.9
	2%	DB	72.9	75.9	80.6	84.3	89.9	95.8	98.5	100.1	95.9	87.9	78.2	73.7
		MCWB	62.5	63.8	66.0	69.3	73.8	75.5	76.2	75.9	73.9	71.3	67.1	65.0
	5%	DB	69.1	72.0	77.2	81.9	87.8	93.0	95.8	97.3	92.9	84.7	74.8	69.8
		MCWB	61.3	62.8	63.8	68.1	73.2	75.7	76.8	76.2	74.0	69.8	65.3	63.8
	10%	DB	65.3	68.4	73.6	79.3	85.6	90.8	93.5	94.7	90.2	81.1	71.8	66.4
		MCWB	58.3	60.7	63.0	66.7	72.4	75.7	76.9	76.1	73.5	68.8	64.7	61.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.9	69.3	70.4	74.6	78.1	80.1	80.5	80.8	79.3	77.0	72.5	70.0
		MCDB	73.1	74.4	78.0	82.3	87.5	90.1	91.8	92.6	89.2	85.2	78.4	74.4
	2%	WB	65.6	67.1	68.8	72.5	76.3	78.8	79.6	79.7	77.7	75.1	70.2	67.6
		MCDB	70.5	72.9	76.1	80.1	85.4	88.9	91.1	91.3	87.5	82.6	75.4	71.9
	5%	WB	63.6	65.1	67.2	71.0	75.1	78.0	78.8	78.7	76.7	73.4	68.3	65.4
		MCDB	67.9	70.0	73.9	78.3	83.9	88.0	90.1	89.9	86.2	80.0	73.1	69.3
	10%	WB	60.0	62.4	65.1	69.4	74.0	77.2	78.2	77.9	75.7	71.8	65.7	61.7
		MCDB	63.8	67.3	72.4	76.4	82.7	86.9	89.1	88.9	84.7	77.7	70.5	66.0
Mean Daily Temperature Range	5% DB	MDBR	19.4	19.4	20.5	21.3	19.2	18.5	18.8	19.8	20.6	21.6	20.4	19.1
		MCDBR	24.0	23.0	23.5	22.2	20.6	21.0	21.7	23.1	23.5	23.8	22.9	22.6
		MCWBR	15.3	14.0	11.6	10.2	7.8	6.1	5.4	5.8	7.0	10.0	13.5	15.5
	5% WB	MCDBR	19.3	19.3	19.4	18.0	18.1	18.0	18.6	19.2	18.8	18.1	19.2	19.2
		MCWBR	14.9	14.1	12.4	10.2	7.9	6.7	6.2	6.1	6.6	9.7	13.9	15.1
Clear-Sky Solar Irradiance	taub	0.328	0.341	0.364	0.397	0.427	0.459	0.473	0.472	0.419	0.363	0.350	0.333	
	taud	2.505	2.473	2.416	2.323	2.296	2.248	2.240	2.236	2.350	2.482	2.469	2.498	
	Ebn at Noon	283	290	290	284	274	264	260	259	269	279	272	274	
	Edh at Noon	28	31	36	41	42	44	44	44	37	30	28	26	
All-Sky Solar Radiation	RadAvg	858	964	1361	1695	1867	1982	1987	1866	1598	1291	937	745	
	RadStd	82	161	121	107	135	151	149	159	144	176	105	96	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+211	+169
Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page