

VICKSBURG TALLULAH, LA, USA

WMO: 722488

Lat: 32.350N

Lon: 91.028W

Elev: 86

StdP: 14.65

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 03996

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.5	27.6	13.1	10.8	30.5	18.0	13.7	34.7	23.1	46.7	20.3	51.0	5.6	10	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	97.1	77.8	94.9	77.5	92.9	77.3	81.0	90.8	80.0	89.9	79.1	88.9	6.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	150.2	85.3	77.4	142.8	84.6	76.4	138.3	83.8	44.5	90.5	43.4	89.4	42.6	88.7	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.6	17.4	15.6	DB	18.7	100.2	4.0	2.9	15.8	102.2	13.5	103.9	11.2	105.5	8.3	107.6	
			WB	17.2	82.9	3.8	1.6	14.5	84.1	12.3	85.0	10.2	85.9	7.5	87.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.7	47.3	51.2	58.3	66.1	73.5	79.9	82.0	82.0	77.0	66.1	55.6	49.1	(6)
	DBStd	14.72	10.68	10.11	9.06	7.17	5.81	3.42	3.15	3.57	5.55	8.29	8.90	9.99	(7)
	HDD50	501	181	99	30	1	0	0	0	0	0	2	45	143	(8)
	HDD65	2181	553	399	244	73	12	0	0	0	2	91	303	504	(9)
	CDD50	6249	98	132	287	485	729	896	991	993	810	502	212	114	(10)
	CDD65	2453	5	12	36	107	276	446	526	528	363	125	19	10	(11)
	CDH74	24590	16	75	257	884	2457	4584	5623	5701	3543	1249	157	44	(12)
	CDH80	10977	0	5	29	191	893	2138	2757	2914	1625	408	16	1	(13)
(14) Wind	WSAvg	6.4	7.7	8.0	8.3	7.9	6.4	5.0	4.2	4.4	5.4	5.7	6.4	7.4	(14)
(15) Precipitation	PrecAvg	51.5	5.1	4.7	5.0	5.5	4.4	3.7	3.7	3.3	3.0	3.7	4.3	5.5	(15)
	PrecMax	71.4	12.3	9.8	13.1	16.2	9.6	10.9	8.8	9.0	10.5	12.8	10.9	10.1	(16)
	PrecMin	32.7	1.1	1.1	0.8	1.8	1.1	1.1	0.6	0.3	0.0	0.0	1.0	2.7	(17)
	PrecStd	10.7	2.6	2.4	2.6	3.3	2.4	2.3	2.0	2.3	2.3	3.6	2.4	2.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.8	80.6	83.1	87.9	91.5	97.0	99.0	100.6	97.5	91.0	82.2	78.9	(19)
		MCWB	65.2	67.6	67.3	72.5	74.6	76.9	78.6	77.7	76.2	72.6	68.2	68.3	(20)
	2%	DB	72.4	76.0	80.4	84.3	89.8	93.9	96.5	97.5	94.3	87.9	78.8	74.1	(21)
		MCWB	63.9	64.8	66.4	69.6	74.1	76.8	78.2	78.0	75.7	72.5	66.5	66.7	(22)
	5%	DB	68.7	72.4	77.0	82.1	87.8	92.0	93.6	95.0	91.5	84.4	74.9	70.2	(23)
		MCWB	62.0	63.1	64.6	68.4	73.0	76.6	78.4	78.0	75.1	69.9	64.4	64.3	(24)
	10%	DB	64.4	68.1	73.3	79.4	85.4	90.4	91.5	92.7	89.3	81.5	71.6	66.2	(25)
		MCWB	59.3	61.2	63.0	66.8	72.0	76.4	78.3	77.6	74.5	68.5	63.5	61.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.5	69.7	70.6	75.0	78.1	81.2	83.0	82.5	79.7	77.6	72.4	70.5	(27)
		MCDB	73.3	76.9	78.7	83.2	88.3	89.2	91.8	93.0	89.9	86.6	77.3	75.2	(28)
	2%	WB	65.9	67.5	68.6	72.5	76.4	79.8	81.3	80.8	78.3	75.4	69.7	68.1	(29)
		MCDB	70.7	73.5	76.0	80.4	85.4	89.3	90.8	91.4	88.4	83.4	74.8	72.9	(30)
	5%	WB	63.4	65.2	66.8	71.0	75.2	78.7	80.2	79.8	77.3	73.8	67.2	65.5	(31)
		MCDB	66.8	70.3	74.3	79.0	83.8	88.2	89.8	90.2	87.2	80.8	73.2	69.7	(32)
	10%	WB	60.3	62.2	65.0	69.4	74.0	77.8	79.3	78.8	76.3	71.8	64.5	62.1	(33)
		MCDB	64.3	67.8	71.9	76.6	82.2	87.1	88.8	88.8	85.4	77.5	69.4	66.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.7	19.9	20.9	21.2	20.5	19.6	19.3	20.8	22.1	25.0	23.5	20.0	(35)
		MCDBR	22.7	23.7	23.5	22.5	22.1	22.0	21.7	24.1	24.2	26.5	26.8	22.9	(36)
	5% WB	MCWBR	15.3	14.5	12.1	10.5	8.9	8.1	7.9	8.2	9.1	12.2	15.5	16.0	(37)
		MCWBR	18.9	20.1	20.2	18.9	18.7	18.8	19.1	20.4	20.4	20.1	20.9	20.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.324	0.337	0.371	0.407	0.442	0.482	0.500	0.499	0.440	0.367	0.345	0.328	(40)
		taud	2.522	2.485	2.395	2.286	2.245	2.167	2.144	2.144	2.292	2.465	2.478	2.522	(41)
	Ebn at Noon		285	292	288	280	270	258	253	251	263	278	274	277	(42)
		Edh at Noon	27	31	36	42	44	48	49	48	40	31	28	26	(43)
(44) All-Sky Solar Radiation	RadAvg		856	1004	1398	1749	1930	2039	1969	1829	1603	1336	982	757	(44)
	RadStd		75	165	105	127	114	145	116	148	128	180	100	80	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+121

Nomenclature: See separate page