

VICKSBURG TALLULAH, LA, USA

WMO: 722488

Lat: 32.350N

Lon: 91.028W

Elev: 26

StdP: 101.01

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 03996

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.4	-10.5	1.5	-0.8	-7.8	2.0	1.5	10.3	8.2	9.1	10.5	2.5	10	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	36.2	25.4	34.9	25.3	33.8	25.2	27.2	32.7	26.7	32.2	26.2	31.6	2.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.5	29.6	25.2	20.4	29.2	24.7	19.8	28.8	85.7	32.5	83.0	31.9	81.1	31.5	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.8	7.0	-7.4	37.9	2.2	1.6	-9.0	39.0	-10.3	40.0	-11.5	40.9	-13.2	42.0		
			-8.2	28.3	2.1	0.9	-9.7	28.9	-10.9	29.4	-12.1	29.9	-13.6	30.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	8.5	10.6	14.6	19.0	23.1	26.6	27.8	27.8	25.0	19.0	13.1	9.5
	DBStd	8.18	5.93	5.61	5.03	3.98	3.23	1.90	1.75	1.99	3.08	4.61	4.95	5.55
	HDD10.0	278	101	55	17	1	0	0	0	0	0	1	25	79
	HDD18.3	1212	307	222	136	41	7	0	0	0	1	51	168	280
	CDD10.0	3472	54	73	159	269	405	498	551	552	450	279	118	63
	CDD18.3	1363	3	7	20	59	153	248	292	293	202	69	11	6
	CDH23.3	13661	9	42	143	491	1365	2547	3124	3167	1968	694	87	24
	CDH26.7	6098	0	3	16	106	496	1188	1532	1619	903	227	9	1
Wind	WSAvg	2.9	3.4	3.6	3.7	3.5	2.9	2.2	1.9	2.0	2.4	2.5	2.8	3.3
Precipitation	PrecAvg	1308	130	119	128	140	112	95	93	83	77	95	108	139
	PrecMax	1813	313	248	332	411	245	276	224	228	267	326	276	256
	PrecMin	830	28	28	20	45	29	27	16	8	0	0	25	68
	PrecStd	273	67	62	65	83	61	59	51	59	59	91	62	54
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.3	27.0	28.4	31.1	33.0	36.1	37.2	38.1	36.4	32.8	27.9	26.1
		MCWB	18.4	19.8	19.6	22.5	23.7	24.9	25.9	25.4	24.5	22.6	20.1	20.2
	2%	DB	22.4	24.4	26.9	29.1	32.1	34.4	35.9	36.4	34.6	31.0	26.0	23.4
		MCWB	17.7	18.2	19.1	20.9	23.4	24.9	25.7	25.5	24.3	22.5	19.2	19.3
	5%	DB	20.4	22.4	25.0	27.8	31.0	33.4	34.2	35.0	33.1	29.1	23.8	21.2
		MCWB	16.7	17.3	18.1	20.2	22.8	24.8	25.8	25.6	24.0	21.1	18.0	17.9
	10%	DB	18.0	20.1	22.9	26.4	29.6	32.4	33.1	33.7	31.8	27.5	22.0	19.0
		MCWB	15.2	16.2	17.2	19.3	22.2	24.7	25.7	25.3	23.6	20.3	17.5	16.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	20.9	21.4	23.9	25.6	27.3	28.3	28.0	26.5	25.3	22.5	21.4
		MCDB	23.0	25.0	25.9	28.5	31.3	31.8	33.2	33.9	32.2	30.3	25.2	24.0
	2%	WB	18.8	19.7	20.3	22.5	24.6	26.6	27.4	27.1	25.7	24.1	21.0	20.0
		MCDB	21.5	23.0	24.5	26.9	29.6	31.8	32.7	33.0	31.3	28.6	23.8	22.7
	5%	WB	17.5	18.5	19.4	21.7	24.0	25.9	26.8	26.6	25.2	23.2	19.6	18.6
		MCDB	19.3	21.3	23.5	26.1	28.8	31.2	32.1	32.3	30.7	27.1	22.9	20.9
	10%	WB	15.7	16.8	18.4	20.8	23.4	25.4	26.3	26.0	24.6	22.1	18.0	16.7
		MCDB	17.9	19.9	22.2	24.8	27.9	30.6	31.6	31.6	29.7	25.3	20.8	18.9
Mean Daily Temperature Range	5% DB	MDBR	10.9	11.1	11.6	11.8	11.4	10.9	10.7	11.6	12.3	13.9	13.0	11.1
		MCDBR	12.6	13.2	13.0	12.5	12.3	12.2	12.0	13.4	13.5	14.7	14.9	12.7
		MCWBR	8.5	8.1	6.7	5.8	4.9	4.5	4.4	4.6	5.0	6.8	8.6	8.9
	5% WB	MCDBR	10.5	11.2	11.2	10.5	10.4	10.4	10.6	11.4	11.3	11.2	11.6	11.4
		MCWBR	8.2	7.7	6.7	5.7	4.7	4.4	4.4	4.5	4.6	5.9	8.2	8.6
Clear-Sky Solar Irradiance	taub	0.324	0.337	0.371	0.407	0.442	0.482	0.500	0.499	0.440	0.367	0.345	0.328	
	taud	2.522	2.485	2.395	2.286	2.245	2.167	2.144	2.144	2.292	2.465	2.478	2.522	
	Ebn at Noon	899	920	908	884	852	814	797	792	828	875	864	874	
	Edh at Noon	85	97	114	133	140	151	153	151	126	98	88	81	
All-Sky Solar Radiation	RadAvg	2.70	3.17	4.41	5.51	6.08	6.43	6.21	5.77	5.05	4.21	3.10	2.38	
	RadStd	0.24	0.52	0.33	0.40	0.36	0.46	0.36	0.47	0.41	0.57	0.32	0.25	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+67

Nomenclature: See separate page