

CORPUS CHRISTI INTL, TX, USA

WMO: 722510

Lat: 27.774N

Lon: 97.512W

Elev: 44

StdP: 14.67

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12924

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.6	38.1	18.7	14.1	47.8	23.1	17.5	48.4	31.6	70.3	28.4	67.9	10.9	0	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.3	96.9	77.9	95.4	77.9	93.9	77.9	81.3	89.6	80.5	88.5	80.1	88.0	14.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.7	83.4	78.8	149.5	83.2	78.2	146.5	83.0	44.8	89.6	44.1	89.0	43.5	87.6	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.7	25.2	23.1	29.1	101.1	3.5	3.0	26.6	103.3	24.5	105.1	22.6	106.8	20.1	109.0		
			25.8	82.7	3.3	0.9	23.5	83.4	21.6	83.9	19.7	84.4	17.4	85.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	72.9	57.9	61.7	66.9	73.2	78.9	83.1	84.3	85.3	81.7	75.1	66.4	59.4	(6)
(7)		DBStd	11.71	9.32	9.42	7.96	6.14	4.27	2.61	2.26	2.36	4.04	6.73	8.48	9.32	(7)
(8)		HDD50	83	34	17	4	0	0	0	0	0	0	0	5	23	(8)
(9)		HDD65	821	255	157	76	12	0	0	0	0	0	11	86	224	(9)
(10)		CDD50	8435	280	346	528	695	896	993	1065	1093	950	778	495	316	(10)
(11)		CDD65	3697	36	65	135	257	431	543	600	628	500	324	126	52	(11)
(12)		CDH74	38026	186	331	655	1773	4084	6346	7318	7882	5389	2950	850	262	(12)
(13)		CDH80	16084	23	58	123	477	1394	2869	3578	4014	2328	1004	184	32	(13)
(14)	Wind	WSAvg	11.5	12.0	12.7	13.4	14.0	12.9	10.7	10.5	10.0	9.0	10.3	11.1	11.2	(14)
(15)	Precipitation	PrecAvg	31.5	1.5	1.8	1.5	2.0	3.3	3.5	2.0	3.4	5.4	3.6	1.9	1.7	(15)
(16)		PrecMax	48.1	5.9	8.1	4.9	9.2	9.4	13.3	11.9	14.8	20.3	12.0	7.4	9.8	(16)
(17)		PrecMin	14.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.5	0.0	0.1	0.1	(17)
(18)		PrecStd	8.6	1.3	1.7	1.4	2.0	2.4	3.1	2.4	3.0	4.1	3.3	1.6	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.9	85.7	87.9	92.3	93.0	97.1	97.8	99.2	98.9	92.8	87.9	83.5	(19)
(20)			MCWB	67.0	69.1	70.0	70.9	76.6	78.4	78.2	77.3	76.6	77.2	73.6	70.6	(20)
(21)		2%	DB	78.7	81.4	83.0	87.9	90.6	94.3	96.0	97.2	94.6	90.3	84.5	79.9	(21)
(22)			MCWB	67.3	68.7	70.2	72.2	76.4	78.1	78.1	78.2	77.1	76.6	72.8	69.2	(22)
(23)		5%	DB	75.6	78.3	80.4	85.0	88.8	92.5	94.5	95.8	92.4	88.1	82.0	76.9	(23)
(24)			MCWB	65.9	67.9	69.5	72.0	76.5	78.1	78.1	78.2	77.2	75.5	71.6	68.8	(24)
(25)		10%	DB	72.2	74.7	77.7	82.4	87.0	90.9	93.0	94.3	90.3	85.8	79.1	73.8	(25)
(26)			MCWB	65.2	66.2	68.2	71.4	75.9	78.1	78.2	78.1	77.1	74.4	70.2	68.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.2	73.2	74.5	78.0	80.7	82.2	82.2	81.8	81.5	80.4	77.2	74.4	(27)
(28)			MCDWB	77.1	80.6	81.7	86.0	88.6	90.6	90.6	91.2	89.2	86.3	83.6	78.9	(28)
(29)		2%	WB	70.5	71.7	73.1	76.3	79.3	81.0	80.9	80.7	80.4	79.3	75.4	72.9	(29)
(30)			MCDWB	75.0	77.6	79.3	82.8	86.2	88.8	89.4	89.7	87.9	85.4	80.6	76.8	(30)
(31)		5%	WB	69.1	70.4	72.0	75.2	78.3	80.3	80.2	80.2	79.8	78.1	74.0	71.2	(31)
(32)			MCDWB	73.5	75.2	77.1	81.2	85.0	87.6	88.5	88.9	87.2	84.4	79.0	74.8	(32)
(33)		10%	WB	67.1	69.0	70.9	74.1	77.5	79.6	79.6	79.6	79.0	77.1	72.5	69.3	(33)
(34)			MCDWB	71.0	73.0	75.4	79.4	84.0	86.6	87.7	88.0	86.1	83.3	77.3	73.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.4	18.9	17.4	17.3	15.7	16.1	17.3	18.3	16.8	18.3	18.8	18.9	(35)
(36)			MCDBR	23.0	21.8	18.6	18.7	17.4	18.3	19.7	20.3	19.4	18.4	20.1	21.4	(36)
(37)		5% WB	MCWBR	13.8	11.6	8.9	8.2	6.5	5.7	5.3	5.3	6.4	7.5	10.4	13.3	(37)
(38)			MCDBR	17.9	17.1	15.2	14.7	14.3	14.9	16.8	17.7	15.6	15.4	16.8	17.5	(38)
(39)		MCWBR	12.1	10.2	8.2	7.1	6.1	5.5	5.8	5.3	6.0	7.7	10.4	12.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.358	0.365	0.385	0.430	0.470	0.447	0.459	0.449	0.439	0.392	0.377	0.349	(40)
(41)		taud		2.464	2.448	2.389	2.272	2.190	2.315	2.301	2.326	2.320	2.446	2.438	2.504	(41)
(42)		Ebn at Noon		280	288	287	276	264	268	265	267	267	275	271	278	(42)
(43)		Edh at Noon		30	33	37	43	47	41	42	41	40	33	31	28	(43)
(44)	All-Sky Solar Radiation	RadAvg		955	1127	1429	1700	1894	2103	2081	1989	1645	1432	1075	857	(44)
(45)		RadStd		102	189	156	161	140	105	172	111	142	153	111	115	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+182
(47)	Regional (30 neighbors)		N/A	N/A	N/A	+0.63	N/A	N/A	N/A	+225	+196

Nomenclature: See separate page