

CORPUS CHRISTI NAS, TX, USA

WMO: 722515

Lat: 27.683N

Lon: 97.283W

Elev: 6

StdP: 101.26

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12926

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.8	5.0	-5.0	2.5	8.4	-2.5	3.1	9.6	13.5	11.8	12.3	10.4	6.9	0	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	33.8	26.7	33.1	26.6	32.7	26.6	28.2	31.5	27.9	31.1	27.5	30.7	6.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.4	23.3	29.5	27.0	22.8	29.4	26.5	22.1	29.3	90.4	31.2	88.3	31.4	86.9	30.9	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.0	10.9	9.7	DB	0.2	35.9	2.4	2.2	-1.5	37.5	-2.9	38.8	-4.3	40.0	-6.0	41.6	
			WB	-1.7	28.9	2.0	0.9	-3.2	29.5	-4.4	30.0	-5.5	30.5	-7.0	31.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.0	14.8	16.6	19.4	23.0	26.2	28.8	29.3	29.6	27.9	24.6	19.8	15.8	(6)
		DBStd	6.29	4.79	4.72	3.99	2.87	2.11	1.35	1.07	1.20	2.13	3.54	4.56	4.78	
		HDD10.0	35	16	8	2	0	0	0	0	0	0	0	2	8	
		HDD18.3	397	127	78	36	5	0	0	0	0	0	0	37	109	
		CDD10.0	4783	164	193	294	389	501	563	598	607	537	453	297	187	
		CDD18.3	2103	18	31	70	144	243	313	339	348	287	199	83	29	
		CDH23.3	21214	27	58	187	714	2151	3765	4262	4448	3311	1777	443	71	
(13)		CDH26.7	8003	1	4	15	109	546	1524	1872	2060	1320	492	58	3	(13)
(14)	Wind	WSAvg	5.4	5.3	5.6	5.9	6.2	6.2	5.6	5.4	4.9	4.5	5.0	5.2	5.2	(14)
(15)	Precipitation	PrecAvg	798	42	48	32	50	83	67	55	68	139	122	59	41	(15)
(16)		PrecMax	1504	135	150	102	238	400	228	310	222	526	554	249	177	(16)
(17)		PrecMin	391	2	0	0	0	0	0	4	11	4	1	2		(17)
(18)		PrecStd	293	32	41	31	58	78	59	67	58	110	121	57	44	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	25.4	26.8	28.2	31.4	32.5	34.2	34.0	35.0	34.7	32.4	29.8	27.1		(19)
(20)		MCWB	19.8	21.1	21.9	20.9	26.0	27.1	26.8	26.5	25.6	26.5	24.7	22.4		(20)
(21)		DB	24.0	25.1	26.6	29.0	31.2	32.9	33.3	33.9	33.2	31.3	28.2	25.3		(21)
(22)		MCWB	19.9	20.9	21.7	22.8	25.6	26.7	26.7	26.8	26.6	26.1	23.6	21.6		(22)
(23)		DB	22.7	23.7	25.4	27.7	30.2	32.3	32.8	33.2	32.5	30.3	27.2	23.9		(23)
(24)		MCWB	19.0	19.9	21.1	23.0	25.2	26.5	26.7	26.7	26.4	25.3	23.2	20.9		(24)
(25)		DB	21.4	22.5	24.1	26.9	29.3	31.7	32.3	32.7	31.7	29.1	26.0	22.7		(25)
(26)		MCWB	18.7	19.4	20.4	22.6	24.9	26.3	26.6	26.6	26.0	24.6	22.5	20.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	22.1	23.0	23.8	25.8	27.9	28.5	28.4	28.9	28.7	27.9	26.3	23.5		(27)
(28)		MCDB	23.7	25.2	26.6	28.2	29.7	32.2	32.1	32.4	31.8	30.2	28.1	25.7		(28)
(29)		WB	21.3	21.9	22.9	24.8	26.9	27.9	27.9	28.1	27.9	27.0	25.0	22.7		(29)
(30)		MCDB	22.6	23.7	25.2	27.2	29.5	31.2	31.4	31.5	31.1	29.6	27.1	24.5		(30)
(31)		WB	20.5	21.2	22.3	24.1	26.3	27.4	27.5	27.8	27.4	26.4	24.1	21.9		(31)
(32)		MCDB	21.9	22.7	24.2	26.5	29.1	30.6	30.9	31.1	30.5	29.2	26.2	23.2		(32)
(33)		WB	19.5	20.5	21.7	23.6	25.7	27.0	27.2	27.4	26.9	25.7	23.3	21.0		(33)
(34)		MCDB	21.1	21.9	23.3	25.8	28.4	30.2	30.5	30.8	30.0	28.5	25.3	22.4		(34)
(35)	Mean Daily Temperature Range	MDBR	8.3	7.7	7.3	6.8	6.0	6.1	6.2	6.7	7.1	7.3	7.8	8.1		(35)
(36)		5% DB	9.1	8.3	7.3	7.1	6.5	6.3	6.6	7.0	7.5	6.7	7.6	8.5		(36)
(37)		MCWBR	6.1	5.0	4.0	3.7	2.8	2.4	2.3	2.3	3.1	3.4	4.5	5.9		(37)
(38)		5% WB	7.5	6.9	6.3	5.9	5.6	5.7	5.9	6.4	6.7	6.3	7.0	7.6		(38)
(39)		MCWBR	5.7	4.8	3.9	3.5	3.1	2.6	2.4	2.5	3.3	3.9	4.9	6.1		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.363	0.369	0.388	0.430	0.470	0.447	0.463	0.451	0.439	0.393	0.378	0.353		(40)
(41)		taud	2.473	2.459	2.400	2.288	2.210	2.336	2.309	2.341	2.335	2.462	2.455	2.515		(41)
(42)		Ebn at Noon	880	904	904	871	832	846	831	841	842	867	855	874		(42)
(43)		Edh at Noon	96	104	117	135	146	128	131	126	123	103	97	88		(43)
(44)	All-Sky Solar Radiation	RadAvg	3.00	3.57	4.55	5.43	6.07	6.69	6.60	6.31	5.21	4.55	3.41	2.70		(44)
(45)		RadStd	0.33	0.59	0.49	0.52	0.42	0.33	0.53	0.34	0.44	0.46	0.35	0.36		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+103

Nomenclature: See separate page